

**JOB 061748**  
**MILL CREEK STR. & APPRS. (S)**  
**JUNE 24, 2026**

**Question:**

Per notes on Drawing No 69438, the contractor shall excavate the existing embankment as shown to elevation 582.0 approximately 756 Cu. Yrds of unclassified.

Yet the summary of quantities do not account for this in the unclassified excavation line item or unclassified excavation for str-br. For clarification, is this quantity to be part of the Removal of Bridge?

**Answer:**

The plans will be revised to include the appropriate quantities of unclassified excavation and compacted embankment. This will be addressed via addendum.

**Question:**

Given the SP Driving Piling by method A, due to limited space and access to the site, can an alternate form of hammer be considered?

**Answer:**

The piling shall be driven according to the current set of plans. No changes will be made at this time.