

General Info

Actions ▼

Digital ID required

 to disable Q & A notifications for this solicitation.

Deadline

04/14/2026 11:00 AM CDT

Advertised


03/25/2026 11:32 AM CDT

Business Name

Arkansas Department of Transportation - Equipment and Procurement

Location(s)

10324 Interstate 30, Little Rock, Arkansas, 72209



County of Pulaski, AR, Esri, TomTom, Garmin, FAO, NOAA, USGS, EPA, NPS, USFWS

Powered by Esri

Number

M-26-036H

Description

ARCOT Central Campus 5th and 6th Floor Renovation

Job 42-170

FOB: Little Rock, AR

Allows zero unit prices and labor

Yes

Allows negative unit prices and labor

Yes

Allows multiple bids per solicitation

No

✦ Solicitation Summary

AI generated | Quality may vary

This is a commercial office renovation involving selective demolition, asbestos abatement, framing, drywall, interior finishes, and HVAC work on the 5th and 6th floors of the ARDOT Central Office building. May require licensed asbestos abatement contractor and coordination with occupied building operations.

Source: 42-170 Fifth and Sixth Floor Renovations Specifications.pdf



Q & A

Deadline

04/09/2026 03:00 PM CDT

Remarks

For questions about the bidding process contact ARDOT Equipment and Procurement at 501-569-2677 For questions about work specifications contact Cameron Parsons at 501-569-4951.

ATTACHMENT LIST

CONTRACT AND GRANT DISCLOSURE AND CERTIFICATION FORM.pdf (157 KB)

Download, complete, and upload in the Required Document List at the bottom of t...

Standard Bid Conditions Revised 2025.pdf (150 KB)

Certificate For Boycott and Illegal Immigrant Restrictions - 2025.pdf (186 KB)

Download, complete, and upload in the Required Document List at the bottom of t...

42-170 Fifth and Sixth Floor Renovations Specifications.pdf (11.9 MB)

42-170 FIFTH AND SIXTH FLOOR RENOVATIONS PLANS.pdf (6.92 MB)

BID INVITATION

Electronic Sealed bids for furnishing the commodities and/or services described below subject to the Standard Bid Conditions of this Bid Invitation will be publicly opened at the above-noted bid opening date and time at the ARDOT Equipment and Procurement Division located at 11302 West Baseline Road, Little Rock, AR 72209. Bids must be submitted on this form, with attachments when appropriate, or bids will be rejected.

In compliance with this Bid Invitation and subject to all the Conditions thereof, the undersigned offers and agrees to furnish any and all items upon which prices are quoted, at the price set opposite each item.

Company Name:*

Name:*

Address:*

Title:*

Federal Tax ID or Social Security No:*

Phone:*

Fax:

E-mail:*

Signature:*

The Arkansas Department of Transportation(hereafter referred to as ARDOT) is seeking bids for the Renovation of the ARDOT Central Campus 5th and 6th Floors located at 10324 Interstate 30, Little Rock, AR 72209.

Job 42-170

To meet the requirements of the Arkansas Department of Transportation Specifications attached to and made part of this bid.

For questions about Bidding requirements contact Danny Keene (501-569-2674)

For questions about job specifications contact Cameron Parsons (501-569-4951)

A pre-bid meeting is scheduled for all potential bidders at the ARDOT Central Campus located at 10324 Interstate 30, Little Rock, AR 72209 at 10:00 A.M. On April 1, 2026.

All bidders should complete and return the Eligible Bidder Certification (Attachment A) and Disclosure Form (see Page 2 of Standard Bid Conditions – Item 18) and Restriction of Boycott of Israel Certification issued with this bid. A current copy of the DFA Illegal Immigrant Contractor Disclosure Certification (see Page 1 of Standard Bid Conditions – Item 17) should also be submitted with bid.

Bid Bond in the amount of 5% of total bid price is required of all bidders at time of bid opening or bid will be rejected. **Personal and company checks are not acceptable as Bid Bonds. See Condition 4 on page 1 of Standard Bid Conditions.** Bid bonds that are not submitted electronically must be physically received by Equipment & Procurement located at 11302 West Baseline Road, Little Rock, AR 72209 prior to the designated time of the bid opening. Bid Invitation number should be clearly displayed on the sealed envelope or package. **Performance Bond only (no checks of any kind allowed) in the amount of 100% will be required of successful bidder prior to providing goods/services. See Condition 4 on page 1 of Standard Bid Conditions.**

Surety Bonds may be submitted electronically through the online bidding process. If submitting a Surety Bond that is not compatible with Surety 2000 and Tinubu, your company still may do so. Other Surety Companies will still be accepted but must be received in Equipment and Procurement before the time of bid opening at 11302 West Baseline Road, Little Rock, AR 72209 prior to the designated time of the bid opening. This includes Cashier's checks, Certified checks, or Money orders submitted as bid bonds must be physically received by Equipment & Procurement.

On site work will not commence until all requested materials have been acquired and accumulated for inspection by ARDOT.

All work must be completed within 120 calendar days of commencement of work.

Current Arkansas Contractor's License Number must be listed or bid will be rejected. (A.C.A. 17-25-101 et. seq.)

The successful bidder for this project will be required to obtain Builder's Risk Insurance coverage in a minimum amount equal to the total amount bid to provide coverage for all existing structures on the job site.

Time is of the essence in this contract and it is important that work be completed in a timely manner. The sum of \$300 per day will be deducted from any money due to the contractor, not as penalty, but as liquidated damages for losses accrued to the public due to delayed completion of the work.

Bid Information and Specifications are available on-line by going to the ARDOT Web Site – www.ardot.gov and clicking on "Commodities and Services Bids/Contracts Information". Tabulations will also be available at this site after award of bid/contract. If you have any questions, call this office at 501-569-2667.

BID SHEET

1. Renovation of the ARDOT Central Campus 5th and 6th Floors located at 10324 Interstate 30, Little Rock, AR 72209. Job 42-170

Lump Sum*

\$

Arkansas Contractors License*

Notes

Notes

ATTACHMENT A - ELIGIBLE BIDDER CERTIFICATION

The Bidder represents and warrants for itself, its employees and its subcontractors and certifies they:

1. Are not presently debarred, suspended, proposed for debarment, declared ineligible, or voluntarily excluded from covered transactions by any Federal department or agency;
2. Have not within a three-year period preceding this Bid been convicted of or had a civil judgment rendered against them for commission of fraud or a criminal offense in connection with obtaining, attempting to obtain, or performing a public (Federal, State, or local) transaction or contract under a public transaction; violation of Federal or State antitrust statutes or commission of embezzlement, theft, forgery, bribery, falsification or destruction of records, making false statements, or receiving stolen property;
3. Are not presently indicted for or otherwise criminally or civilly charged by a governmental entity (Federal, State, or local) with commission of any of the offenses enumerated in paragraph two (2) of this Certification;
4. Have not within a one-year period preceding this application/Bid had one or more public transactions (Federal, State, or local) terminated for cause or default; and

The Bidder represents, warrants and acknowledges the understanding that restrictions placed on the employment of labor or on the scale of pay for the work on a contract will be the requirements of the Fair Labor Standards Act (Federal Wage-Hour Law) of 1938, 28 USC §201 et seq., and other applicable labor laws.

The person executing this Certification further represents, warrants and affirms the truthfulness and accuracy of the contents of the statements submitted on or with this Certification and understands that the provisions of 31 USC §3801 et seq. are applicable thereto.

BIDDER NAME (Company Name):*

BY (Signature):*

TITLE:*

BID BOND

In the amount of 5%

Guarantee Method*

Choices...

Paper Bid Bond, Cashier's Check, Certified Check, Money Order, or an Annual Bond on File

Confirmation*

Choices...

Electronic Bid Bond

Bond ID*

Surety Agency*

Choices...

Surety State*

Principal*

**ENVELOPE REQUIRED DOCUMENT
LIST**

Name

Omission Terms



The information supplied in this component will be available to the owner-agency immediately after the bid deadline, but before the bid is opened.

Paper Bid Bond, Cashier's Check, Certified Check, Money Order, or an Annual Bond on File
Original, wet-ink documents are required at time of bid opening or bid will be rejected.

I have opted to electronically verify my bid bond.

1 Required Document

REQUIRED DOCUMENT LIST

Name

Omission Terms

Contract and Grant Disclosure and Certification Form
Failure to complete all of the following information may result in a delay in obtaining a contract...

Certificate for Boycott and Illegal Immigrant Restrictions
Failure to complete all of the following information may result in a delay in obtaining a contract...

2 Required Documents

ARDOT - STANDARD BID CONDITIONS

1. **GENERAL:** Any special terms and conditions included in the invitation for bid override these standard terms and conditions. The standard terms and conditions and any special terms and conditions become part of any contract entered into if any or all parts of the bid are accepted by the Arkansas Department of Transportation (ARDOT).
2. **ACCEPTANCE AND REJECTION:** ARDOT reserves the right to reject any or all bids, to accept bids in whole or in part (unless otherwise indicated by bidder), to waive any informalities in bids received, to accept bids on materials or equipment with variations from specifications where efficiency of operation will not be impaired, and to award bids to best serve the interest of the State.
3. **PRICES:** Unless otherwise stated in the Bid Invitation, the following will apply: (1) unit prices shall be bid, (2) prices should be stated in units of quantity specified (feet, each, lbs., etc.), (3) prices must be F.O.B. destination specified in bid, (4) prices must be firm and not subject to escalation, (5) bid must be firm for acceptance for 30 days from bid opening date. In case of errors in extension, unit prices shall govern. Discounts from bid price will not be considered in making awards.
4. **BID BONDS AND PERFORMANCE BONDS:** If required, a **Bid Bond** in the form of a cashier's check, certified check, or surety bond issued by a surety company, in an amount stated in the Bid Invitation, must accompany bid. **Personal and company checks are not acceptable as Bid Bonds.** Surety Bonds may be submitted electronically through the online bidding process. Cashier's checks, Certified checks, or Money orders submitted as bid bonds must be physically received by Equipment & Procurement located at 11302 West Baseline Road, Little Rock, AR 72209 prior to the designated time of the bid opening and should be made payable to the Arkansas Department of Transportation (ARDOT) Failure to submit a Bid Bond as required will cause a bid to be rejected. The Bid Bond will be forfeited as liquidated damages if the successful bidder fails to provide a required Performance Bond within the period stipulated by ARDOT or fails to honor their bid. When a bidder claims and can show clear and convincing evidence that a material mistake was made in the bid and was not the bid intended, the bidder may be permitted to withdraw their bid prior to award without forfeiture of bid bond. Cashier's checks and certified checks submitted as Bid Bonds will be returned to unsuccessful bidders; surety bonds will be retained. The successful bidder will be required to furnish a **Performance Bond** in an amount stated in the Bid Invitation and in the form of a cashier's check, certified check, or surety bond issued by a surety company, unless otherwise stated in the Bid Invitation, as a guarantee of delivery of goods/services in accordance with the specifications and within the time established in the bid. **Personal and company checks are not acceptable as Performance Bonds.** In some cases, a cashier's check or certified check submitted as a Bid Bond and made payable to the Arkansas Department of Transportation (ARDOT) will be held as the Performance Bond of the successful bidder. Cashier's checks or certified checks submitted as Performance Bonds will be refunded shortly after payment has been made to the successful bidder for completion of all terms of the bid; surety bonds will be retained. Surety bonds must be issued by a surety company that is authorized to do business in the State of Arkansas and that is listed on the current United States Department of the Treasury Listing of Approved Sureties. Surety bonds must be executed by a resident or non-resident agent who is licensed by the Arkansas State Insurance Commissioner to represent the surety company executing the bond, and the resident or non-resident agent shall file with the bond the power of attorney of the agent to act on behalf of the bonding company. Certain bids involving labor will require Performance Bonds in the form of surety bonds only (no checks of any kind allowed). These bonds shall not only serve to guarantee the completion of the work, but also to guarantee the excellence of both workmanship and material until the work is finally accepted and the provisions of the Plans, Specifications, and Special Provisions fulfilled. In such cases, the company issuing the surety bond must comply with all stipulations herein and must be named in the U. S. Treasury listing of companies holding Certificates of Authority as acceptable sureties on Federal Bonds and as acceptable reinsuring companies. Any excess between the face amount of the bond and the underwriting limitation of the bonding company shall be protected by reinsurance provided by an acceptable reinsuring company. Annual Bid and Performance Bonds on file with E & P Division must have sufficient unencumbered funds to meet current bonding requirements, or the bid will be rejected, unless the balance is submitted as set forth above, prior to bid opening.
5. **TAXES:** The ARDOT is not exempt from Arkansas State Sales and Use Taxes, or local option city/county sales taxes, when applicable, and bidders are responsible to the State Revenue Department for such taxes. These taxes should not be included in bid prices, but where required by law, will be paid by the ARDOT as an addition thereto, and should be added to the billing to the ARDOT. The ARDOT is exempt from Federal Excise Taxes on all commodities except motor fuels; and excise taxes should not be included in bid prices except for motor fuels. Where applicable, tax exemption certificates will be furnished by the ARDOT.
6. **"ALL OR NONE" BIDS:** Bidders who wish to bid "All or None" on two or more items shall so stipulate on the face of bid sheet; otherwise, bid may be awarded on an individual item basis.
7. **SPECIFICATIONS:** Complete specifications should be attached for any substitution or alternate offered, or where amplification is necessary. Bidder's name must be placed on all attachments to the bid.
8. **EXCEPTIONS TO SPECIFICATIONS:** Any exceptions to the bid specifications must be stated in the bid. Any exceptions to manufacturer's published literature must be stated in the bid, or it will be assumed that bidder is bidding exactly as stated in the literature.
9. **BRAND NAME REFERENCES:** All brand name references in bid specifications refer to that commodity or its equivalent, unless otherwise stated in Bid Invitation. Bidder should state brand or trade name of item being bid, if such name exists.
10. **FREIGHT:** All freight charges should be included in bid price. Any change in common carrier rates authorized by the Interstate Commerce Commission will be adjusted if such change occurs after the bid opening date. Received common carrier bills that reflect ICC authorized rate changes must be furnished.

11. **SAMPLES, LITERATURE, DEMONSTRATIONS:** Samples and technical literature must be provided free of any charge within 14 days of ARDOT request, and free demonstrations within 30 days, unless ARDOT extends time. Failure to provide as requested within this period may cause bid to be rejected. Samples, literature and demonstrations must be substantially the same as the item(s) being bid, unless otherwise agreed to by ARDOT. Samples that are not destroyed will be returned upon request at bidders expense. Samples from successful bidders may be retained for comparison with items actually furnished.
12. **GUARANTY:** Unless otherwise indicated in Bid Invitation, it is understood and agreed that any item offered or shipped on this bid shall be newly manufactured, latest model and design, and in first class condition; and that all containers shall be new, suitable for storage or shipment and in compliance with all applicable laws relating to construction, packaging, labeling and registration.
13. **BACKORDERS OR DELAY IN DELIVERY:** Backorders or failure to deliver within the time required may constitute default. Vendor must give written notice to the ARDOT, as soon as possible, of the reason for any delay and the expected delivery date. The ARDOT has the right to extend delivery if reasons appear valid. If reason or delivery date is not acceptable, vendor is in default.
14. **DEFAULT:** All commodities furnished will be subject to inspection and acceptance by ARDOT after delivery. Default in promised delivery or failure to meet specifications authorizes the ARDOT to cancel award or any portion of same, to reasonably purchase commodities or services elsewhere and to charge full increase, if any, in cost and handling to defaulting vendor. Applicable bonds may be forfeited.
15. **ETHICS:** *"It shall be a breach of ethical standards for a person to be retained, or to retain a person, to solicit or secure a State contract upon an agreement of understanding for a commission, percentage, brokerage, or contingent fee, except for retention of bona fide employees or bona fide established commercial selling agencies maintained by the contractor for the purpose of securing business."* (Arkansas Code, Annotated, Section 19-11-708).
16. **NOTICE OF NONDISCRIMINATION:** The Arkansas State Highway Commission, through ARDOT, complies with all civil rights provisions of federal statutes and related authorities that prohibit discrimination in programs and activities receiving federal financial assistance. Therefore, ARDOT does not discriminate on the basis of race, sex, color, age, national origin, religion (not applicable as a protected group under the Federal Motor Carrier Safety Administration Title VI Program), disability, Limited English Proficiency (LEP), or low-income status in the admission, access to and treatment in the ARDOT's programs and activities, as well as the ARDOT's hiring or employment practices. Complaints of alleged discrimination and inquiries regarding the ARDOT's nondiscrimination policies may be directed to Civil Rights Officer Joanna P. McFadden (ADA/504/Title VI Coordinator), P. O. Box 2261, Little Rock, AR 72203, (501)569-2298, (Voice/TTY 711), or the following email address: joanna.mcfadden@ardot.gov. Free language assistance for Limited English Proficient individuals is available upon request. This notice is available from the ADA/504/Title VI Coordinator in large print, on audiotape and in Braille.
17. **PROHIBITION OF EMPLOYMENT OF ILLEGAL IMMIGRANTS:** Pursuant to Arkansas Code Annotated 19-11-105, all bidders must certify prior to award of a contract that they **do not** employ or contract with any illegal immigrant(s) in its contract with the state. Bidders shall certify online at <https://www.ark.org/dfa/immigrant/index.php>.
18. **DISCLOSURE:** Failure to make any disclosure required by Governor's Executive Order 98-04, or any violation of any rule, regulation, or policy adopted pursuant to that order, **shall** be a material breach of the terms of this contract. Any contractor, whether an individual or entity, who fails to make the required disclosure or who violates any rule, regulation, or policy **shall** be subject to all legal remedies available to the agency.



CERTIFICATION FOR BOYCOTT AND ILLEGAL IMMIGRANT RESTRICTIONS

Pursuant to Arkansas law, a vendor must submit the below certifications prior to entering into a contract with a public entity for an amount as designated by the applicable laws.

1. **Israel Boycott Restriction:** For contracts valued at \$1,000 or greater.
A public entity shall not enter into a contract with a company unless the contract includes a written certification that the person or company is not currently engaged in a boycott of Israel. If at any time after signing this certification the contractor decides to engage in a boycott of Israel, the contractor must notify the contracting public entity in writing. See Arkansas Code Annotated § 25-1-503.
2. **Illegal Immigrant Restriction:** For contracts exceeding \$25,000.
No state agency may enter into or renew a public contract for services with a contractor who employs or contracts with an illegal immigrant. A contractor shall certify that it does not employ, or contract with, illegal immigrants. See Arkansas Code Annotated § 19-11-105.
3. **Energy, Fossil Fuel, Firearms, and Ammunition Industries Boycott Restriction:** For contracts valued at, or exceeding, \$75,000.
A public entity shall not enter into a contract with a company unless the contract includes a written certification that the person or company is not currently engaged in, and agrees for the duration of the contract not to engage in, a boycott of an Energy, Fossil Fuel, Firearms, or Ammunition Industry. If a company does boycott any of these industries, see Arkansas Code Annotated § 25-1-1102.
4. **Scrutinized Company Restriction:** Required with bid or proposal submission.
A state agency shall not contract with a Scrutinized Company or a company that employs a Scrutinized Company as a subcontractor. A Scrutinized Company is a company owned in whole or with a majority ownership by the government of the People's Republic of China. A state agency shall require a company that submits a bid or proposal for a contract to certify that it is not a Scrutinized Company and does not employ a Scrutinized Company as a subcontractor. See Arkansas Code Annotated § 25-1-1203.

By signing this form, the contractor agrees and certifies that it does not, and shall not for the remaining aggregate term of the contract, participate in the activities checked below:

- Do not boycott Israel.
- Do not employ illegal immigrants.
- Do not boycott Energy, Fossil Fuel, Firearms, or Ammunition Industries.
- Do not employ a Scrutinized Company as a subcontractor.

| | |
|-------------------------------|---------------------------------------|
| Contract Number & Description | |
| Name of Public Entity | Arkansas Department of Transportation |
| Name of Vendor/Contractor | |
| AASIS Vendor Number | N/A |

Contractor Signature

Date

CONTRACT AND GRANT DISCLOSURE AND CERTIFICATION FORM

Failure to complete all of the following information may result in a delay in obtaining a contract, lease, purchase agreement, or grant award with any Arkansas State Agency.

SUBCONTRACTOR NAME: _____

Yes No

IS THIS FOR:

Goods? Services? Both?

TAXPAYER ID NAME: _____

FIRST NAME: _____

M.I.: _____

ADDRESS: _____

STATE: _____

ZIP CODE: _____

COUNTY: _____

AS A CONDITION OF OBTAINING, EXTENDING, AMENDING, OR RENEWING A CONTRACT, LEASE, PURCHASE AGREEMENT, OR GRANT AWARD WITH ANY ARKANSAS STATE AGENCY, THE FOLLOWING INFORMATION MUST BE DISCLOSED:

FOR INDIVIDUALS*

Indicate below if: you, your spouse or the brother, sister, parent, or child of you or your spouse is a current or former: member of the General Assembly, Constitutional Officer, State Board or Commission Member, or State Employee:

| Position Held | Mark (<input checked="" type="checkbox"/>) | | Name of Position of Job Held <small>(senator, representative, name of board/ commission, data entry, etc.)</small> | For How Long? | | What is the person(s) name and how are they related to you? <small>(i.e., Jane Q. Public, spouse, John Q. Public, Jr., child, etc.)</small> | Relation |
|----------------------------------|----------------------------------------------|--------|-----------------------------------------------------------------------------------------------------------------------|---------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------|----------|
| | Current | Former | | From MM/YY | To MM/YY | | |
| General Assembly | | | | | | | |
| Constitutional Officer | | | | | | | |
| State Board or Commission Member | | | | | | | |
| State Employee | | | | | | | |

None of the above applies

FOR AN ENTITY (BUSINESS)*

Indicate below if any of the following persons, current or former, hold any position of control or hold any ownership interest of 10% or greater in the entity: member of the General Assembly, Constitutional Officer, State Board or Commission Member, State Employee, or the spouse, brother, sister, parent, or child of a member of the General Assembly, Constitutional Officer, State Board or Commission Member, or State Employee. Position of control means the power to direct the purchasing policies or influence the management of the entity.

| Position Held | Mark (<input checked="" type="checkbox"/>) | | Name of Position of Job Held <small>(senator, representative, name of board/ commission, data entry, etc.)</small> | For How Long? | | What is the person(s) name and what is his/her % of ownership interest and/or what is his/her position of control? | Ownership interest (%) | Position of Control |
|----------------------------------|----------------------------------------------|--------|-----------------------------------------------------------------------------------------------------------------------|---------------|-------------|--------------------------------------------------------------------------------------------------------------------|------------------------|---------------------|
| | Current | Former | | From MM/YY | To MM/YY | | | |
| General Assembly | | | | | | | | |
| Constitutional Officer | | | | | | | | |
| State Board or Commission Member | | | | | | | | |
| State Employee | | | | | | | | |

None of the above applies

Contract and Grant Disclosure and Certification Form

Failure to make any disclosure required by Governor's Executive Order 98-04, or any violation of any rule, regulation, or policy adopted pursuant to that Order, shall be a material breach of the terms of this contract. Any contractor, whether an individual or entity, who fails to make the required disclosure or who violates any rule, regulation, or policy shall be subject to all legal remedies available to the agency.

As an additional condition of obtaining, extending, amending, or renewing a contract with a state agency I agree as follows:

1. Prior to entering into any agreement with any subcontractor, prior or subsequent to the contract date, I will require the subcontractor to complete a **CONTRACT AND GRANT DISCLOSURE AND CERTIFICATION FORM**. Subcontractor shall mean any person or entity with whom I enter an agreement whereby I assign or otherwise delegate to the person or entity, for consideration, all, or any part, of the performance required of me under the terms of my contract with the state agency.
2. I will include the following language as a part of any agreement with a subcontractor:

Failure to make any disclosure required by Governor's Executive Order 98-04, or any violation of any rule, regulation, or policy adopted pursuant to that Order, shall be a material breach of the terms of this subcontract. The party who fails to make the required disclosure or who violates any rule, regulation, or policy shall be subject to all legal remedies available to the contractor.
3. No later than ten (10) days after entering into any agreement with a subcontractor, whether prior or subsequent to the contract date, I will mail a copy of the **CONTRACT AND GRANT DISCLOSURE AND CERTIFICATION FORM** completed by the subcontractor and a statement containing the dollar amount of the subcontract to the state agency.

| | | |
|-----------------------------|-------------|-----------------|
| Signature _____ | Title _____ | Date _____ |
| Vendor Contact Person _____ | Title _____ | Phone No. _____ |

| | | | |
|---------------------|-------------------|-----------------------------|-----------------------------|
| Agency Use Only | | | |
| Agency Number _____ | Agency Name _____ | Agency Contact Person _____ | Agency Phone No. _____ |
| | | Contact Phone No. _____ | Contract or Grant No. _____ |

PROJECT MANUAL

ARDOT **Central Office Fifth and Sixth Floor** **Renovations** Little Rock, Arkansas

Prepared by
Arkansas Department of Transportation

10324 Interstate 30
Little Rock, Arkansas 72209
Project Number 42-170



**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

TABLE OF CONTENTS

PROCUREMENT AND CONTRACTING REQUIREMENTS GROUP

DIVISION 00 – PROCUREMENT AND CONTRACTING REQUIREMENTS

INTRODUCTORY INFORMATION

00 01 10 Table of Contents

SPECIFICATIONS GROUP

GENERAL REQUIREMENTS SUBGROUP

DIVISION 01 - GENERAL REQUIREMENTS

| | |
|----------|-----------------------------------------------|
| 01 10 00 | SUMMARY |
| 01 25 00 | SUBSTITUTION PROCEDURES |
| 01 26 00 | CONTRACT MODIFICATION PROCEDURES |
| 01 29 00 | PAYMENT PROCEDURES |
| 01 31 00 | PROJECT MANAGEMENT AND COORDINATION |
| 01 33 00 | SUBMITTAL PROCEDURES |
| 01 40 00 | QUALITY REQUIREMENTS |
| 01 42 00 | REFERENCES |
| 01 60 00 | PRODUCT REQUIREMENTS |
| 01 73 00 | EXECUTION |
| 01 74 19 | CONSTRUCTION WASTE MANAGEMENT AND DISPOSAL |
| 01 77 00 | CLOSEOUT PROCEDURES |
| 01 78 23 | OPERATION AND MAINTENANCE DATA |
| 01 78 39 | PROJECT RECORD DOCUMENTS |

FACILITY CONSTRUCTION SUBGROUP

DIVISION 02 - EXISTING CONDITIONS

02 41 19 SELECTIVE DEMOLITION

DIVISION 05 - METALS

05 40 00 COLD-FORMED METAL FRAMING

DIVISION 06 - WOOD, PLASTICS, AND COMPOSITES

| | |
|----------|-------------------------------------------------|
| 06 10 00 | ROUGH CARPENTRY |
| 06 41 16 | PLASTIC LAMINATE CLAD ARCHITECTURAL CABINETS |

DIVISION 07 - THERMAL AND MOISTURE PROTECTION

| | |
|----------|-------------------------|
| 07 21 00 | THERMAL INSULATION |
| 07 81 00 | APPLIED FIRE PROTECTION |

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

DIVISION 08 - OPENINGS

| | |
|----------|----------------------------------------------|
| 08 12 13 | HOLLOW METAL FRAMES |
| 08 14 16 | FLUSH WOOD DOORS |
| 08 41 13 | ALUMINUM-FRAMED ENTRANCES AND STOREFRONTS |

DIVISION 09 - FINISHES

| | |
|----------|--------------------------------|
| 09 29 00 | GYPSUM BOARD |
| 09 51 23 | ACOUSTICAL TILE CEILINGS |
| 09 65 13 | RESILIENT BASE AND ACCESSORIES |
| 09 68 13 | TILE CARPETING |
| 09 91 23 | INTERIOR PAINTING |

FACILITY SERVICES SUBGROUP

DIVISION 22 - PLUMBING

| | |
|----------|-----------------------------------------------------------|
| 22 05 00 | COMMON WORK RESULTS FOR PLUMBING |
| 22 05 29 | HANGERS AND SUPPORTS FOR PLUMBING PIPING AND EQUIPMENT |
| 22 07 19 | PLUMBING PIPING INSULATION |
| 22 11 16 | DOMESTIC WATER PIPING |
| 22 13 16 | SANITARY WASTE AND VENT PIPING |
| 22 42 00 | COMMERCIAL PLUMBING FIXTURES |

DIVISION 23 - HEATING, VENTILATING, AND AIR CONDITIONING (HVAC)

| | |
|-------------|-------------------------------------------------|
| 23 05 53 | IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT |
| 23 05 93 | TESTING, ADJUSTING, AND BALANCING FOR HVAC |
| 23 07 13 | DUCT INSULATION |
| 23 31 13 | METAL DUCTS |
| 23 37 13.13 | AIR DIFFUSERS |
| 23 37 13.23 | REGISTERS AND GRILLES |

APPENDICES

APPENDIX A – FIRE PROTECTION REQUIREMENTS

APPENDIX B – ASBESTOS TEST RESULTS

END OF TABLE OF CONTENTS

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 10 00 - SUMMARY

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Project information.
2. Work covered by Contract Documents.
3. Phased construction.
4. Work performed by Owner.
5. Work under Owner's separate contracts.
6. Future work not part of this Project.
7. Owner's product purchase contracts.
8. Owner-furnished/Owner-installed (OFOI) products.
9. Contractor's use of site and premises.
10. Coordination with occupants.
11. Work restrictions.
12. Specification and Drawing conventions.
13. Miscellaneous provisions.

B. Related Requirements:

1. Section 015000 "Temporary Facilities and Controls" for limitations and procedures governing temporary use of Owner's facilities.
2. Section 017300 "Execution" for coordination of Owner-installed products.

1.2 DEFINITIONS

- A. Work Package: A group of specifications, drawings, and schedules prepared by the design team to describe a portion of the Project Work for pricing, permitting, and construction.

1.3 PROJECT INFORMATION

- A. Project Identification: ARDOT Central Office 5th and 6th Floor Renovations.

1. Project Location: 10324 Interstate 30; Little Rock, AR 72209.

- B. Owner: Arkansas Department of Transportation; 10324 I-30; Little Rock, AR 72209.

- C. Other Owner Consultants: Owner has retained the following design professionals who have prepared designated portions of the Contract Documents:

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1. Innerplan Office Interiors: Innerplan Office Interiors has prepared the following portions of the Contract Documents:
 - a. Cubicle Layout and design Representative: Mark Phillips (501) 607-0830.
 - b. Scope of Service: Provide and install cubicle furniture.

1.4 WORK COVERED BY CONTRACT DOCUMENTS

- A. The Work of Project is defined by the Contract Documents and includes, but is not limited to, the following:
 1. Renovation of existing office spaces including selective demolition, framing, drywall, interior finishes, and HVAC work and other Work indicated in the Contract Documents.
 2. Removal and abatement of all fireproofing material, floor tile, ceiling material, piping insulation and any other material that has been tested as an asbestos containing material (ACM). Removal shall be performed by a licensed and certified abatement contractor.
 - a. Work shall be per the requirements Arkansas Regulation 21 and CFR 1926.1101
 - b. Follow all federal, state and local guidelines.
 - c. Provide pre-construction ACM testing for all materials being demolished.
 - d. Space shall be tested at the completion of the demolition and abatement. Provide Air Monitoring and Final Clearance Certificate to the Owner.
 - e. Available test results can be found in Appendix B.
 3. Duct cleaning shall be performed at the completion of the ACM abatement and shall be tested and certified that all potential ACM has been removed from the HVAC duct system.
- B. Type of Contract:
 1. Project will be constructed under a single prime contract.

1.5 WORK PERFORMED BY OWNER

- A. Cooperate fully with Owner, so work may be carried out smoothly, without interfering with or delaying Work under this Contract or work by Owner. Coordinate the Work of this Contract with work performed by Owner.
- B. Concurrent Work: Owner will perform the following construction operations at Project site. Those operations will be conducted simultaneously with Work under this Contract.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1. Installation of cubicle furniture.
2. Electrical lighting and power installation.
3. Data and communication wiring.
4. Plumbing and associated piping.

1.6 CONTRACTOR'S USE OF SITE AND PREMISES

- A. **Restricted Use of Site:** Contractor shall have limited use of Project site for construction operations as indicated on Drawings by the Contract limits and as indicated by requirements of this Section.
- B. **Limits on Use of Site:** Limit use of Project site to Work in areas indicated. Do not disturb portions of Project site beyond areas in which the Work is indicated.
 1. **Limits on Use of Site:** Confine construction operations to active work areas. A portion of the office will be in use during construction. Make necessary arrangements to coordinate the active work so as to create a minimal disturbance in the occupied portion of the office space..
 2. **Driveways, Walkways and Entrances:** Keep driveways, loading areas, and entrances serving premises clear and available to Owner, Owner's employees, and emergency vehicles at all times. Do not use these areas for parking or for storage of materials.
 - a. Schedule deliveries and elevator use to minimize use of elevators, driveways and entrances by construction operations.
- C. **Condition of Existing Building:** Maintain portions of existing building affected by construction operations in a weathertight condition throughout construction period. Repair damage caused by construction operations.
- D. **Condition of Existing Grounds:** Maintain portions of existing grounds, landscaping, and hardscaping affected by construction operations throughout construction period. Repair damage caused by construction operations.

1.7 COORDINATION WITH OCCUPANTS

- A. **Partial Owner Occupancy:** Owner will occupy the premises during entire construction period, with the exception of areas under construction. Cooperate with Owner during construction operations to minimize conflicts and facilitate Owner usage. Perform the Work so as not to interfere with Owner's operations. Maintain existing exits unless otherwise indicated.
 1. Maintain access to existing walkways, corridors, and other adjacent occupied or used facilities. Do not close or obstruct walkways, corridors, or other occupied or used facilities without written permission from Owner and authorities having jurisdiction.
 2. Provide not less than 72 hours' notice to Owner of activities that will affect Owner's operations.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1.8 WORK RESTRICTIONS

- A. Comply with restrictions on construction operations.
 - 1. Comply with limitations on use of public streets, work on public streets, rights of way, and other requirements of authorities having jurisdiction.
- B. On-Site Work Hours: Limit work to between 7:00 a.m. to 5:00 p.m., Monday through Friday, unless otherwise indicated. Work hours may be modified to meet Project requirements if approved by Owner and authorities having jurisdiction.
- C. Demolition material removal and haul-off: Limit delivery and removal of material using the elevators and loading dock to between 6:00 P.M. – 12:00 A.M , M-F or on the weekend. Use of elevator(s) shall be limited to the West elevator. Provide elevator and building protection outside of renovation areas. Contractor is responsible for repair of any elevator or building surface or component that is damaged outside of the project scope.
- D. Existing Utility Interruptions: Do not interrupt utilities serving facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging for temporary utility services according to requirements indicated:
 - 1. Notify Owner not less than seven days in advance of proposed utility interruptions.
 - 2. Obtain Owner's written permission before proceeding with utility interruptions.
- E. Noise, Vibration, Dust, and Odors: Coordinate operations that may result in high levels of noise and vibration, dust, odors, or other disruption to Owner occupancy with Owner.
- F. Provide the necessary control devices for protecting building occupants from injury or harm from any construction related activity.
- G. Smoking and Controlled Substance Restrictions: Use of tobacco products , alcoholic beverages, and other controlled substances on Owner's property is not permitted.
- H. Employee Screening: Comply with Owner's requirements for drug and background screening of Contractor personnel working on Project site.
 - 1. Maintain list of approved screened personnel with Owner's representative.

1.9 SPECIFICATION AND DRAWING CONVENTIONS

- A. Specification Content: The Specifications use certain conventions for the style of language and the intended meaning of certain terms, words, and phrases when used in particular situations. These conventions are as follows:

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1. Imperative mood and streamlined language are generally used in the Specifications. The words "shall," "shall be," or "shall comply with," depending on the context, are implied where a colon (:) is used within a sentence or phrase.
 2. Specification requirements are to be performed by Contractor unless specifically stated otherwise.
- B. Division 00 Contracting Requirements: General provisions of the Contract, including General and Supplementary Conditions, apply to all Sections of the Specifications.
- C. Division 01 General Requirements: Requirements of Sections in Division 01 apply to the Work of all Sections in the Specifications.
- D. Drawing Coordination: Requirements for materials and products identified on Drawings are described in detail in the Specifications. One or more of the following are used on Drawings to identify materials and products:
1. Terminology: Materials and products are identified by the typical generic terms used in the individual Specifications Sections.
 2. Abbreviations: Materials and products are identified by abbreviations scheduled on Drawings and published as part of the U.S. National CAD Standard].
 3. Keynoting: Materials and products are identified by reference keynotes referencing Specification Section numbers found in this Project Manual.

PART 2 - PRODUCTS (Not Used)
PART 3 - EXECUTION (Not Used)

END OF SECTION 01 10 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 25 00 - SUBSTITUTION PROCEDURES

PART 1 - GENERAL

1.1 SUMMARY

- A. The Work of This Section Includes: Administrative and procedural requirements for substitutions.

1.2 DEFINITIONS

- A. Substitutions: Changes in products, materials, equipment, and methods of construction from those required by the Contract Documents.
 - 1. Substitutions for Cause: Changes proposed by Contractor that are required due to changed Project conditions, such as unavailability of product, regulatory changes, or unavailability of required warranty terms.
 - 2. Substitutions for Convenience: Changes proposed by Contractor or Owner that are not required to meet other Project requirements but may offer advantage to Contractor or Owner.

1.3 ACTION SUBMITTALS

- A. Substitution Requests: Submit documentation identifying product or fabrication or installation method to be replaced. Include Specification Section number and title and Drawing numbers and titles.
 - 1. Documentation: Show compliance with requirements for substitutions and the following, as applicable:
 - a. Statement indicating why specified product or fabrication or installation method cannot be provided, if applicable.
 - b. Coordination of information, including a list of changes or revisions needed to other parts of the Work and to construction performed by Owner and separate contractors that will be necessary to accommodate proposed substitution.
 - c. Detailed comparison of significant qualities of proposed substitutions with those of the Work specified. Include annotated copy of applicable Specification Section. Significant qualities may include attributes, such as performance, weight, size, durability, visual effect, sustainable design characteristics, warranties, and specific features and requirements indicated. Indicate deviations, if any, from the Work specified.
 - d. Product Data, including drawings and descriptions of products and fabrication and installation procedures.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- e. Samples, where applicable or requested.
 - f. Certificates and qualification data, where applicable or requested.
 - g. Material test reports from a qualified testing agency, indicating and interpreting test results for compliance with requirements indicated.
 - h. Research reports evidencing compliance with building code in effect for Project, from ICC-ES.
 - i. Detailed comparison of Contractor's construction schedule using proposed substitutions with products specified for the Work, including effect on the overall Contract Time. If specified product or method of construction cannot be provided within the Contract Time, include letter from manufacturer, on manufacturer's letterhead, stating date of receipt of purchase order, lack of availability, or delays in delivery.
 - j. Cost information, including a proposal of change, if any, in the Contract Sum.
 - k. Contractor's certification that proposed substitution complies with requirements in the Contract Documents, except as indicated in substitution request, is compatible with related materials and is appropriate for applications indicated.
 - l. Contractor's waiver of rights to additional payment or time that may subsequently become necessary because of failure of proposed substitution to produce indicated results.
2. Owner's Action: If necessary, Owner will request additional information or documentation for evaluation within seven days of receipt of a request for substitution. Owner will notify Contractor of acceptance or rejection of proposed substitution within 7 days of receipt of request, or seven days of receipt of additional information or documentation, whichever is later.
- a. Forms of Acceptance: Change Order, Construction Change Directive, or Owner's Supplemental Instructions for minor changes in the Work.
 - b. Use product specified if Owner does not issue a decision on use of a proposed substitution within time allocated.

1.4 QUALITY ASSURANCE

- A. Compatibility of Substitutions: Investigate and document compatibility of proposed substitution with related products and materials. Engage a qualified testing agency to perform compatibility tests recommended by manufacturers.

1.5 PROCEDURES

- A. Coordination: Revise or adjust affected work as necessary to integrate work of the approved substitutions.

1.6 SUBSTITUTIONS

- A. Substitutions for Cause: Submit requests for substitution immediately on

SUBSTITUTION
PROCEDURES

01 25 00

2

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

discovery of need for change, but not later than 15 days prior to time required for preparation and review of related submittals.

1. Conditions: Owner will consider Contractor's request for substitution when the following conditions are satisfied. If the following conditions are not satisfied, Owner will return requests without action, except to record noncompliance with these requirements:
 - a. Requested substitution is consistent with the Contract Documents and will produce indicated results.
 - b. Substitution request is fully documented and properly submitted.
 - c. Requested substitution will not adversely affect Contractor's construction schedule.
 - d. Requested substitution has received necessary approvals from authorities having jurisdiction.
 - e. Requested substitution is compatible with other portions of the Work.
 - f. Requested substitution has been coordinated with other portions of the Work.
 - g. Requested substitution provides specified warranty.
 - h. If requested substitution involves more than one contractor, requested substitution has been coordinated with other portions of the Work, is uniform and consistent, is compatible with other products, and is acceptable to all contractors involved.

B. Substitutions for Convenience:

1. Not allowed.
2. Owner will consider requests for substitution if received within 60 days after the Notice of Award. Requests received after that time may be considered or rejected at discretion of Owner.
 - a. Conditions: Owner will consider Contractor's request for substitution when the following conditions are satisfied. If the following conditions are not satisfied, Owner will return requests without action, except to record noncompliance with these requirements:
 - 1) Requested substitution offers Owner a substantial advantage in cost, time, energy conservation, or other considerations, after deducting additional responsibilities Owner must assume. Owner's additional responsibilities may include compensation to Owner for redesign and evaluation services, increased cost of other construction by Owner, and similar considerations.
 - 2) Requested substitution does not require extensive revisions to the Contract Documents.
 - 3) Requested substitution is consistent with the Contract Documents and will produce indicated results.
 - 4) Requested substitution provides sustainable design characteristics that specified product provided for compliance with LEED requirements.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- 5) Substitution request is fully documented and properly submitted.
- 6) Requested substitution will not adversely affect Contractor's construction schedule.
- 7) Requested substitution has received necessary approvals from authorities having jurisdiction.
- 8) Requested substitution is compatible with other portions of the Work.
- 9) Requested substitution has been coordinated with other portions of the Work.
- 10) Requested substitution provides specified warranty.
- 11) If requested substitution involves more than one contractor, requested substitution has been coordinated with other portions of the Work, is uniform and consistent, is compatible with other products, and is acceptable to all contractors involved.

PART 2 - PRODUCTS (Not Used)
PART 3 - EXECUTION (Not Used)

END OF SECTION 01 25 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 26 00 - CONTRACT MODIFICATION PROCEDURES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes administrative and procedural requirements for handling and processing Contract modifications.
- B. Related Requirements:
 - 1. Section 012500 "Substitution Procedures" for administrative procedures for handling requests for substitutions made after the Contract award.

1.2 MINOR CHANGES IN THE WORK

- A. Architect will issue supplemental instructions authorizing minor changes in the Work, not involving adjustment to the Contract Sum or the Contract Time, on web-based Project management software.

1.3 PROPOSAL REQUESTS

- A. Owner-Initiated Proposal Requests: Owner will issue a detailed description of proposed changes in the Work that may require adjustment to the Contract Sum or the Contract Time. If necessary, the description will include supplemental or revised Drawings and Specifications.
 - 1. Work Change Proposal Requests issued by Owner are not instructions either to stop work in progress or to execute the proposed change.
 - 2. Within time specified in Proposal Request or 3 days after receipt of Proposal Request, submit a quotation estimating cost adjustments to the Contract Sum and the Contract Time necessary to execute the change.
 - a. Include a list of quantities of products required or eliminated and unit costs, with total amount of purchases and credits to be made. If requested, furnish survey data to substantiate quantities.
 - b. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
 - c. Include costs of labor and supervision directly attributable to the change.
 - d. Include an updated Contractor's construction schedule that indicates the effect of the change, including, but not limited to, changes in activity duration, start and finish times, and activity relationship. Use available total float before requesting an extension of the Contract Time.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- B. Contractor-Initiated Proposals: If latent or changed conditions require modifications to the Contract, Contractor may initiate a claim by submitting a request for a change to Owner.
1. Include a statement outlining reasons for the change and the effect of the change on the Work. Provide a complete description of the proposed change. Indicate the effect of the proposed change on the Contract Sum and the Contract Time.
 2. Include a list of quantities of products required or eliminated and unit costs, with total amount of purchases and credits to be made. If requested, furnish survey data to substantiate quantities.
 3. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
 4. Include costs of labor and supervision directly attributable to the change.
 5. Include an updated Contractor's construction schedule that indicates the effect of the change, including, but not limited to, changes in activity duration, start and finish times, and activity relationship. Use available total float before requesting an extension of the Contract Time.
 6. Comply with requirements in Section 012500 "Substitution Procedures" if the proposed change requires substitution of one product or system for product or system specified.

1.4 CHANGE ORDER PROCEDURES

- A. On Owner's approval of a Work Change Proposal Request, Owner will issue a Change Order for signatures of Owner and Contractor on form provided as part of web-based Project management software.
- B. Construction Change Directive: Owner may issue a Construction Change Directive on form provided as part of web-based Project management software. Construction Change Directive instructs Contractor to proceed with a change in the Work, for subsequent inclusion in a Change Order.
1. Construction Change Directive contains a complete description of change in the Work. It also designates method to be followed to determine change in the Contract Sum or the Contract Time.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 26 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 29 00 - PAYMENT PROCEDURES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes administrative and procedural requirements necessary to prepare and process Applications for Payment.

1.2 DEFINITIONS

- A. Schedule of Values: A statement furnished by Contractor allocating portions of the Contract Sum to various portions of the Work and used as the basis for reviewing Contractor's Applications for Payment.

1.3 SCHEDULE OF VALUES

- A. Coordination: Coordinate preparation of the schedule of values with preparation of Contractor's construction schedule.
 - 1. Submit the schedule of values to Owner at earliest possible date, but no later than seven days before the date scheduled for submittal of initial Applications for Payment.
- B. Format and Content: Use Project Manual table of contents as a guide to establish line items for the schedule of values. Provide at least one line item for each Specification Section.
 - 1. Identification: Include the following Project identification on the schedule of values:
 - a. Project name and location.
 - b. Owner's name.
 - c. Owner's Project number.
 - d. Contractor's name and address.
 - e. Date of submittal.
 - 2. Arrange schedule of values consistent with format of AIA Document G703.
 - 3. Arrange the schedule of values in tabular form, with separate columns to indicate the following for each item listed:
 - a. Related Specification Section or division.
 - b. Description of the Work.
 - c. Name of subcontractor.
 - d. Name of manufacturer or fabricator.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- e. Name of supplier.
 - f. Change Orders (numbers) that affect value.
 - g. Dollar value of the following, as a percentage of the Contract Sum to nearest one-hundredth percent, adjusted to total 100 percent. Round dollar amounts to whole dollars, with total equal to Contract Sum.
- 4. Provide a breakdown of the Contract Sum in enough detail to facilitate continued evaluation of Applications for Payment and progress reports. Provide multiple line items for principal subcontract amounts in excess of 15 percent of the Contract Sum.
 - 5. Provide a separate line item in the schedule of values for each part of the Work where Applications for Payment may include materials or equipment purchased or fabricated and stored, but not yet installed.
 - 6. Overhead Costs, Proportional Distribution: Include total cost and proportionate share of general overhead and profit for each line item.
 - 7. Closeout Costs. Include separate line items under Contractor and principal subcontracts for Project closeout requirements in an amount totaling five percent of the Contract Sum and subcontract amount.
 - 8. Schedule of Values Revisions: Revise the schedule of values when Change Orders or Construction Change Directives result in a change in the Contract Sum. Include at least one separate line item for each Change Order and Construction Change Directive.

1.4 APPLICATIONS FOR PAYMENT

- A. Each Application for Payment following the initial Application for Payment shall be consistent with previous applications and payments, as certified by Owner paid for by Owner.
- B. Payment Application Times: The date for each progress payment is indicated in the Owner/Contractor Agreement. The period of construction work covered by each Application for Payment is the period indicated in the Agreement.
- C. Payment Application Times: Submit Application for Payment to Owner by the 10th of the month. The period covered by each Application for Payment is one month, ending on the last day of the previous month.
 - 1. Submit draft copy of Application for Payment 3 days prior to due date for review by Owner.
- D. Application for Payment Forms: Use AIA Document G702 and AIA Document G703 as form for Applications for Payment.
 - 1. Other Application for Payment forms proposed by the Contractor may be acceptable to Owner. Submit forms for approval with initial submittal of schedule of values.
- E. Application Preparation: Complete every entry on form. Notarize and execute by a person authorized to sign legal documents on behalf of Contractor. Owner will

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

return incomplete applications without action.

1. Entries shall match data on the schedule of values and Contractor's construction schedule. Use updated schedules if revisions were made.
 2. Include amounts for work completed following previous Application for Payment, whether or not payment has been received. Include only amounts for work completed at time of Application for Payment.
 3. Include amounts of Change Orders and Construction Change Directives issued before last day of construction period covered by application.
- F. Transmittal: Submit 1 signed and notarized original copies of each Application for Payment to Owner by a method ensuring receipt within 24 hours. One copy shall include waivers of lien and similar attachments if required.
1. Transmit each copy with a transmittal form listing attachments and recording appropriate information about application.
- G. Waivers of Mechanic's Lien: With each Application for Payment, submit waivers of mechanic's lien from subcontractors, sub-subcontractors, and suppliers for construction period covered by the previous application.
1. Submit final Application for Payment with or preceded by conditional final waivers from every entity involved with performance of the Work covered by the application who is lawfully entitled to a lien.
 2. Waiver Forms: Submit executed waivers of lien on forms acceptable to Owner.
- H. Initial Application for Payment: Administrative actions and submittals that must precede or coincide with submittal of first Application for Payment include the following:
1. List of subcontractors.
 2. Schedule of values.
 3. Contractor's construction schedule (preliminary if not final).
 4. Certificates of insurance and insurance policies.
 5. Performance and payment bonds.
- I. Application for Payment at Substantial Completion: After Owner issues the Certificate of Substantial Completion, submit an Application for Payment showing 100 percent completion for portion of the Work claimed as substantially complete.
1. Include documentation supporting claim that the Work is substantially complete and a statement showing an accounting of changes to the Contract Sum.
 2. This application shall reflect Certificate(s) of Substantial Completion issued previously for Owner occupancy of designated portions of the Work.
- J. Final Payment Application: After completing Project closeout requirements, submit final Application for Payment with releases and supporting documentation

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

not previously submitted and accepted, including, but not limited, to the following:

1. Evidence of completion of Project closeout requirements.
2. Certification of completion of final punch list items.
3. Insurance certificates for products and completed operations where required and proof that taxes, fees, and similar obligations were paid.
4. Waivers and releases.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 29 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 31 00 - PROJECT MANAGEMENT AND COORDINATION

PART 1 - GENERAL

1.1 SUMMARY

- A. The Work of this Section includes administrative provisions for coordinating construction operations on Project, including, but not limited to, the following:
 - 1. General coordination procedures.
 - 2. Coordination drawings.
 - 3. RFIs.
 - 4. Project meetings.
- B. Each contractor shall participate in coordination requirements. Certain areas of responsibility are assigned to a specific contractor.
- C. Related Requirements:
 - 1. Section 013200 "Construction Progress Documentation" for preparing and submitting Contractor's construction schedule.
 - 2. Section 017300 "Execution" for procedures for coordinating general installation and field-engineering services, including establishment of benchmarks and control points.
 - 3. Section 017700 "Closeout Procedures" for coordinating closeout of the Contract.

1.2 DEFINITIONS

- A. RFI: Request for Information. Request from Owner or Contractor seeking information required by or clarifications of the Contract Documents.

1.3 INFORMATIONAL SUBMITTALS

- A. Subcontract List: Prepare a written summary identifying individuals or firms proposed for each portion of the Work, including those who are to furnish products or equipment fabricated to a special design. Include the following information in tabular form:
 - 1. Name, address, telephone number, and email address of entity performing subcontract or supplying products.
 - 2. Number and title of related Specification Section(s) covered by subcontract.
 - 3. Drawing number and detail references, as appropriate, covered by subcontract.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- B. Key Personnel Names: Within 7 days of starting construction operations, submit a list of key personnel assignments, including superintendent and other personnel in attendance at Project site. Identify individuals and their duties and responsibilities; list addresses, cellular telephone numbers, and e-mail addresses. Provide names, addresses, and telephone numbers of individuals assigned as alternates in the absence of individuals assigned to Project.

1.4 GENERAL COORDINATION PROCEDURES

- A. Coordination: Coordinate construction operations included in different Sections of the Specifications to ensure efficient and orderly installation of each part of the Work. Coordinate construction operations included in different Sections that depend on each other for proper installation, connection, and operation.
 - 1. Schedule construction operations in sequence required to obtain the best results, where installation of one part of the Work depends on installation of other components, before or after its own installation.
 - 2. Coordinate installation of different components to ensure maximum performance and accessibility for required maintenance, service, and repair.
- B. Coordination of Multiple Contracts: Each contractor shall coordinate its construction operations with those of other contractors and entities to ensure efficient and orderly installation of each part of the Work. Each contractor shall coordinate its own operations with operations included in different Sections that depend on each other for proper installation, connection, and operation.
 - 1. Schedule construction operations in sequence required to obtain the best results, where installation of one part of the Work depends on installation of other components, before or after its own installation.
 - 2. Coordinate installation of different components with other contractors to ensure maximum performance and accessibility for required maintenance, service, and repair.
 - 3. Make adequate provisions to accommodate items scheduled for later installation.

1.5 COORDINATION DRAWINGS

- A. Coordination Drawings, General: Prepare coordination drawings according to requirements in individual Sections, and additionally where installation is not completely indicated on Shop Drawings, where limited space availability necessitates coordination, or if coordination is required to facilitate integration of products and materials fabricated or installed by more than one entity.
- B. Coordination Digital Data Files: Prepare coordination digital data files according to the following requirements:
 - 1. File Preparation Format:

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

2. File Submittal Format: Submit or post coordination drawing files using PDF format.
3. Owner will furnish Contractor one set of digital data files of Drawings for use in preparing coordination digital data files.
 - a. Owner makes no representations as to the accuracy or completeness of digital data files as they relate to Drawings.

1.6 REQUEST FOR INFORMATION (RFI)

- A. General: Immediately on discovery of the need for additional information, clarification, or interpretation of the Contract Documents, Contractor shall prepare and submit an RFI in the form specified.
 1. Owner will return without response those RFIs submitted to Owner by other entities controlled by Contractor.
 2. Coordinate and submit RFIs in a prompt manner to avoid delays in Contractor's work or work of subcontractors.
- B. Content of the RFI: Include a detailed, legible description of item needing information or interpretation and the following:
 1. Project name.
 2. Owner name.
 3. Owner's Project number.
 4. Date.
 5. Name of Contractor.
 6. RFI number, numbered sequentially.
 7. RFI subject.
 8. Specification Section number and title and related paragraphs, as appropriate.
 9. Drawing number and detail references, as appropriate.
 10. Field dimensions and conditions, as appropriate.
 11. Contractor's suggested resolution. If Contractor's suggested resolution impacts the Contract Time or the Contract Sum, Contractor shall state impact in the RFI.
 12. Contractor's signature.
 13. Attachments: Include sketches, descriptions, measurements, photos, Product Data, Shop Drawings, coordination drawings, and other information necessary to fully describe items needing interpretation.
 - a. Include dimensions, thicknesses, structural grid references, and details of affected materials, assemblies, and attachments on attached sketches.
- C. RFI Forms: generated form with substantially the same content as indicated above, acceptable to Owner.
 1. Attachments shall be electronic files in PDF format.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- D. Action: Owner will review each RFI, determine action required, and respond. Allow three days for Owner's response for each RFI. RFIs received by Owner after 1:00 p.m. will be considered as received the following working day.
1. The following Contractor-generated RFIs will be returned without action:
 - a. Requests for approval of submittals.
 - b. Requests for approval of substitutions.
 - c. Requests for approval of Contractor's means and methods.
 - d. Requests for coordination information already indicated in the Contract Documents.
 - e. Requests for adjustments in the Contract Time or the Contract Sum.
 - f. Requests for interpretation of Owner's actions on submittals.
 - g. Incomplete RFIs or inaccurately prepared RFIs.
 2. Owner's action may include a request for additional information, in which case Owner's time for response will date from time of receipt by Owner of additional information.
 3. Owner's action on RFIs that may result in a change to the Contract Time or the Contract Sum may be eligible for Contractor to submit Change Proposal according to Section 012600 "Contract Modification Procedures."
 - a. If Contractor believes the RFI response warrants change in the Contract Time or the Contract Sum, notify Owner in writing within 5 days of receipt of the RFI response.
- E. RFI Log: Prepare, maintain, and submit a tabular log of RFIs organized by the RFI number.
1. Project name.
 2. Name and address of Contractor.
 3. Name and address of Owner
 4. RFI number, including RFIs that were returned without action or withdrawn.
 5. RFI description.
 6. Date the RFI was submitted.
 7. Date Owner's response was received.
- F. On receipt of Owner's action, update the RFI log and immediately distribute the RFI response to affected parties. Review response and notify Owner within three days if Contractor disagrees with response.

1.7 DIGITAL PROJECT MANAGEMENT PROCEDURES

- A. Use of Owner's Digital Data Files: Digital data files of Owner's CAD drawings will be provided by Owner for Contractor's use during construction.
1. Digital data files may be used by Contractor in preparing coordination drawings, Shop Drawings, and Project Record Drawings.
 2. Owner makes no representations as to the accuracy or completeness of

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

3. digital data files as they relate to Contract Drawings.
 3. Digital Drawing Software Program: Contract Drawings are available in .pdf format.
 4. The following digital data files will be furnished for each appropriate discipline:
 - a. Floor plans.
 - b. Reflected ceiling plans.
- B. PDF Document Preparation: Where PDFs are required to be submitted to Owner, prepare as follows:
1. Assemble complete submittal package into a single indexed file, incorporating submittal requirements of a single Specification Section and transmittal form with links enabling navigation to each item.
 2. Name file with submittal number or other unique identifier, including revision identifier.
 3. Certifications: Where digitally submitted certificates and certifications are required, provide a digital signature with digital certificate on where indicated.

1.8 PROJECT MEETINGS

- A. General: Schedule and conduct meetings and conferences at Project site unless otherwise indicated.
1. Attendees: Inform participants and others involved, and individuals whose presence is required, of date and time of each meeting. Notify Owner and Owner of scheduled meeting dates and times a minimum of seven days prior to meeting.
 2. Agenda: Prepare the meeting agenda. Distribute the agenda to all invited attendees.
 3. Minutes: Entity responsible for conducting meeting will record significant discussions and agreements achieved. Distribute the meeting minutes to everyone concerned, including Owner, within three days of the meeting.
- B. Preconstruction Conference: Schedule and conduct a preconstruction conference before starting construction, at a time convenient to Owner and Owner, but no later than 7 days after execution of the Agreement.
1. Attendees: Authorized representatives of Owner and their consultants; Contractor and its superintendent; major subcontractors; suppliers; and other concerned parties shall attend the conference. Participants at the conference shall be familiar with Project and authorized to conclude matters relating to the Work.
 2. Agenda: Discuss items of significance that could affect progress, including the following:
 - a. Responsibilities and personnel assignments.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- b. Tentative construction schedule.
 - c. Phasing.
 - d. Critical work sequencing and long lead items.
 - e. Designation of key personnel and their duties.
 - f. Lines of communications.
 - g. Use of web-based Project software.
 - h. Procedures for processing field decisions and Change Orders.
 - i. Procedures for RFIs.
 - j. Procedures for processing Applications for Payment.
 - k. Distribution of the Contract Documents.
 - l. Submittal procedures.
 - m. Preparation of Record Documents.
 - n. Use of the premises and existing building.
 - o. Work restrictions.
 - p. Working hours.
 - q. Owner's occupancy requirements.
 - r. Responsibility for temporary facilities and controls.
 - s. Procedures for moisture and mold control.
 - t. Procedures for disruptions and shutdowns.
 - u. Construction waste management and recycling.
 - v. Parking availability.
 - w. Office, work, and storage areas.
 - x. Equipment deliveries and priorities.
 - y. Security.
 - z. Progress cleaning.
3. Minutes: Entity responsible for conducting meeting will record and distribute meeting minutes.
- C. Preinstallation Conferences: Conduct a preinstallation conference at Project site before each construction activity when required by other Sections and when required for coordination with other construction.
- 1. Attendees: Installer and representatives of manufacturers and fabricators involved in or affected by the installation and its coordination or integration with other materials and installations that have preceded or will follow, shall attend the meeting. Advise Owner of scheduled meeting dates.
 - 2. Do not proceed with installation if the conference cannot be successfully concluded. Initiate whatever actions are necessary to resolve impediments to performance of the Work and reconvene the conference at earliest feasible date.
- D. Progress Meetings: Conduct progress meetings at biweekly intervals.
- 1. Coordinate dates of meetings with preparation of payment requests.
 - 2. Attendees: In addition to representatives of Owner, each contractor, subcontractor, supplier, and other entity concerned with current progress or involved in planning, coordination, or performance of future activities shall be represented at these meetings. All participants at the meeting shall be

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

familiar with Project and authorized to conclude matters relating to the Work.

3. Agenda: Review and correct or approve minutes of previous progress meeting. Review other items of significance that could affect progress. Include topics for discussion as appropriate to status of Project.
 - a. Review present and future needs of each entity present, including the following:
 - 1) Interface requirements.
 - 2) Status of submittals.
 - 3) Deliveries.
 - 4) Access.
 - 5) Site use.
 - 6) Temporary facilities and controls.
 - 7) Progress cleaning.
 - 8) Quality and work standards.
 - 9) Status of correction of deficient items.
 - 10) Field observations.
 - 11) Status of RFIs.
 - 12) Pending changes.
 - 13) Status of Change Orders.
 - 14) Pending claims and disputes.
 - 15) Documentation of information for payment requests.
 4. Minutes: Entity responsible for conducting the meeting will record and distribute the meeting minutes to each party present and to parties requiring information.
 - a. Schedule Updating: Revise Contractor's construction schedule after each progress meeting, where revisions to the schedule have been made or recognized. Issue revised schedule concurrently with the report of each meeting.
- E. Coordination Meetings: Conduct Project coordination meetings at appropriate intervals. Project coordination meetings are in addition to specific meetings held for other purposes, such as progress meetings and preinstallation conferences.
1. Attendees: In addition to representatives of Owner each contractor, subcontractor, supplier, and other entity concerned with current progress or involved in planning, coordination, or performance of future activities shall be represented at these meetings. All participants at the meetings shall be familiar with Project and authorized to conclude matters relating to the Work.
 2. Reporting: Record meeting results and distribute copies to everyone in attendance and to others affected by decisions or actions resulting from each meeting.
- F. Project Closeout Conference: Schedule and conduct a project closeout

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

conference, at a time convenient to Owner, but no later than 30 days prior to the scheduled date of Substantial Completion.

1. Conduct the conference to review requirements and responsibilities related to Project closeout.
2. Attendees: Authorized representatives of Owner and their consultants; Contractor and its superintendent; major subcontractors; suppliers; and other concerned parties shall attend the meeting. Participants at the meeting shall be familiar with Project and authorized to conclude matters relating to the Work.
3. Agenda: Discuss items of significance that could affect or delay Project closeout, including the following:
 - a. Preparation of Record Documents.
 - b. Procedures required prior to inspection for Substantial Completion and for final inspection for acceptance.
 - c. Submittal of written warranties.
 - d. Requirements for preparing operations and maintenance data.
 - e. Requirements for delivery of material samples, attic stock, and spare parts.
 - f. Requirements for demonstration and training.
 - g. Preparation of Contractor's punch list.
 - h. Procedures for processing Applications for Payment at Substantial Completion and for final payment.
 - i. Submittal procedures.
 - j. Installation of Owner's furniture, fixtures, and equipment.
4. Minutes: Entity conducting meeting will record and distribute meeting minutes.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 31 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 33 00 - SUBMITTAL PROCEDURES

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Submittal schedule requirements.
2. Administrative and procedural requirements for submittals.

B. Related Requirements:

1. Section 012900 "Payment Procedures" for submitting Applications for Payment and the schedule of values.
2. Section 013100 "Project Management and Coordination" for submitting coordination drawings and subcontract list and for requirements for web-based Project software.
3. Section 013200 "Construction Progress Documentation" for submitting schedules and reports, including Contractor's construction schedule.
4. Section 017700 "Closeout Procedures" for submitting closeout submittals and maintenance material submittals.
5. Section 017823 "Operation and Maintenance Data" for submitting operation and maintenance manuals.
6. Section 017839 "Project Record Documents" for submitting record Drawings, record Specifications, and record Product Data.

1.2 DEFINITIONS

- A. Action Submittals: Written and graphic information and physical samples that require Architect's responsive action. Action submittals are those submittals indicated in individual Specification Sections as "action submittals."
- B. Informational Submittals: Written and graphic information and physical samples that do not require Architect's responsive action. Submittals may be rejected for not complying with requirements. Informational submittals are those submittals indicated in individual Specification Sections as "informational submittals."

1.3 SUBMITTAL SCHEDULE

- A. Submittal Schedule: Submit, as an action submittal, a list of submittals, arranged in chronological order by dates required by construction schedule. Include time required for review, ordering, manufacturing, fabrication, and delivery when establishing dates. Include additional time required for making corrections or revisions to submittals noted by and additional time for handling and reviewing

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

submittals required by those corrections.

1. Coordinate submittal schedule with list of subcontracts, the schedule of values, and Contractor's construction schedule.
2. Initial Submittal Schedule: Submit concurrently with startup construction schedule. Include submittals required during the first 60 days of construction. List those submittals required to maintain orderly progress of the Work and those required early because of long lead time for manufacture or fabrication.
3. Final Submittal Schedule: Submit concurrently with the first complete submittal of Contractor's construction schedule.
 - a. Submit revised submittal schedule as required to reflect changes in current status and timing for submittals.
4. Format: Arrange the following information in a tabular format:
 - a. Scheduled date for first submittal.
 - b. Specification Section number and title.
 - c. Submittal Category: Action; informational.
 - d. Name of subcontractor.
 - e. Description of the Work covered.
 - f. Scheduled date for Architect's final release or approval.
 - g. Scheduled dates for installation.
 - h. Activity or event number.

1.4 SUBMITTAL FORMATS

A. Submittal Information: Include the following information in each submittal:

1. Project name.
2. Date.
3. Name of Contractor.
4. Name of firm or entity that prepared submittal.
5. Names of subcontractor, manufacturer, and supplier.
6. Unique submittal number, including revision identifier. Include Specification Section number with sequential alphanumeric identifier and alphanumeric suffix for resubmittals.
7. Submittal purpose and description.
8. Number and title of Specification Section, with paragraph number and generic name for each of multiple items.
9. Drawing number and detail references, as appropriate.
10. Indication of full or partial submittal.
11. Location(s) where product is to be installed, as appropriate.
12. Other necessary identification.
13. Remarks.
14. Signature of transmitter.

B. Options: Identify options requiring selection by Architect.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- C. Deviations and Additional Information: On each submittal, clearly indicate deviations from requirements in the Contract Documents, including minor variations and limitations; include relevant additional information and revisions, other than those requested by Architect on previous submittals. Indicate by highlighting on each submittal or noting on attached separate sheet.
- D. Paper Submittals:
1. Place a permanent label or title block on each submittal item for identification; include name of firm or entity that prepared submittal.
 2. Provide a space approximately 6 by 8 inches on label or beside title block to record Contractor's review and approval markings and action taken by Architect.
 3. Action Submittals: Submit three paper copies of each submittal unless otherwise indicated. Architect will return two copies.
 4. Informational Submittals: Submit two paper copies of each submittal unless otherwise indicated. Architect will not return copies.
 5. Additional Copies: Unless additional copies are required for final submittal, and unless Architect observes noncompliance with provisions in the Contract Documents, initial submittal may serve as final submittal.
 6. Transmittal for Submittals: Assemble each submittal individually and appropriately for transmittal and handling. Transmit each submittal using transmittal form.
- E. Electronic Submittals: Prepare submittals as PDF package, incorporating complete information into each PDF file. Name PDF file with submittal number.

1.5 SUBMITTAL PROCEDURES

- A. Prepare and submit submittals required by individual Specification Sections. Types of submittals are indicated in individual Specification Sections.
1. Email: Prepare submittals as PDF package and transmit to Architect by sending via email. Include PDF transmittal form. Include information in email subject line as requested by Architect.
 - a. Architect will return annotated file. Annotate and retain one copy of file as a digital Project Record Document file.
 2. Paper: Prepare submittals in paper form and deliver to Architect.
- B. Coordination: Coordinate preparation and processing of submittals with performance of construction activities.
1. Submit all submittal items required for each Specification Section concurrently unless partial submittals for portions of the Work are indicated on approved submittal schedule.
 2. Submit action submittals and informational submittals required by the same Specification Section as separate packages under separate transmittals.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3. Coordinate transmittal of submittals for related parts of the Work specified in different Sections, so processing will not be delayed because of need to review submittals concurrently for coordination.
 - a. Architect reserves the right to withhold action on a submittal requiring coordination with other submittals until related submittals are received.

- C. Processing Time: Allow time for submittal review, including time for resubmittals, as follows. Time for review shall commence on Architect's receipt of submittal. No extension of the Contract Time will be authorized because of failure to transmit submittals enough in advance of the Work to permit processing, including resubmittals.
 1. Initial Review: Allow 15 days for initial review of each submittal. Allow additional time if coordination with subsequent submittals is required. Owner will advise Contractor when a submittal being processed must be delayed for coordination.
 2. Intermediate Review: If intermediate submittal is necessary, process it in same manner as initial submittal.
 3. Resubmittal Review: Allow 7 days for review of each resubmittal.
 4. Sequential Review: Where sequential review of submittals by Architect's consultants, Owner, or other parties is indicated, allow 21 days for initial review of each submittal.
 5. Concurrent Consultant Review: Where the Contract Documents indicate that submittals may be transmitted simultaneously to Architect and to Architect's consultants, allow 15 days for review of each submittal. Submittal will be returned to Architect before being returned to Contractor.
 - a. Submit one copy of submittal to concurrent reviewer in addition to specified number of copies to Architect.

- D. Resubmittals: Make resubmittals in same form and number of copies as initial submittal.
 1. Note date and content of previous submittal.
 2. Note date and content of revision in label or title block, and clearly indicate extent of revision.
 3. Resubmit submittals until they are marked with approval notation from Architect's action stamp.

- E. Distribution: Furnish copies of final submittals to manufacturers, subcontractors, suppliers, fabricators, installers, authorities having jurisdiction, and others as necessary for performance of construction activities. Show distribution on transmittal forms.

- F. Use for Construction: Retain complete copies of submittals on Project site. Use only final action submittals that are marked with approval notation from Architect's action stamp.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1.6 SUBMITTAL REQUIREMENTS

- A. Product Data: Collect information into a single submittal for each element of construction and type of product or equipment.
1. If information must be specially prepared for submittal because standard published data are unsuitable for use, submit as Shop Drawings, not as Product Data.
 2. Mark each copy of each submittal to show which products and options are applicable.
 3. Include the following information, as applicable:
 - a. Manufacturer's catalog cuts.
 - b. Manufacturer's product specifications.
 - c. Standard color charts.
 - d. Statement of compliance with specified referenced standards.
 - e. Notation of coordination requirements.
 - f. Availability and delivery time information.
 4. For equipment, include the following in addition to the above, as applicable:
 - a. Wiring diagrams that show factory-installed wiring.
 - b. Printed performance curves.
 - c. Operational range diagrams.
 - d. Clearances required to other construction, if not indicated on accompanying Shop Drawings.
 5. Submit Product Data before Shop Drawings, and before or concurrently with Samples.
- B. Shop Drawings: Prepare Project-specific information, drawn accurately to scale. Do not base Shop Drawings on reproductions of the Contract Documents or standard printed data.
1. Preparation: Fully illustrate requirements in the Contract Documents. Include the following information, as applicable:
 - a. Identification of products.
 - b. Schedules.
 - c. Compliance with specified standards.
 - d. Notation of coordination requirements.
 - e. Notation of dimensions established by field measurement.
 - f. Relationship and attachment to adjoining construction clearly indicated.
 - g. Seal and signature of professional engineer if specified.
 2. Paper Sheet Size: Except for templates, patterns, and similar full-size Drawings, submit Shop Drawings on sheets at least Minimum 11".x17".
- C. Samples: Submit Samples for review of type, color, pattern, and texture for a

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

check of these characteristics with other materials.

1. Transmit Samples that contain multiple, related components, such as accessories together in one submittal package.
2. Identification: Permanently attach label on unexposed side of Samples that includes the following:
 - a. Project name and submittal number.
 - b. Generic description of Sample.
 - c. Product name and name of manufacturer.
 - d. Sample source.
 - e. Number and title of applicable Specification Section.
 - f. Specification paragraph number and generic name of each item.
3. Email Transmittal: Provide PDF transmittal. Include digital image file illustrating Sample characteristics and identification information for record.
4. Paper Transmittal: Include paper transmittal, including complete submittal information indicated.
5. Disposition: Maintain sets of approved Samples at Project site, available for quality-control comparisons throughout the course of construction activity. Sample sets may be used to determine final acceptance of construction associated with each set.
 - a. Samples not incorporated into the Work, or otherwise designated as Owner's property, are the property of Contractor.
6. Samples for Initial Selection: Submit manufacturer's color charts consisting of units or sections of units, showing the full range of colors, textures, and patterns available.
 - a. Number of Samples: Submit 2 full set(s) of available choices where color, pattern, texture, or similar characteristics are required to be selected from manufacturer's product line. Architect will return submittal with options selected.

1.7 CONTRACTOR'S REVIEW

- A. Action Submittals and Informational Submittals: Review each submittal and check for coordination with other Work of the Contract and for compliance with the Contract Documents. Note corrections and field dimensions. Mark with approval stamp before submitting to Architect .
- B. Contractor's Approval: Indicate Contractor's approval for each submittal with a uniform approval stamp. Include name of reviewer, date of Contractor's approval, and statement certifying that submittal has been reviewed, checked, and approved for compliance with the Contract Documents.
 1. Owner will not review submittals received from Contractor that do not have Contractor's review and approval.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1.8 OWNER'S REVIEW

- A. Action Submittals: Owner will review each submittal, indicate corrections or revisions required and return.
 - 1. PDF Submittals: Owner will indicate, via markup on each submittal, the appropriate action , as follows:
 - a. Approved - Submittal complies with Contract Documents; Make Corrections Noted - Submittal complies with Contract Documents with minor revisions noted; Revise and Resubmit - Submittal does not comply with Contract Documents; Rejected - Submittal does not meet specifications and is fundamentally incorrect; Reviewed for Record Only - Submittal is for information only..
 - 2. Paper Submittals: Owner will stamp each submittal with an action stamp and will mark stamp appropriately to indicate action , as follows:
 - a. Approved - Submittal complies with Contract Documents; Make Corrections Noted - Submittal complies with Contract Documents with minor revisions noted; Revise and Resubmit - Submittal does not comply with Contract Documents; Rejected - Submittal does not meet specifications and is fundamentally incorrect; Reviewed for Record Only - Submittal is for information only..
- B. Informational Submittals: Owner will review each submittal and will not return it, or will return it if it does not comply with requirements. Owner will forward each submittal to appropriate party.
- C. Partial submittals prepared for a portion of the Work will be reviewed when use of partial submittals has received prior approval from Owner.
- D. Incomplete submittals are unacceptable, will be considered nonresponsive, and will be returned for resubmittal without review.
- E. Owner will return without review submittals received from sources other than Contractor.
- F. Submittals not required by the Contract Documents will be returned by Owner without action.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 33 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 40 00 - QUALITY REQUIREMENTS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes administrative and procedural requirements for quality assurance and quality control.

1.2 DEFINITIONS

- A. Experienced: When used with an entity or individual, "experienced," unless otherwise further described, means having successfully completed a minimum of five previous projects similar in nature, size, and extent to this Project; being familiar with special requirements indicated; and having complied with requirements of authorities having jurisdiction.
- B. Installer/Applicator/Erector: Contractor or another entity engaged by Contractor as an employee, subcontractor, or sub-subcontractor, to perform a particular construction operation, including installation, erection, application, assembly, and similar operations.
 - 1. Use of trade-specific terminology in referring to a Work result does not require that certain construction activities specified apply exclusively to specific trade(s).

1.3 DELEGATED DESIGN SERVICES

- A. Performance and Design Criteria: Where professional design services or certifications by a design professional are specifically required of Contractor by the Contract Documents, provide products and systems complying with specific performance and design criteria indicated.
 - 1. If criteria indicated are not sufficient to perform services or certification required, submit a written request for additional information to Owner.
- B. Delegated Design Services Statement: Submit a statement signed and sealed by the responsible design professional, for each product and system specifically assigned to Contractor to be designed or certified by a design professional, indicating that the products and systems are in compliance with performance and design criteria indicated. Include list of codes, loads, and other factors used in performing these services.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1.4 CONFLICTING REQUIREMENTS

- A. Conflicting Standards and Other Requirements: If compliance with two or more standards or requirements is specified and the standards or requirements establish different or conflicting requirements for minimum quantities or quality levels, inform the Owner regarding the conflict and obtain clarification prior to proceeding with the Work. Refer conflicting requirements that are different, but apparently equal, to Owner for clarification before proceeding.
- B. Minimum Quantity or Quality Levels: The quantity or quality level shown or specified is the minimum provided or performed. The actual installation may comply exactly with the minimum quantity or quality specified, or it may exceed the minimum within reasonable limits. To comply with these requirements, indicated numeric values are minimum or maximum, as appropriate, for the context of requirements. Refer uncertainties to Owner for a decision before proceeding.

1.5 ACTION SUBMITTALS

- A. Mockup Shop Drawings:
 - 1. Include plans, sections, elevations, and details, indicating materials and size of mockup construction.
 - 2. Indicate manufacturer and model number of individual components.
 - 3. Provide axonometric drawings for conditions difficult to illustrate in two dimensions.

1.6 INFORMATIONAL SUBMITTALS

- A. Contractor's Quality-Control Plan: For quality-assurance and quality-control activities and responsibilities.
- B. Qualification Data: For Contractor's quality-control personnel.
- C. Permits, Licenses, and Certificates: For Owner's record, submit copies of permits, licenses, certifications, inspection reports, releases, jurisdictional settlements, notices, receipts for fee payments, judgments, correspondence, records, and similar documents established for compliance with standards and regulations bearing on performance of the Work.

1.7 REPORTS AND DOCUMENTS

- A. Test and Inspection Reports: Prepare and submit certified written reports specified in other Sections. Include the following:
 - 1. Date of issue.
 - 2. Project title and number.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

3. Name, address, telephone number, and email address of testing agency.
 4. Dates and locations of samples and tests or inspections.
 5. Names of individuals making tests and inspections.
 6. Description of the Work and test and inspection method.
 7. Identification of product and Specification Section.
 8. Complete test or inspection data.
 9. Test and inspection results and an interpretation of test results.
 10. Record of temperature and weather conditions at time of sample-taking and testing and inspection.
- B. Manufacturer's Technical Representative's Field Reports: Prepare written information documenting manufacturer's technical representative's tests and inspections specified in other Sections. Include the following:
1. Name, address, telephone number, and email address of technical representative making report.
 2. Statement on condition of substrates and their acceptability for installation of product.
 3. Statement that products at Project site comply with requirements.
 4. Summary of installation procedures being followed, whether they comply with requirements and, if not, what corrective action was taken.
 5. Results of operational and other tests and a statement of whether observed performance complies with requirements.
 6. Statement of whether conditions, products, and installation will affect warranty.
 7. Other required items indicated in individual Specification Sections.

1.8 QUALITY ASSURANCE

- A. Qualifications paragraphs in this article establish the minimum qualification levels required; individual Specification Sections specify additional requirements.
- B. Manufacturer Qualifications: A firm experienced in manufacturing products or systems similar to those indicated for this Project and with a record of successful in-service performance, as well as sufficient production capacity to produce required units. As applicable, procure products from manufacturers able to meet qualification requirements, warranty requirements, and technical or factory-authorized service representative requirements.
- C. Fabricator Qualifications: A firm experienced in producing products similar to those indicated for this Project and with a record of successful in-service performance, as well as sufficient production capacity to produce required units.
- D. Installer Qualifications: A firm or individual experienced in installing, erecting, applying, or assembling work similar in material, design, and extent to that indicated for this Project, whose work has resulted in construction with a record of successful in-service performance.
- E. Professional Engineer Qualifications: A professional engineer who is legally

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

qualified to practice in jurisdiction where Project is located and who is experienced in providing engineering services of the kind indicated. Engineering services are defined as those performed for installations of the system, assembly, or product that is similar in material, design, and extent to those indicated for this Project.

- F. Specialists: Certain Specification Sections require that specific construction activities be performed by entities who are recognized experts in those operations. Specialists will satisfy qualification requirements indicated and engage in the activities indicated.
 - 1. Requirements of authorities having jurisdiction supersede requirements for specialists.
- G. Testing and Inspecting Agency Qualifications: An NRTL, an NVLAP, or an independent agency with the experience and capability to conduct testing and inspection indicated, as documented in accordance with ASTM E329, and with additional qualifications specified in individual Sections; and, where required by authorities having jurisdiction, that is acceptable to authorities.
- H. Manufacturer's Technical Representative Qualifications: An authorized representative of manufacturer who is trained and approved by manufacturer to observe and inspect installation of manufacturer's products that are similar in material, design, and extent to those indicated for this Project.
- I. Factory-Authorized Service Representative Qualifications: An authorized representative of manufacturer who is trained and approved by manufacturer to inspect, demonstrate, repair, and perform service on installations of manufacturer's products that are similar in material, design, and extent to those indicated for this Project.
- J. Preconstruction Testing: Where testing agency is indicated to perform preconstruction testing for compliance with specified requirements for performance and test methods, comply with the following:
 - 1. Contractor's Responsibilities:
 - a. Provide test specimens representative of proposed products and construction.
 - b. Submit specimens in a timely manner with sufficient time for testing and analyzing results to prevent delaying the Work.
 - c. Provide sizes and configurations of test assemblies, mockups, and laboratory mockups to adequately demonstrate capability of products to comply with performance requirements.
 - d. Build site-assembled test assemblies and mockups, using installers who will perform same tasks for Project.
 - e. When testing is complete, remove test specimens and test assemblies; do not reuse products on Project.
 - 2. Testing Agency Responsibilities: Submit a certified written report of each

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

test, inspection, and similar quality-assurance service to Owner with copy to Contractor. Interpret tests and inspections, and state in each report whether tested and inspected Work complies with or deviates from the Contract Documents.

1.9 QUALITY CONTROL

- A. Contractor Responsibilities: Tests and inspections not explicitly assigned to Owner are Contractor's responsibility. Perform additional quality-control activities, whether specified or not, to verify and document that the Work complies with requirements.
1. Unless otherwise indicated, provide quality-control services specified and those required by authorities having jurisdiction. Perform quality-control services required of Contractor by authorities having jurisdiction, whether specified or not.
 2. Engage a qualified testing agency to perform quality-control services.
 - a. Contractor will not employ same entity engaged by Owner, unless agreed to in writing by Owner.
 3. Notify testing agencies at least 48 hours in advance of time when Work that requires testing or inspection will be performed.
 4. Where quality-control services are indicated as Contractor's responsibility, submit a certified written report, in duplicate, of each quality-control service.
 5. Testing and inspection requested by Contractor and not required by the Contract Documents are Contractor's responsibility.
 6. Submit additional copies of each written report directly to authorities having jurisdiction, when they so direct.
- B. Retesting/Reinspecting: Regardless of whether original tests or inspections were Contractor's responsibility, provide quality-control services, including retesting and reinspecting, for construction that replaced Work that failed to comply with the Contract Documents.
- C. Testing Agency Responsibilities: Cooperate with Owner and Contractor in performance of duties. Provide qualified personnel to perform required tests and inspections.
1. Notify Owner and Contractor promptly of irregularities or deficiencies observed in the Work during performance of its services.
 2. Determine the locations from which test samples will be taken and in which in-situ tests are conducted.
 3. Conduct and interpret tests and inspections, and state in each report whether tested and inspected Work complies with or deviates from requirements.
 4. Submit a certified written report, in duplicate, of each test, inspection, and similar quality-control service through Contractor.
 5. Do not release, revoke, alter, or increase the Contract Document

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- requirements or approve or accept any portion of the Work.
6. Do not perform duties of Contractor.
- D. **Manufacturer's Field Services:** Where indicated, engage a factory-authorized service representative to inspect field-assembled components and equipment installation, including service connections. Report results in writing as specified in Section 013300 "Submittal Procedures."
- E. **Manufacturer's Technical Services:** Where indicated, engage a manufacturer's technical representative to observe and inspect the Work. Manufacturer's technical representative's services include participation in preinstallation conferences, examination of substrates and conditions, verification of materials, observation of Installer activities, inspection of completed portions of the Work, and submittal of written reports.
- F. **Contractor's Associated Requirements and Services:** Cooperate with agencies and representatives performing required tests, inspections, and similar quality-control services, and provide reasonable auxiliary services as requested. Notify agency sufficiently in advance of operations to permit assignment of personnel. Provide the following:
1. Access to the Work.
 2. Incidental labor and facilities necessary to facilitate tests and inspections.
 3. Adequate quantities of representative samples of materials that require testing and inspection. Assist agency in obtaining samples.
 4. Facilities for storage and field curing of test samples.
 5. Delivery of samples to testing agencies.
 6. Preliminary design mix proposed for use for material mixes that require control by testing agency.
 7. Security and protection for samples and for testing and inspection equipment at Project site.
- G. **Coordination:** Coordinate sequence of activities to accommodate required quality-assurance and quality-control services with a minimum of delay and to avoid necessity of removing and replacing construction to accommodate testing and inspection.
1. Schedule times for tests, inspections, obtaining samples, and similar activities.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 TEST AND INSPECTION LOG

- A. **Test and Inspection Log:** Prepare a record of tests and inspections. Include the following:

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1. Date test or inspection was conducted.
 2. Description of the Work tested or inspected.
 3. Date test or inspection results were transmitted to Owner.
 4. Identification of testing agency or special inspector conducting test or inspection.
- B. Maintain log at Project site. Post changes and revisions as they occur. Provide access to test and inspection log for Owner's reference during normal working hours.
1. Submit log at Project closeout as part of Project Record Documents.

3.2 REPAIR AND PROTECTION

- A. General: On completion of testing, inspection, sample-taking, and similar services, repair damaged construction and restore substrates and finishes.
1. Provide materials and comply with installation requirements specified in other Specification Sections or matching existing substrates and finishes. Restore patched areas and extend restoration into adjoining areas with durable seams that are as invisible as possible. Comply with the Contract Document requirements for cutting and patching in Section 017300 "Execution."
- B. Protect construction exposed by or for quality-control service activities.
- C. Repair and protection are Contractor's responsibility, regardless of the assignment of responsibility for quality-control services.

END OF SECTION 01 40 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 42 00 - REFERENCES

PART 1 - GENERAL

1.1 DEFINITIONS

- A. General: Basic Contract definitions are included in the Conditions of the Contract.
- B. "Approved": When used to convey Architect's action on Contractor's submittals, applications, and requests, "approved" is limited to Architect's duties and responsibilities as stated in the Conditions of the Contract.
- C. "Directed": A command or instruction by Architect. Other terms, including "requested," "authorized," "selected," "required," and "permitted," have the same meaning as "directed."
- D. "Indicated": Requirements expressed by graphic representations or in written form on Drawings, in Specifications, and in other Contract Documents. Other terms, including "shown," "noted," "scheduled," and "specified," have the same meaning as "indicated."
- E. "Regulations": Laws, ordinances, statutes, and lawful orders issued by authorities having jurisdiction, and rules, conventions, and agreements within the construction industry that control performance of the Work.
- F. "Furnish": Supply and deliver to Project site, ready for unloading, unpacking, assembly, installation, and similar operations.
- G. "Install": Unload, temporarily store, unpack, assemble, erect, place, anchor, apply, work to dimension, finish, cure, protect, clean, and similar operations at Project site.
- H. "Provide": Furnish and install, complete and ready for the intended use.
- I. "Project Site": Space available for performing construction activities. The extent of Project site is shown on Drawings and may or may not be identical with the description of the land on which Project is to be built.

1.2 INDUSTRY STANDARDS

- A. Applicability of Standards: Unless the Contract Documents include more stringent requirements, applicable construction industry standards have the same force and effect as if bound or copied directly into the Contract Documents to the extent referenced. Such standards are made a part of the Contract Documents by reference.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- B. Publication Dates: Comply with standards in effect as of date of the Contract Documents unless otherwise indicated.
 - 1. For standards referenced by applicable building codes, comply with dates of standards as listed in building codes.

- C. Copies of Standards: Each entity engaged in construction on Project should be familiar with industry standards applicable to its construction activity. Copies of applicable standards are not bound with the Contract Documents.
 - 1. Where copies of standards are needed to perform a required construction activity, obtain copies directly from publication source.

1.3 ABBREVIATIONS AND ACRONYMS

- A. Industry Organizations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they are to mean the recognized name of the entities indicated in Gale's "Encyclopedia of Associations: National Organizations of the U.S." or in Columbia Books' "National Trade & Professional Associations of the United States."

- B. Industry Organizations, List: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they are to mean the recognized name of the entities in the following list. The information in this list is subject to change and is believed to be accurate as of the date of the Contract Documents.
 - 1. AABC - Associated Air Balance Council; www.aabc.com.
 - 2. AAMA - American Architectural Manufacturers Association; (see FGIA).
 - 3. AASHTO - American Association of State Highway and Transportation Officials; www.transportation.org.
 - 4. AATCC - American Association of Textile Chemists and Colorists; www.aatcc.org.
 - 5. ACI - American Concrete Institute; www.concrete.org.
 - 6. ACPA - American Concrete Pipe Association; www.concretepipe.org.
 - 7. AEIC - Association of Edison Illuminating Companies, Inc. (The); www.aeic.org.
 - 8. AF&PA - American Forest & Paper Association; www.afandpa.org.
 - 9. AGA - American Gas Association; www.aga.org.
 - 10. AHAM - Association of Home Appliance Manufacturers; www.aham.org.
 - 11. AHRI - Air-Conditioning, Heating, and Refrigeration Institute (The); www.ahrinet.org.
 - 12. AI - Asphalt Institute; www.asphaltinstitute.org.
 - 13. AIA - American Institute of Architects (The); www.aia.org.
 - 14. AISC - American Institute of Steel Construction; www.aisc.org.
 - 15. AISI - American Iron and Steel Institute; www.steel.org.
 - 16. AMCA - Air Movement and Control Association International, Inc.; www.amca.org.
 - 17. ANSI - American National Standards Institute; www.ansi.org.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

18. ASA - Acoustical Society of America; www.acousticalsociety.org.
19. ASCE - American Society of Civil Engineers; www.asce.org.
20. ASCE/SEI - American Society of Civil Engineers/Structural Engineering Institute; (see ASCE).
21. ASHRAE - American Society of Heating, Refrigerating and Air-Conditioning Engineers; www.ashrae.org.
22. ASME - ASME International; American Society of Mechanical Engineers; www.asme.org.
23. ASSE - ASSE International; (American Society of Sanitary Engineering); www.asse-plumbing.org.
24. ASTM - ASTM International; www.astm.org.
25. AWI - Architectural Woodwork Institute; www.awinet.org.
26. AWS - American Welding Society; www.aws.org.
27. AWWA - American Water Works Association; www.awwa.org.
28. BHMA - Builders Hardware Manufacturers Association; www.buildershardware.com.
29. BIA - Brick Industry Association (The); www.gobrick.com.
30. CFFA - Chemical Fabrics and Film Association, Inc.; www.chemicalfabricsandfilm.com.
31. CFSEI - Cold-Formed Steel Engineers Institute; www.cfsei.org.
32. CISCA - Ceilings & Interior Systems Construction Association; www.cisca.org.
33. CISPI - Cast Iron Soil Pipe Institute; www.cispi.org.
34. CLFMI - Chain Link Fence Manufacturers Institute; www.chainlinkinfo.org.
35. CMHA - Concrete Masonry & Hardscape Association; (Formerly: National Concrete Masonry Association); www.masonryandhardscapes.org.
36. CRI - Carpet and Rug Institute (The); www.carpet-rug.org.
37. CRSI - Concrete Reinforcing Steel Institute; www.crsi.org.
38. CSI - Construction Specifications Institute (The); www.csiresources.org.
39. DASMA - Door and Access Systems Manufacturers Association; www.dasma.com.
40. DHI - Door and Hardware Institute; www.dhi.org.
41. EIMA - EIFS Industry Members Association; www.eima.com.
42. EJMA - Expansion Joint Manufacturers Association, Inc.; www.ejma.org.
43. FM Global - FM Global; www.fmglobal.com.
44. GA - Gypsum Association; www.gypsum.org.
45. HMMA - Hollow Metal Manufacturers Association; (see NAAMM).
46. ICC - International Code Council; www.iccsafe.org.
47. ICRI - International Concrete Repair Institute, Inc.; www.icri.org.
48. IEEE SA - IEEE Standards Association; <https://standards.ieee.org>.
49. IGMA - Insulating Glass Manufacturers Alliance; (see FGIA).
50. ISO - International Organization for Standardization; www.iso.org.
51. MBMA - Metal Building Manufacturers Association; www.mbma.com.
52. MCA - Metal Construction Association; www.metalconstruction.org.
53. MFMA - Metal Framing Manufacturers Association, Inc.; www.metalframingmfg.org.
54. MPI - Master Painters Institute; www.paintinfo.com.
55. NADCA - National Air Duct Cleaners Association; www.nadca.com.
56. NEBB - National Environmental Balancing Bureau; www.nebb.org.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

57. NEMA - National Electrical Manufacturers Association; www.nema.org.
 58. NFPA - National Fire Protection Association; www.nfpa.org.
 59. NFPA - NFPA International; (see NFPA).
 60. NSF - NSF International; www.nsf.org.
 61. NSPE - National Society of Professional Engineers; www.nspe.org.
 62. SAE - SAE International; www.sae.org.
 63. SMACNA - Sheet Metal and Air Conditioning Contractors' National Association; www.smacna.org.
- C. Code Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they are to mean the recognized name of the entities in the following list. This information is believed to be accurate as of the date of the Contract Documents.
1. ICC - International Code Council; www.iccsafe.org.
- D. Standards and Regulations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they are to mean the recognized name of the standards and regulations in the following list. This information is subject to change and is believed to be accurate as of the date of the Contract Documents.
1. CFR - Code of Federal Regulations; Available from U.S. Government Publishing Office; www.govinfo.gov.

PART 2 - PRODUCTS (Not Used)
PART 3 - EXECUTION (Not Used)

END OF SECTION 01 42 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 60 00 - PRODUCT REQUIREMENTS

PART 1 - GENERAL

1.1 SUMMARY

- A. The Work of This Section Includes: Administrative and procedural requirements for selection of products for use in Project; product delivery, storage, and handling; manufacturers' standard warranties on products; special warranties; and comparable products.
- B. Related Requirements:
 - 1. Section 011000 "Summary" for Contractor requirements related to Owner-furnished products.
 - 2. Section 012300 "Alternates" for products selected under an alternate.
 - 3. Section 012500 "Substitution Procedures" for requests for substitutions.
 - 4. Section 014200 "References" for applicable industry standards for products specified.
 - 5. Section 017700 "Closeout Procedures" for submitting warranties.

1.2 DEFINITIONS

- A. Products: Items obtained for incorporating into the Work, whether purchased for Project or taken from previously purchased stock. The term "product" includes the terms "material," "equipment," "system," and terms of similar intent.
 - 1. Named Products: Items identified by manufacturer's product name, including make or model number or other designation shown or listed in manufacturer's published product literature that is current as of date of the Contract Documents.
 - 2. New Products: Items that have not previously been incorporated into another project or facility. Salvaged items or items reused from other projects are not considered new products. Items that are manufactured or fabricated to include recycled content materials are considered new products unless otherwise indicated.
 - 3. Comparable Product: Product by named manufacturer that is demonstrated and approved through the comparable product submittal process described in "Comparable Products" Article, to have the indicated qualities related to type, function, dimension, in-service performance, physical properties, appearance, and other characteristics that equal or exceed those of specified product.
- B. Basis-of-Design Product Specification: A specification in which a single manufacturer's product is named and accompanied by the words "basis-of-design product," including make or model number or other designation.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

Published attributes and characteristics of basis-of-design product establish salient characteristics of products.

- C. Subject to Compliance with Requirements: Where the phrase "Subject to compliance with requirements" introduces a product selection procedure in an individual Specification Section, provide products qualified under the specified product procedure. In the event that a named product or product by a named manufacturer does not meet the other requirements of the specifications, select another named product or product from another named manufacturer that does meet the requirements of the specifications; submit a comparable product request or substitution request, if applicable.
- D. Comparable Product Request Submittal: An action submittal requesting consideration of a comparable product, including the following information:
 - 1. Identification of basis-of-design product or fabrication or installation method to be replaced, including Specification Section number and title and Drawing numbers and titles.
 - 2. Data indicating compliance with the requirements specified in "Comparable Products" Article.
- E. Basis-of-Design Product Specification Submittal: An action submittal complying with requirements in Section 013300 "Submittal Procedures."
- F. Substitution: Refer to Section 012500 "Substitution Procedures" for definition and limitations on substitutions.

1.3 QUALITY ASSURANCE

- A. Compatibility of Options: If Contractor is given option of selecting between two or more products for use on Project, select product compatible with products previously selected, even if previously selected products were also options.
- B. Identification of Products: Except for required labels and operating data, do not attach or imprint manufacturer or product names or trademarks on exposed surfaces of products or equipment that will be exposed to view in occupied spaces or on the exterior.
 - 1. Labels: Locate required product labels and stamps on a concealed surface, or, where required for observation following installation, on a visually accessible surface that is inconspicuous.
 - 2. Equipment Nameplates: Provide a permanent nameplate on each item of service- or power-operated equipment. Locate on a visually accessible but inconspicuous surface. Include information essential for operation, including the following:
 - 3. See individual identification Sections in Divisions 21, 22, 23, and 26 for additional equipment identification requirements.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1.4 COORDINATION

- A. Modify or adjust affected work as necessary to integrate work of approved comparable products and approved substitutions.

1.5 PRODUCT DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store, and handle products, using means and methods that will prevent damage, deterioration, and loss, including theft and vandalism. Comply with manufacturer's written instructions.
- B. Delivery and Handling:
 - 1. Schedule delivery to minimize long-term storage at Project site and to prevent overcrowding of construction spaces.
 - 2. Coordinate delivery with installation time to ensure minimum holding time for items that are flammable, hazardous, easily damaged, or sensitive to deterioration, theft, and other losses.
 - 3. Deliver products to Project site in an undamaged condition in manufacturer's original sealed container or other packaging system, complete with labels and instructions for handling, storing, unpacking, protecting, and installing.
 - 4. Inspect products on delivery to determine compliance with the Contract Documents and that products are undamaged and properly protected.
- C. Storage:
 - 1. Provide a secure location and enclosure at Project site for storage of materials and equipment.
 - 2. Store products to allow for inspection and measurement of quantity or counting of units.
 - 3. Store materials in a manner that will not endanger Project structure.
 - 4. Store products that are subject to damage by the elements under cover in a weathertight enclosure above ground, with ventilation adequate to prevent condensation and with adequate protection from wind.
 - 5. Protect foam plastic from exposure to sunlight, except to extent necessary for period of installation and concealment.
 - 6. Comply with product manufacturer's written instructions for temperature, humidity, ventilation, and weather-protection requirements for storage.
 - 7. Protect stored products from damage and liquids from freezing.
 - 8. Provide a secure location and enclosure at Project site for storage of materials and equipment by Owner's construction forces. Coordinate location with Owner.

1.6 PRODUCT WARRANTIES

- A. Warranties specified in other Sections are to be in addition to, and run concurrent with, other warranties required by the Contract Documents.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

Manufacturer's disclaimers and limitations on product warranties do not relieve Contractor of obligations under requirements of the Contract Documents.

1. Manufacturer's Warranty: Written standard warranty form furnished by individual manufacturer for a particular product and issued in the name of Owner or endorsed by manufacturer to Owner.
- B. Submittal Time: Comply with requirements in Section 017700 "Closeout Procedures."

PART 2 - PRODUCTS

2.1 PRODUCT SELECTION PROCEDURES

- A. General Product Requirements: Provide products that comply with the Contract Documents, are undamaged and, unless otherwise indicated, are new at time of installation.
1. Provide products complete with accessories, trim, finish, fasteners, and other items needed for a complete installation and indicated use and effect.
 2. Standard Products: If available, and unless custom products or nonstandard options are specified, provide standard products of types that have been produced and used successfully in similar situations on other projects.
 3. Owner reserves the right to limit selection to products with warranties meeting requirements of the Contract Documents.
 4. Where products are accompanied by the term "as selected," Owner will make selection.
 5. Descriptive, performance, and reference standard requirements in Specifications establish salient characteristics of products.
 6. Or Equal: For products specified by name and accompanied by the term "or equal," "or approved equal," or "or approved," comply with requirements in "Comparable Products" Article to obtain approval for use of an unnamed product.
 - a. Submit additional documentation required by Owner in order to establish equivalency of proposed products. Unless otherwise indicated, evaluation of "or equal" product status is by Owner, whose determination is final.
- B. Product Selection Procedures:
1. Sole Product: Where Specifications name a single manufacturer and product, provide the named product that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered.
 - a. Sole product may be indicated by the phrase "Subject to compliance

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

with requirements, provide the following."

2. Sole Manufacturer/Source: Where Specifications name a single manufacturer or source, provide a product by the named manufacturer or source that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered.
 - a. Sole manufacturer/source may be indicated by the phrase "Subject to compliance with requirements, provide products by the following."
3. Limited List of Products: Where Specifications include a list of names of both manufacturers and products, provide one of the products listed that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered unless otherwise indicated.
 - a. Limited list of products may be indicated by the phrase "Subject to compliance with requirements, provide one of the following."
4. Non-Limited List of Products: Where Specifications include a list of names of both available manufacturers and products, provide one of the products listed or an unnamed product that complies with requirements.
 - a. Non-limited list of products is indicated by the phrase "Subject to compliance with requirements, available products that may be incorporated in the Work include, but are not limited to, the following."
 - b. Provision of an unnamed product is not considered a substitution, if the product complies with requirements.
5. Limited List of Manufacturers: Where Specifications include a list of manufacturers' names, provide a product by one of the manufacturers listed that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered unless otherwise indicated.
 - a. Limited list of manufacturers is indicated by the phrase "Subject to compliance with requirements, provide products by one of the following."
6. Non-Limited List of Manufacturers: Where Specifications include a list of available manufacturers, provide a product by one of the manufacturers listed or a product by an unnamed manufacturer that complies with requirements.
 - a. Non-limited list of manufacturers is indicated by the phrase "Subject to compliance with requirements, available manufacturers whose products may be incorporated in the Work include, but are not limited to, the following."
 - b. Provision of products of an unnamed manufacturer is not considered a substitution, if the product complies with requirements.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

7. Basis-of-Design Product: Where Specifications name a product, or refer to a product indicated on Drawings, and include a list of manufacturers, provide the specified or indicated product or a comparable product by one of the other named manufacturers. Drawings and Specifications may additionally indicate sizes, profiles, dimensions, and other characteristics that are based on the product named. Comply with requirements in "Comparable Products" Article for consideration of an unnamed product by one of the other named manufacturers.
 - a. For approval of products by unnamed manufacturers, comply with requirements in Section 012500 "Substitution Procedures" for substitutions for convenience.
- C. Visual Matching Specification: Where Specifications require the phrase "match sample," provide a product that complies with requirements and matches Owner's sample. Owner's decision will be final on whether a proposed product matches.
 1. If no product available within specified category matches and complies with other specified requirements, comply with requirements in Section 012500 "Substitution Procedures" for proposal of product.
- D. Visual Selection Specification: Where Specifications include the phrase "as selected by Owner from manufacturer's full range" or a similar phrase, select a product that complies with requirements. Owner will select color, gloss, pattern, density, or texture from manufacturer's product line that includes both standard and premium items.

2.2 COMPARABLE PRODUCTS

- A. Conditions for Consideration of Comparable Products: Owner will consider Contractor's request for comparable product when the following conditions are satisfied. If the following conditions are not satisfied, Owner may return requests without action, except to record noncompliance with the following requirements:
 1. Evidence that proposed product does not require revisions to the Contract Documents, is consistent with the Contract Documents, will produce the indicated results, and is compatible with other portions of the Work.
 2. Detailed comparison of significant qualities of proposed product with those of the named basis-of-design product. Significant product qualities include attributes such as type, function, in-service performance and physical properties, weight, dimension, durability, visual characteristics, and other specific features and requirements.
 3. Evidence that proposed product provides specified warranty.
 4. Samples, if requested.
- B. Owner's Action on Comparable Products Submittal: If necessary, Owner will request additional information or documentation for evaluation within seven days of receipt of a request for a comparable product. Owner will notify Contractor [of

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

approval or rejection of proposed comparable product within 15 days of receipt of request, or seven days of receipt of additional information or documentation, whichever is later.

1. Owner's Approval of Submittal: See Section 013300 "Submittal Procedures."
 2. Use product specified if Owner does not issue a decision on use of a comparable product request within time allocated.
- C. Submittal Requirements, Two-Step Process: Approval by Owner of Contractor's request for use of comparable product is not intended to satisfy other submittal requirements. Comply with specified submittal requirements.
- D. Submittal Requirements, Single-Step Process: When acceptable to Owner, incorporate specified submittal requirements of individual Specification Section in combined submittal for comparable products. Approval by Owner of Contractor's request for use of comparable product and of individual submittal requirements will also satisfy other submittal requirements.

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 60 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 73 00 - EXECUTION

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes general administrative and procedural requirements governing execution of the Work, including, but not limited to, the following:
 - 1. Construction layout.
 - 2. Installation.
 - 3. Cutting and patching.
 - 4. Coordination of Owner's portion of the Work.
 - 5. Progress cleaning.
 - 6. Starting and adjusting.
 - 7. Protection of installed construction.
 - 8. Correction of the Work.

- B. Related Requirements:
 - 1. Section 011000 "Summary" for coordination of Owner-performed work, and limits on use of Project site.
 - 2. Section 013300 "Submittal Procedures" for submitting surveys.
 - 3. Section 017700 "Closeout Procedures" for submitting final property survey with Project Record Documents, recording of Owner-accepted deviations from indicated lines and levels, replacing defective work, and final cleaning.
 - 4. Section 024119 "Selective Demolition" for demolition and removal of selected portions of the building.

1.2 DEFINITIONS

- A. Cutting: Removal of in-place construction necessary to permit installation or performance of subsequent work.

- B. Patching: Fitting and repair work required to restore construction to original conditions after installation of subsequent work.

1.3 QUALITY ASSURANCE

- A. Cutting and Patching: Comply with requirements for and limitations on cutting and patching of construction elements.
 - 1. Operational Elements: Do not cut and patch operating elements and related components in a manner that results in reducing their capacity to perform as intended or that results in increased maintenance or decreased

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

operational life or safety.

- a. Plumbing piping systems.
 - b. Mechanical systems piping and ducts.
 - c. Control systems.
 - d. Communication systems.
 - e. Fire-detection and -alarm systems.
 - f. Electrical wiring systems.
2. Other Construction Elements: Do not cut and patch other construction elements or components in a manner that could change their load-carrying capacity, that results in reducing their capacity to perform as intended, or that results in increased maintenance or decreased operational life or safety.
- a. Water, moisture, or vapor barriers.
 - b. Membranes and flashings.
 - c. Exterior curtain-wall construction.
 - d. Equipment supports.
 - e. Piping, ductwork, vessels, and equipment.
 - f. Noise- and vibration-control elements and systems.
3. Visual Elements: Do not cut and patch construction in a manner that results in visual evidence of cutting and patching. Do not cut and patch exposed construction in a manner that would, in Owner's opinion, reduce the building's aesthetic qualities. Remove and replace construction that has been cut and patched in a visually unsatisfactory manner.
- B. Manufacturer's Installation Instructions: Obtain and maintain on-site manufacturer's written recommendations and instructions for installation of specified products and equipment.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. Comply with requirements specified in other Sections.
- B. In-Place Materials: Use materials for patching identical to in-place materials. For exposed surfaces, use materials that visually match in-place adjacent surfaces to the fullest extent possible.
1. If identical materials are unavailable or cannot be used, use materials that, when installed, will provide a match acceptable to Owner for the visual and functional performance of in-place materials. Use materials that are not considered hazardous.
- C. Cleaning Agents: Use cleaning materials and agents recommended by

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

manufacturer or fabricator of the surface to be cleaned. Do not use cleaning agents that are potentially hazardous to health or property or that might damage finished surfaces.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examination and Acceptance of Conditions: Before proceeding with each component of the Work, examine substrates, areas, and conditions, with Installer or Applicator present where indicated, for compliance with requirements for installation tolerances and other conditions affecting performance. Record observations.
 - 1. Examine roughing-in for mechanical and electrical systems to verify actual locations of connections before equipment and fixture installation.
 - 2. Examine walls, floors, and roofs for suitable conditions where products and systems are to be installed.
 - 3. Verify compatibility with and suitability of substrates, including compatibility with existing finishes or primers.
- B. Proceed with installation only after unsatisfactory conditions have been corrected. Proceeding with the Work indicates acceptance of surfaces and conditions.

3.2 PREPARATION

- A. Field Measurements: Take field measurements as required to fit the Work properly. Recheck measurements before installing each product. Where portions of the Work are indicated to fit to other construction, verify dimensions of other construction by field measurements before fabrication. Coordinate fabrication schedule with construction progress to avoid delaying the Work.
- B. Space Requirements: Verify space requirements and dimensions of items shown diagrammatically on Drawings.
- C. Review of Contract Documents and Field Conditions: Immediately on discovery of the need for clarification of the Contract Documents, submit a request for information to Owner in accordance with requirements in Section 013100 "Project Management and Coordination."

3.3 CONSTRUCTION LAYOUT

- A. Verification: Before proceeding to lay out the Work, verify layout information shown on Drawings, in relation to the property survey and existing benchmarks and existing conditions. If discrepancies are discovered, notify Owner promptly.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- B. Record Log: Maintain a log of layout control work. Record deviations from required lines and levels. Include beginning and ending dates and times of surveys, weather conditions, name and duty of each survey party member, and types of instruments and tapes used. Make the log available for reference by Owner.

3.4 INSTALLATION

- A. Locate the Work and components of the Work accurately, in correct alignment and elevation, as indicated.
 - 1. Make vertical work plumb, and make horizontal work level.
 - 2. Where space is limited, install components to maximize space available for maintenance and ease of removal for replacement.
 - 3. Conceal pipes, ducts, and wiring in finished areas unless otherwise indicated.
- B. Comply with manufacturer's written instructions and recommendations for installing products in applications indicated.
- C. Install products at the time and under conditions that will ensure satisfactory results as judged by Owner. Maintain conditions required for product performance until Substantial Completion.
- D. Conduct construction operations, so no part of the Work is subjected to damaging operations or loading in excess of that expected during normal conditions of occupancy of type expected for Project.
- E. Sequence the Work and allow adequate clearances to accommodate movement of construction items on-site and placement in permanent locations.
- F. Tools and Equipment: Select tools or equipment that minimize production of excessive noise levels.
- G. Attachment: Provide blocking and attachment plates and anchors and fasteners of adequate size and number to securely anchor each component in place, accurately located and aligned with other portions of the Work. Where size and type of attachments are not indicated, verify size and type required for load conditions with manufacturer.
 - 1. Mounting Heights: Where mounting heights are not indicated, mount components at heights directed by Owner.
 - 2. Allow for building movement, including thermal expansion and contraction.
 - 3. Coordinate installation of anchorages. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- H. Joints: Make joints of uniform width. Where joint locations in exposed Work are not indicated, arrange joints for the best visual effect, as judged by Owner. Fit exposed connections together to form hairline joints.

3.5 CUTTING AND PATCHING

- A. General: Employ skilled workers to perform cutting and patching. Proceed with cutting and patching at the earliest feasible time, and complete without delay.
1. Cut in-place construction to provide for installation of other components or performance of other construction, and subsequently patch as required to restore surfaces to their original condition.
- B. Existing Warranties: Remove, replace, patch, and repair materials and surfaces cut or damaged during installation or cutting and patching operations, by methods and with materials so as not to void existing warranties.
- C. Temporary Support: Provide temporary support of Work to be cut.
- D. Protection: Protect in-place construction during cutting and patching to prevent damage. Provide protection from adverse weather conditions for portions of Project that might be exposed during cutting and patching operations.
- E. Adjacent Occupied Areas: Where interference with use of adjoining areas or interruption of free passage to adjoining areas is unavoidable, coordinate cutting and patching in accordance with requirements in Section 011000 "Summary."
- F. Existing Utility Services and Mechanical/Electrical Systems: Where existing services/systems are required to be removed, relocated, or abandoned, bypass such services/systems before cutting to minimize interruption to occupied areas.
- G. Cutting: Cut in-place construction by sawing, drilling, breaking, chipping, grinding, and similar operations, including excavation, using methods least likely to damage elements retained or adjoining construction. If possible, review proposed procedures with original Installer; comply with original Installer's written recommendations.
1. In general, use hand or small power tools designed for sawing and grinding, not hammering and chopping. Cut holes and slots neatly to minimum size required, and with minimum disturbance of adjacent surfaces. Temporarily cover openings when not in use.
 2. Finished Surfaces: Cut or drill from the exposed or finished side into concealed surfaces.
 3. Mechanical and Electrical Services: Cut off pipe or conduit in walls or partitions to be removed. Cap, valve, or plug and seal remaining portion of pipe or conduit to prevent entrance of moisture or other foreign matter after cutting.
 4. Proceed with patching after construction operations requiring cutting are complete.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- H. Patching: Patch construction by filling, repairing, refinishing, closing up, and similar operations following performance of other Work. Patch with durable seams that are as invisible as practicable, as judged by Owner. Provide materials and comply with installation requirements specified in other Sections, where applicable.
1. Inspection: Where feasible, test and inspect patched areas after completion to demonstrate physical integrity of installation.
 2. Exposed Finishes: Restore exposed finishes of patched areas and extend finish restoration into retained adjoining construction in a manner that will eliminate evidence of patching and refinishing.
 - a. Clean piping, conduit, and similar features before applying paint or other finishing materials.
 - b. Restore damaged pipe covering to its original condition.
 3. Floors and Walls: Where walls or partitions that are removed extend one finished area into another, patch and repair floor and wall surfaces in the new space. Provide an even surface of uniform finish, color, texture, and appearance. Remove in-place floor and wall coverings and replace with new materials, if necessary, to achieve uniform color and appearance.
 - a. Where patching occurs in a painted surface, prepare substrate and apply primer and intermediate paint coats appropriate for substrate over the patch, and apply final paint coat over entire unbroken surface containing the patch, corner to corner of wall and edge to edge of ceiling. Provide additional coats until patch blends with adjacent surfaces.
 4. Ceilings: Patch, repair, or rehang in-place ceilings as necessary to provide an even-plane surface of uniform appearance.
 5. Exterior Building Enclosure: Patch components in a manner that restores enclosure to a weathertight condition and ensures thermal and moisture integrity of building enclosure.
- I. Cleaning: Clean areas and spaces where cutting and patching are performed. Remove paint, mortar, oils, putty, and similar materials from adjacent finished surfaces.

3.6 COORDINATION OF OWNER'S PORTION OF THE WORK

- A. Site Access: Provide access to Project site for Owner's construction personnel
1. Provide temporary facilities required for Owner-furnished, Contractor-installed products.
 2. Refer to Section 011000 "Summary" for other requirements for Owner-furnished, Contractor-installed products.
- B. Coordination: Coordinate construction and operations of the Work with work

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

performed by Owner's construction personnel.

1. Construction Schedule: Inform Owner of Contractor's preferred construction schedule for Owner's portion of the Work. Adjust construction schedule based on a mutually agreeable timetable. Notify Owner if changes to schedule are required due to differences in actual construction progress.

3.7 PROGRESS CLEANING

- A. Clean Project site and work areas daily, including common areas. Enforce requirements strictly. Dispose of materials lawfully.
 1. Comply with requirements in NFPA 241 for removal of combustible waste materials and debris.
 2. Do not hold waste materials more than seven days during normal weather or three days if the temperature is expected to rise above 80 deg F.
 3. Coordinate progress cleaning for joint-use areas where Contractor and other contractors are working concurrently.
- B. Site: Maintain Project site free of waste materials and debris.
- C. Work Areas: Clean areas where Work is in progress to the level of cleanliness necessary for proper execution of the Work.
 1. Remove liquid spills promptly.
 2. Where dust would impair proper execution of the Work, broom-clean or vacuum the entire work area, as appropriate.
- D. Installed Work: Keep installed work clean. Clean installed surfaces in accordance with written instructions of manufacturer or fabricator of product installed, using only cleaning materials specifically recommended. If specific cleaning materials are not recommended, use cleaning materials that are not hazardous to health or property and that will not damage exposed surfaces.
- E. Concealed Spaces: Remove debris from concealed spaces before enclosing the space.
- F. Exposed Surfaces: Clean exposed surfaces and protect as necessary to ensure freedom from damage and deterioration at time of Substantial Completion.
- G. Waste Disposal: Do not bury or burn waste materials on-site. Do not wash waste materials down sewers or into waterways. Comply with waste disposal requirements in Section 017419 "Construction Waste Management and Disposal."
- H. During handling and installation, clean and protect construction in progress and adjoining materials already in place. Apply protective covering where required to ensure protection from damage or deterioration at Substantial Completion.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- I. Clean and provide maintenance on completed construction as frequently as necessary through the remainder of the construction period. Adjust and lubricate operable components to ensure operability without damaging effects.
- J. Limiting Exposures: Supervise construction operations to ensure that no part of the construction, completed or in progress, is subject to harmful, dangerous, damaging, or otherwise deleterious exposure during the construction period.

3.8 STARTING AND ADJUSTING

- A. Start equipment and operating components to confirm proper operation. Remove malfunctioning units, replace with new units, and retest.
- B. Adjust equipment for proper operation. Adjust operating components for proper operation without binding.
- C. Test each piece of equipment to verify proper operation. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- D. Manufacturer's Field Service: Comply with qualification requirements in Section 014000 "Quality Requirements."

3.9 PROTECTION OF INSTALLED CONSTRUCTION

- A. Provide final protection and maintain conditions that ensure installed Work is without damage or deterioration at time of Substantial Completion.
- B. Protection of Existing Items: Provide protection and ensure that existing items to remain undisturbed by construction are maintained in condition that existed at commencement of the Work.
- C. Comply with manufacturer's written instructions for temperature and relative humidity.

3.10 CORRECTION OF THE WORK

- A. Repair or remove and replace damaged, defective, or nonconforming Work. Restore damaged substrates and finishes.
 - 1. Repairing includes replacing defective parts, refinishing damaged surfaces, touching up with matching materials, and properly adjusting operating equipment.
- B. Repair Work previously completed and subsequently damaged during construction period. Repair to like-new condition.
- C. Restore permanent facilities used during construction to their specified condition.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- D. Remove and replace damaged surfaces that are exposed to view if surfaces cannot be repaired without visible evidence of repair.
- E. Repair components that do not operate properly. Remove and replace operating components that cannot be repaired.
- F. Remove and replace chipped, scratched, and broken glass or reflective surfaces.

END OF SECTION 01 73 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 74 19 - CONSTRUCTION WASTE MANAGEMENT AND DISPOSAL

PART 1 - GENERAL

1.1 SUMMARY

- A. The Work of this Section includes administrative and procedural requirements for the following:
 - 1. Disposing of nonhazardous demolition and construction waste.

1.2 DEFINITIONS

- A. CMU: Concrete masonry units.
- B. Construction Waste: Building, structure, and site improvement materials and other solid waste resulting from construction, remodeling, renovation, or repair operations. Construction waste includes packaging.
- C. Demolition Waste: Building, structure, and site improvement materials resulting from demolition operations.
- D. Disposal: Removal of demolition or construction waste and subsequent salvage, sale, recycling, or deposit in landfill, incinerator acceptable to authorities having jurisdiction, or designated spoil areas on Owner's property.
- E. Salvage and Reuse: Recovery of demolition or construction waste and subsequent incorporation into the Work.

1.3 MATERIALS OWNERSHIP

- A. Unless otherwise indicated, demolition and construction waste becomes property of Contractor.

1.4 QUALITY ASSURANCE

- A. Refrigerant Recovery Technician Qualifications:
 - 1. Universal, certified by EPA-approved certification program.
 - 2. Comply with requirements in Section 024119 "Selective Demolition."
- B. Regulatory Requirements: Comply with transportation and disposal regulations of authorities having jurisdiction.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 DISPOSAL OF WASTE

- A. Except for items or materials to be salvaged or recycled, remove waste materials from Project site and legally dispose of them in a landfill or incinerator acceptable to authorities having jurisdiction.
 - 1. Unless otherwise specified, do not allow waste materials that are to be disposed of accumulate on-site.
 - 2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.

- B. Burning:
 - 1. Do not burn waste materials.

END OF SECTION 01 74 19

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 77 00 - CLOSEOUT PROCEDURES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes administrative and procedural requirements for Contract closeout, including, but not limited to, the following:
 - 1. Substantial Completion procedures.
 - 2. Final Completion procedures.
 - 3. List of incomplete items.
 - 4. Submittal of Project warranties.
 - 5. Final cleaning.
- B. Related Requirements:
 - 1. Section 012900 "Payment Procedures" for requirements for Applications for Payment for Substantial Completion and Final Completion.
 - 2. Section 017823 "Operation and Maintenance Data" for additional operation and maintenance manual requirements.
 - 3. Section 017839 "Project Record Documents" for submitting Record Drawings, Record Specifications, and Record Product Data.

1.2 DEFINITIONS

- A. List of Incomplete Items: Contractor-prepared list of items to be completed or corrected, prepared for the Architect's use prior to Architect's inspection, to determine if the Work is substantially complete.

1.3 CLOSEOUT SUBMITTALS

- A. Certificate of Insurance: For continuing coverage.

1.4 MAINTENANCE MATERIAL SUBMITTALS

- A. Schedule of Maintenance Material Items: For maintenance material submittal items required by other Sections.

1.5 SUBSTANTIAL COMPLETION PROCEDURES

- A. Contractor's List of Incomplete Items: Prepare and submit a list of items to be completed and corrected (Contractor's "punch list"), indicating the value of each

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

item on the list and reasons why the Work is incomplete.

- B. Submittals Prior to Substantial Completion: Complete the following a minimum of 10 days prior to requesting inspection for determining date of Substantial Completion. List items below that are incomplete at time of request.
1. Certificates of Release: Obtain and submit releases from authorities having jurisdiction, permitting Owner unrestricted use of the Work and access to services and utilities. Include occupancy permits, operating certificates, and similar releases.
 2. Submit closeout submittals specified in other Division 01 Sections, including Project Record Documents, operation and maintenance manuals, damage or settlement surveys, property surveys, and similar final record information.
 3. Submit closeout submittals specified in individual Sections, including specific warranties, workmanship bonds, maintenance service agreements, final certifications, and similar documents.
 4. Submit maintenance material submittals specified in individual Sections, including tools, spare parts, extra materials, and similar items, and deliver to location designated by Architect. Label with manufacturer's name and model number.
 5. Submit testing, adjusting, and balancing records.
- C. Inspection: Submit a written request for inspection to determine Substantial Completion a minimum of 10 days prior to date the Work will be completed and ready for final inspection and tests. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare the Certificate of Substantial Completion after inspection or will notify Contractor of items, either on Contractor's list or additional items identified by Architect, that must be completed or corrected before certificate will be issued.
1. Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.
 2. Results of completed inspection will form the basis of requirements for Final Completion.

1.6 FINAL COMPLETION PROCEDURES

- A. Submittals Prior to Final Completion: Before requesting final inspection for determining Final Completion, complete the following:
1. Submit a final Application for Payment in accordance with Section 012900 "Payment Procedures."
 2. Certified List of Incomplete Items: Submit certified copy of Architect's Substantial Completion inspection list of items to be completed or corrected (punch list), endorsed and dated by Architect. Certified copy of the list will state that each item has been completed or otherwise resolved for acceptance.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3. Certificate of Insurance: Submit evidence of final, continuing insurance coverage complying with insurance requirements.
 4. Submit Final Completion photographic documentation.
- B. Inspection: Submit a written request for final inspection to determine acceptance a minimum of 10 days prior to date the Work will be completed and ready for final inspection and tests. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare a final Certificate for Payment after inspection or will notify Contractor of construction that must be completed or corrected before certificate will be issued.
1. Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.

1.7 LIST OF INCOMPLETE ITEMS

- A. Organization of List: Include name and identification of each space and area affected by construction operations for incomplete items and items needing correction including, if necessary, areas disturbed by Contractor that are outside the limits of construction.
1. Organize items applying to each space by major element, including categories for ceilings, individual walls, floors, equipment, and building systems.
 2. Include the following information at the top of each page:
 - a. Project name.
 - b. Date.
 - c. Name of Contractor.
 - d. Page number.
 3. Submit list of incomplete items in the following format:
 - a. PDF Electronic File: Architect will return annotated file.

1.8 SUBMITTAL OF PROJECT WARRANTIES

- A. Time of Submittal: Submit written warranties on request of Architect for designated portions of the Work where warranties are indicated to commence on dates other than date of Substantial Completion, or when delay in submittal of warranties might limit Owner's rights under warranty.
- B. Organize warranty documents into an orderly sequence based on the table of contents of Project Manual.
- C. Warranty Electronic File: Provide warranties and bonds in PDF format. Assemble complete warranty and bond submittal package into a single electronic PDF file

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

with bookmarks enabling navigation to each item. Provide bookmarked table of contents at beginning of document.

1. Submit by email to Architect.
- D. Provide additional copies of each warranty to include in operation and maintenance manuals.

PART 2 - PRODUCTS

2.1 MATERIALS

- A. **Cleaning Agents:** Use cleaning materials and agents recommended by manufacturer or fabricator of the surface to be cleaned. Do not use cleaning agents that are potentially hazardous to health or property or that might damage finished surfaces.

PART 3 - EXECUTION

3.1 FINAL CLEANING

- A. **General:** Perform final cleaning. Conduct cleaning and waste-removal operations to comply with local laws and ordinances and Federal and local environmental and antipollution regulations.
- B. **Cleaning:** Employ experienced workers or professional cleaners for final cleaning. Clean each surface or unit to condition expected in an average commercial building cleaning and maintenance program. Comply with manufacturer's written instructions.
 1. Complete the following cleaning operations before requesting inspection for certification of Substantial Completion for entire Project or for a designated portion of Project:
 - a. Clean Project site of rubbish, waste material, litter, and other foreign substances.
 - b. Sweep paved areas broom clean. Remove petrochemical spills, stains, and other foreign deposits.
 - c. Rake grounds that are not planted, mulched, or paved to a smooth, even-textured surface.
 - d. Remove tools, construction equipment, machinery, and surplus material from Project site.
 - e. Remove snow and ice to provide safe access to building.
 - f. Clean exposed exterior and interior hard-surfaced finishes to a dirt-free condition, free of stains, films, and similar foreign substances. Avoid disturbing natural weathering of exterior surfaces. Restore

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- reflective surfaces to their original condition.
 - g. Remove debris and surface dust from limited-access spaces, including roofs, plenums, shafts, trenches, equipment vaults, manholes, attics, and similar spaces.
 - h. Clean flooring, removing debris, dirt, and staining; clean in accordance with manufacturer's instructions.
 - i. Vacuum and mop concrete.
 - j. Vacuum carpet and similar soft surfaces, removing debris and excess nap; clean in accordance with manufacturer's instructions if visible soil or stains remain.
 - k. Clean transparent materials, including mirrors and glass in doors and windows. Remove glazing compounds and other noticeable, vision-obscuring materials. Polish mirrors and glass, taking care not to scratch surfaces.
 - l. Remove labels that are not permanent.
 - m. Clean plumbing fixtures to a sanitary condition, free of stains, including stains resulting from water exposure.
 - n. Replace disposable air filters and clean permanent air filters. Clean exposed surfaces of diffusers, registers, and grills.
 - o. Clean ducts, blowers, and coils.
 - p. Clean luminaires, lamps, globes, and reflectors to function with full efficiency.
 - q. Leave Project clean and ready for occupancy.
- C. Construction Waste Disposal: Comply with waste-disposal requirements in Section 017419 "Construction Waste Management and Disposal."

3.2 CORRECTION OF THE WORK

- A. Complete repair and restoration operations required by "Correction of the Work" Article in Section 017300 "Execution" before requesting inspection for determination of Substantial Completion.

END OF SECTION 01 77 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 78 23 - OPERATION AND MAINTENANCE DATA

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes: Administrative and procedural requirements for preparing operation and maintenance manuals, including the following:
 - 1. Operation and maintenance documentation directory manuals.
 - 2. Emergency manuals.
 - 3. Systems and equipment operation manuals.
 - 4. Systems and equipment maintenance manuals.
 - 5. Product maintenance manuals.
- B. Related Requirements:
 - 1. Section 013300 "Submittal Procedures" for submitting copies of submittals for operation and maintenance manuals.

1.2 DEFINITIONS

- A. System: An organized collection of parts, equipment, or subsystems united by regular interaction.
- B. Subsystem: A portion of a system with characteristics similar to a system.

1.3 CLOSEOUT SUBMITTALS

- A. Submit operation and maintenance manuals indicated. Provide content for each manual as specified in individual Specification Sections, and as reviewed and approved at the time of Section submittals. Submit reviewed manual content formatted and organized as required by this Section.
 - 1. Where applicable, clarify and update reviewed manual content to correspond to revisions and field conditions.
- B. Format: Submit operation and maintenance manuals in the following format:
 - 1. Submit 2 paper copies. Architect will return two copies.
- C. Final Manual Submittal: Submit each manual in final form prior to requesting inspection for Substantial Completion and at least 7 days before commencing demonstration and training. Architect will return copy with comments.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1. Correct or revise each manual to comply with Architect's comments. Submit copies of each corrected manual within **15** days of receipt of Architect's comments and prior to commencing demonstration and training.
- D. Comply with Section 017700 "Closeout Procedures" for schedule for submitting operation and maintenance documentation.

1.4 FORMAT OF OPERATION AND MAINTENANCE MANUALS

- A. Manuals, Electronic Files: Submit manuals in the form of a multiple file composite electronic PDF file for each manual type required.
 1. Electronic Files: Use electronic files prepared by manufacturer where available. Where scanning of paper documents is required, configure scanned file for minimum readable file size.
 2. File Names and Bookmarks: Bookmark individual documents based on file names. Name document files to correspond to system, subsystem, and equipment names used in manual directory and table of contents. Group documents for each system and subsystem into individual composite bookmarked files, then create composite manual, so that resulting bookmarks reflect the system, subsystem, and equipment names in a readily navigated file tree. Configure electronic manual to display bookmark panel on opening file.
- B. Manuals, Paper Copy: Submit manuals in the form of hard-copy, bound and labeled volumes.
 1. Binders: Heavy-duty, three-ring, vinyl-covered, binders, in thickness necessary to accommodate contents, sized to hold 8-1/2-by-11-inch paper; with clear plastic sleeve on spine to hold label describing contents and with pockets inside covers to hold folded oversize sheets.
 - a. If two or more binders are necessary to accommodate data of a system, organize data in each binder into groupings by subsystem and related components. Cross-reference other binders if necessary to provide essential information for proper operation or maintenance of equipment or system.
 - b. Identify each binder on front and spine, with printed title "OPERATION AND MAINTENANCE MANUAL," Project title or name, subject matter of contents. Indicate volume number for multiple-volume sets.
 2. Dividers: Heavy-paper dividers with plastic-covered tabs for each section of the manual. Mark each tab to indicate contents. Include typed list of products and major components of equipment included in the section on each divider, cross-referenced to Specification Section number and title of Project Manual.
 3. Protective Plastic Sleeves: Transparent plastic sleeves designed to enclose diagnostic software storage media for computerized electronic

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- equipment. Enclose title pages and directories in clear plastic sleeves.
4. Supplementary Text: Prepared on 8-1/2-by-11-inch white bond paper.
 5. Drawings: Attach reinforced, punched binder tabs on drawings and bind with text.
 - a. If oversize drawings are necessary, fold drawings to same size as text pages and use as foldouts.
 - b. If drawings are too large to be used as foldouts, fold and place drawings in labeled envelopes and bind envelopes in rear of manual. At appropriate locations in manual, insert typewritten pages indicating drawing titles, descriptions of contents, and drawing locations.

1.5 SYSTEMS AND EQUIPMENT OPERATION MANUALS

- A. Systems and Equipment Operation Manual: Assemble a complete set of data indicating operation of each system, subsystem, and piece of equipment not part of a system. Include information required for daily operation and management, operating standards, and routine and special operating procedures.
- B. Content: In addition to requirements in this Section, include operation data required in individual Specification Sections and the following information:
 1. System, subsystem, and equipment descriptions. Use designations for systems and equipment indicated on Contract Documents.
 2. Operating procedures.
 3. Wiring diagrams.
- C. Descriptions: Include the following:
 1. Product name and model number. Use designations for products indicated on Contract Documents.
 2. Manufacturer's name.
 3. Equipment identification with serial number of each component.
 4. Equipment function.
 5. Operating characteristics.
 6. Complete nomenclature and number of replacement parts.
- D. Operating Procedures: Include the following, as applicable:
 1. Startup procedures.
 2. Equipment or system break-in procedures.
 3. Routine and normal operating instructions.
 4. Regulation and control procedures.
 5. Instructions on stopping.
 6. Normal shutdown instructions.
 7. Seasonal and weekend operating instructions.
 8. Required sequences for electric or electronic systems.
 9. Special operating instructions and procedures.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- E. Systems and Equipment Controls: Describe the sequence of operation, and diagram controls as installed.

1.6 SYSTEMS AND EQUIPMENT MAINTENANCE MANUALS

- A. Systems and Equipment Maintenance Manuals: Assemble a complete set of data indicating maintenance of each system, subsystem, and piece of equipment not part of a system. Include manufacturers' maintenance documentation, preventive maintenance procedures and frequency, repair procedures, wiring and systems diagrams, lists of spare parts, and warranty information.
- B. Content: For each system, subsystem, and piece of equipment not part of a system, include source information, manufacturers' maintenance documentation, maintenance procedures, maintenance and service schedules, spare parts list and source information, maintenance service contracts, and warranties and bonds as described below.
- C. Source Information: List each system, subsystem, and piece of equipment included in manual, identified by product name and arranged to match manual's table of contents. For each product, list name, address, and telephone number of Installer or supplier and maintenance service agent, and cross-reference Specification Section number and title in Project Manual and drawing or schedule designation or identifier where applicable.
- D. Manufacturers' Maintenance Documentation: Include the following information for each component part or piece of equipment:
 - 1. Standard maintenance instructions and bulletins; include only sheets pertinent to product or component installed. Mark each sheet to identify each product or component incorporated into the Work. If data include more than one item in a tabular format, identify each item using appropriate references from the Contract Documents. Identify data applicable to the Work and delete references to information not applicable.
 - 2. Drawings, diagrams, and instructions required for maintenance, including disassembly and component removal, replacement, and assembly.
 - 3. Identification and nomenclature of parts and components.
 - 4. List of items recommended to be stocked as spare parts.
- E. Maintenance Procedures: Include the following information and items that detail essential maintenance procedures:
 - 1. Test and inspection instructions.
 - 2. Troubleshooting guide.
 - 3. Precautions against improper maintenance.
 - 4. Disassembly; component removal, repair, and replacement; and reassembly instructions.
 - 5. Aligning, adjusting, and checking instructions.
- F. Maintenance and Service Schedules: Include service and lubrication

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

requirements, list of required lubricants for equipment, and separate schedules for preventive and routine maintenance and service with standard time allotment.

- G. Spare Parts List and Source Information: Include lists of replacement and repair parts, with parts identified and cross-referenced to manufacturers' maintenance documentation and local sources of maintenance materials and related services.
- H. Warranties and Bonds: Include copies of warranties and bonds and lists of circumstances and conditions that would affect validity of warranties or bonds.
 - 1. Include procedures to follow and required notifications for warranty claims.
- I. Drawings: Prepare drawings supplementing manufacturers' printed data to illustrate the relationship of component parts of equipment and systems and to illustrate control sequence and flow diagrams. Coordinate these drawings with information contained in record Drawings to ensure correct illustration of completed installation.
 - 1. Do not use original project record documents as part of maintenance manuals.

1.7 PRODUCT MAINTENANCE MANUALS

- A. Product Maintenance Manual: Assemble a complete set of maintenance data indicating care and maintenance of each product, material, and finish incorporated into the Work.
- B. Content: Organize manual into a separate section for each product, material, and finish. Include source information, product information, maintenance procedures, repair materials and sources, and warranties and bonds, as described below.
- C. Source Information: List each product included in manual, identified by product name and arranged to match manual's table of contents. For each product, list name, address, and telephone number of Installer or supplier and maintenance service agent, and cross-reference Specification Section number and title in Project Manual and drawing or schedule designation or identifier where applicable.
- D. Product Information: Include the following, as applicable:
 - 1. Product name and model number.
 - 2. Manufacturer's name.
 - 3. Color, pattern, and texture.
 - 4. Reordering information for specially manufactured products.
- E. Maintenance Procedures: Include manufacturer's written recommendations and the following:

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1. Inspection procedures.
 2. Types of cleaning agents to be used and methods of cleaning.
 3. List of cleaning agents and methods of cleaning detrimental to product.
 4. Schedule for routine cleaning and maintenance.
 5. Repair instructions.
- F. Repair Materials and Sources: Include lists of materials and local sources of materials and related services.
- G. Warranties and Bonds: Include copies of warranties and bonds and lists of circumstances and conditions that would affect validity of warranties or bonds.
1. Include procedures to follow and required notifications for warranty claims.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 78 23

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 01 78 39 - PROJECT RECORD DOCUMENTS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section includes administrative and procedural requirements for Project Record Documents, including the following:
 - 1. Record Drawings.
 - 2. Record specifications.
 - 3. Record Product Data.

- B. Related Requirements:
 - 1. Section 017300 "Execution" for final property survey.
 - 2. Section 017700 "Closeout Procedures" for general closeout procedures.
 - 3. Section 017823 "Operation and Maintenance Data" for operation and maintenance manual requirements.

1.2 CLOSEOUT SUBMITTALS

- A. Record Drawings: Comply with the following:
 - 1. Number of Copies: Submit one set(s) of marked-up record prints.
 - 2. Number of Copies: Submit copies of Record Drawings as follows:
 - a. Final Submittal:
 - 1) Submit PDF electronic files of scanned Record Prints and 1 set(s) of file prints.
 - 2) Print each drawing, whether or not changes and additional information were recorded.

- B. Record Specifications: Submit annotated PDF electronic files of Project's Specifications, including addenda and Contract modifications.

- C. Record Product Data: Submit annotated PDF electronic files and directories of each submittal.

1.3 RECORD DRAWINGS

- A. Record Prints: Maintain one set of marked-up paper copies of the Contract Drawings and Shop Drawings, incorporating new and revised drawings as modifications are issued.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1. Preparation: Mark record prints to show the actual installation, where installation varies from that shown originally. Require individual or entity who obtained record data, whether individual or entity is Installer, subcontractor, or similar entity, to provide information for preparation of corresponding marked-up record prints.
 - a. Give particular attention to information on concealed elements that would be difficult to identify or measure and record later.
 - b. Accurately record information in an acceptable drawing technique.
 - c. Record data as soon as possible after obtaining it.
 - d. Record and check the markup before enclosing concealed installations.
 - e. Cross-reference record prints to corresponding photographic documentation.

 2. Content: Types of items requiring marking include, but are not limited to, the following:
 - a. Dimensional changes to Drawings.
 - b. Revisions to details shown on Drawings.
 - c. Revisions to routing of piping and conduits.
 - d. Revisions to electrical circuitry.
 - e. Actual equipment locations.
 - f. Duct size and routing.
 - g. Locations of concealed internal utilities.
 - h. Changes made by Change Order or Change Directive.
 - i. Changes made following Owner's written orders.
 - j. Details not on the original Contract Drawings.
 - k. Field records for variable and concealed conditions.
 - l. Record information on the Work that is shown only schematically.

 3. Mark the Contract Drawings and Shop Drawings completely and accurately. Use personnel proficient at recording graphic information in production of marked-up record prints.
 4. Mark record prints with erasable, red-colored pencil. Use other colors to distinguish between changes for different categories of the Work at same location.
 5. Mark important additional information that was either shown schematically or omitted from original Drawings.
 6. Note Construction Change Directive numbers, alternate numbers, Change Order numbers, and similar identification, where applicable.
- B. Record Digital Data Files: Immediately before inspection for Certificate of Substantial Completion, review marked-up record prints with Owner. When authorized, prepare a full set of corrected digital data files of the Contract Drawings, as follows:
1. Format: Annotated PDF electronic file.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- C. Format: Identify and date each Record Drawing; include the designation "PROJECT RECORD DRAWING" in a prominent location.
 - 1. Format: Annotated PDF electronic file.
 - 2. Identification: As follows:
 - a. Project name.
 - b. Date.
 - c. Designation "PROJECT RECORD DRAWINGS."
 - d. Name of Contractor.

1.4 RECORD SPECIFICATIONS

- A. Preparation: Mark Specifications to indicate the actual product installation, where installation varies from that indicated in Specifications, addenda, and Contract modifications.
 - 1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.
 - 2. Record the name of manufacturer, supplier, Installer, and other information necessary to provide a record of selections made.
 - 3. Note related Change Orders and Record Drawings where applicable.
- B. Format: Submit record specifications as annotated PDF electronic file.

1.5 MAINTENANCE OF RECORD DOCUMENTS

- A. Maintenance of Record Documents: Store Record Documents in the field office apart from the Contract Documents used for construction. Do not use Project Record Documents for construction purposes. Maintain Record Documents in good order and in a clean, dry, legible condition, protected from deterioration and loss. Provide access to Project Record Documents for Owner's reference during normal working hours.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 78 39

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 05 40 00 - COLD-FORMED METAL FRAMING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Cold-formed steel framing.
 - 2. Vertical deflection clips, interior.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.
 - 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes.
- B. Shop Drawings:
 - 1. Include layout, spacings, sizes, thicknesses, and types of cold-formed steel framing; fabrication; and fastening and anchorage details, including mechanical fasteners.
 - 2. Indicate reinforcing channels, opening framing, supplemental framing, strapping, bracing, bridging, splices, accessories, connection details, and attachment to adjoining work.

1.3 QUALITY ASSURANCE

- A. Testing Agency Qualifications: Accredited by International Accreditation Service (IAS) to IAS AC98 criteria for testing indicated.
- B. Product Tests: Mill certificates or data from a qualified independent testing agency, or in-house testing with calibrated test equipment, indicating steel sheet complies with requirements, including base-steel thickness, yield strength, tensile strength, total elongation, chemical requirements, and metallic-coating thickness.
- C. Code-Compliance Certification of Studs and Track: Provide documentation that framing members are certified in accordance with the product-certification program of the Steel Framing Industry Association.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Protect and store cold-formed steel framing from corrosion, moisture staining, deformation, and other damage during delivery, storage, and handling as required in AISI S202.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Structural Performance: Provide cold-formed steel framing capable of withstanding design loads within limits and under conditions indicated.
 - 1. Deflection Limits: Design framing systems to withstand without deflections greater than the following:
 - a. Interior Non-Load-Bearing Framing: Horizontal deflection of 1/360 of the wall height under a horizontal load of 5 lbf/sq. ft..
 - b. Ceiling Joist Framing: Vertical deflection of 1/120 of the span for live loads and 1/240 for total loads of the span.
 - 2. Design framing system to maintain clearances at openings, to allow for construction tolerances, and to accommodate live load deflection of primary building structure as follows:
 - a. Upward and downward movement of 1/2 inch.
- B. Cold-Formed Steel Framing Standards: Unless more stringent requirements are indicated, framing complies with AISI S100 and ASTM C955.
- C. Sound-Rated Assemblies: For STC-rated assemblies, provide materials and construction identical to those tested in assembly indicated, in accordance with ASTM E90 and classified according to ASTM E413 by an independent testing agency.

2.2 INTERIOR NON-LOAD-BEARING WALL FRAMING

- A. Steel Studs: Manufacturer's standard C-shaped steel studs, of web depths indicated, punched, with stiffened flanges, and as follows:
 - 1. Minimum Base-Steel Thickness: 0.0428 inch.
 - 2. Flange Width: 1-5/8 inches.
- B. Steel Track: Manufacturer's standard U-shaped steel track, of web depths indicated, unpunched, with unstiffened flanges, and as follows:
 - 1. Minimum Base-Steel Thickness: Matching steel studs.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

2. Flange Width: 1-1/2 inches.
- C. Single Deflection Track: Manufacturer's single, deep-leg, U-shaped steel track; unpunched, with unstiffened flanges, of web depth to contain studs while allowing free vertical movement, with flanges designed to support horizontal loads and transfer them to the primary structure, and as follows:
1. Minimum Base-Steel Thickness: 0.0428 inch.
 2. Flange Width: 1 inch plus the design gap for one-story structures.
- D. Drift Clips: Manufacturer's standard bypass or head clips, capable of isolating wall stud from upward and downward vertical displacement and lateral drift of primary structure through positive mechanical attachment to stud web and structure.

2.3 FRAMING ACCESSORIES

- A. Fabricate steel-framing accessories from ASTM A1003/A1003M, Structural Grade, Type H, metallic-coated steel sheet, of same grade and coating designation used for framing members.
- B. Provide accessories of manufacturer's standard thickness and configuration, unless otherwise indicated, as follows:
1. Bracing, bridging, and solid blocking.
 2. Web stiffeners.
 3. Anchor clips.
 4. End clips.
 5. Stud kickers and knee braces.
 6. Hole-reinforcing plates.
 7. Backer plates.

2.4 ANCHORS, CLIPS, AND FASTENERS

- A. Steel Shapes and Clips: ASTM A36/A36M, zinc coated by hot-dip process in accordance with ASTM A123/A123M.
- B. Anchor Bolts: ASTM F1554, Grade 36, threaded carbon-steel hex-headed bolts carbon-steel nuts, and flat, hardened-steel washers; zinc coated by hot-dip process in accordance with ASTM A153/A153M, Class C.
- C. Post-Installed Anchors: Fastener systems with bolts of same basic metal as fastened metal, if visible, unless otherwise indicated; with working capacity greater than or equal to the design load, in accordance with an evaluation report acceptable to authorities having jurisdiction, based on ICC-ES AC01 as appropriate for the substrate.
1. Uses: Securing cold-formed steel framing to structure.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

2. Material for Interior Locations: Carbon-steel components zinc plated to comply with ASTM B633 or ASTM F1941/ASTM F1941M, Class Fe/Zn 5, unless otherwise indicated.
- D. Power-Actuated Anchors: Fastener systems with working capacity greater than or equal to the design load, in accordance with an evaluation report acceptable to authorities having jurisdiction, based on ICC-ES AC70.
- E. Mechanical Fasteners: ASTM C1513, corrosion-resistant-coated, self-drilling, self-tapping, steel drill screws.
 1. Head Type: Low-profile head beneath sheathing; manufacturer's standard elsewhere.

2.5 MISCELLANEOUS MATERIALS

- A. Galvanizing Repair Paint: ASTM A780/A780M.

2.6 FABRICATION

- A. Fabricate cold-formed steel framing and accessories plumb, square, and true to line, and with connections securely fastened, in accordance with AISI S240 and standards, manufacturer's written instructions, and requirements in this Section.
 1. Fabricate framing assemblies using jigs or templates.
 2. Cut framing members by sawing or shearing; do not torch cut.
 3. Fasten cold-formed steel framing members by welding, screw fastening, clinch fastening, pneumatic pin fastening, or riveting as standard with fabricator. Wire tying of framing members is not permitted.
- B. Reinforce, stiffen, and brace framing assemblies to withstand handling, delivery, and erection stresses. Lift fabricated assemblies by means that prevent damage or permanent distortion.
- C. Tolerances: Fabricate assemblies level, plumb, and true to line to a maximum allowable variation of 1/8 inch in 10 ft. and as follows:
 1. Spacing: Space individual framing members no more than plus or minus 1/8 inch from plan location. Cumulative errors are not to exceed minimum fastening requirements of sheathing or other finishing materials.
 2. Squareness: Fabricate each cold-formed steel framing assembly to a maximum out-of-square tolerance of 1/8 inch.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, conditions, and abutting structural framing for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Install sill sealer gasket at the underside of wall bottom track or rim track and at the top of foundation wall or slab at stud or joist locations.

3.3 INSTALLATION OF INTERIOR NON-LOAD-BEARING WALL FRAMING

- A. Install continuous track sized to match studs. Align track accurately and securely anchor to supporting structure.
- B. Fasten both flanges of studs to top and bottom track unless otherwise indicated. Space studs as follows:
 - 1. Stud Spacing: 16 inches.
- C. Set studs plumb, except as needed for diagonal bracing or required for nonplumb walls or warped surfaces and similar requirements.
- D. Isolate non-load-bearing steel framing from building structure to prevent transfer of vertical loads while providing lateral support.
- E. Install horizontal bridging in wall studs, spaced vertically in rows indicated but not more than 48 inches apart. Fasten at each stud intersection.
 - 1. Channel Bridging: Cold-rolled steel channel, welded or mechanically fastened to webs of punched studs.

3.4 INSTALLATION TOLERANCES

- A. Install cold-formed steel framing level, plumb, and true to line to a maximum allowable tolerance variation of 1/8 inch in 10 ft. and as follows:
 - 1. Space individual framing members no more than plus or minus 1/8 inch from plan location. Cumulative error are not to exceed minimum fastening requirements of sheathing or other finishing materials.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3.5 REPAIR

- A. Galvanizing Repairs: Prepare and repair damaged galvanized coatings on fabricated and installed cold-formed steel framing with galvanized repair paint in accordance with ASTM A780/A780M and manufacturer's written instructions.

3.6 PROTECTION

- A. Provide final protection and maintain conditions, in a manner acceptable to manufacturer and Installer, that ensure that cold-formed steel framing is without damage or deterioration at time of Substantial Completion.

END OF SECTION 05 40 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 06 10 00 - ROUGH CARPENTRY

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. Wood products.
 2. Miscellaneous lumber.
 3. Plywood backing panels.

1.2 DEFINITIONS

- A. Boards or Strips: Lumber of less than 2 inches nominal size in least dimension.
- B. Dimension Lumber: Lumber of 2 inches nominal size or greater but less than 5 inches nominal size in least dimension.

1.3 DELIVERY, STORAGE, AND HANDLING

- A. Stack wood products flat with spacers beneath and between each bundle to provide air circulation. Protect wood products from weather by covering with waterproof sheeting, securely anchored. Provide for air circulation around stacks and under coverings.

PART 2 - PRODUCTS

2.1 WOOD PRODUCTS

- A. Lumber: Comply with DOC PS 20 and applicable rules of grading agencies indicated. If no grading agency is indicated, comply with the applicable rules of any rules-writing agency certified by the ALSC Board of Review. Grade lumber by an agency certified by the ALSC Board of Review to inspect and grade lumber under the rules indicated.
1. Where nominal sizes are indicated, provide actual sizes required by DOC PS 20 for moisture content specified. Where actual sizes are indicated, they are minimum dressed sizes for dry wood products.
 2. Dress lumber, S4S, unless otherwise indicated.
- B. Maximum Moisture Content:

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1. Boards: 15 percent.
2. Dimension Lumber: 15 percent for 2-inch nominal thickness or less; 19 percent for more than 2-inch nominal thickness unless otherwise indicated.

2.2 FIRE-RETARDANT-TREATED LUMBER

- A. General: Where fire-retardant-treated materials are indicated, materials are to comply with requirements in this article, that are acceptable to authorities having jurisdiction, and with fire-test-response characteristics specified as determined by testing identical products per test method indicated by a qualified testing agency.
- B. Fire-Retardant-Treated Lumber and Plywood by Pressure Process: Products with a flame-spread index of 25 or less when tested in accordance with ASTM E84, and with no evidence of significant progressive combustion when the test is extended an additional 20 minutes, and with the flame front not extending more than 10.5 ft. beyond the centerline of the burners at any time during the test.
 1. Treatment is not to promote corrosion of metal fasteners.
 2. Interior Type A: Treated materials are to have a moisture content of 28 percent or less when tested in accordance with ASTM D3201/D3201M at 92 percent relative humidity. Use where exterior type is not indicated.
 3. Design Value Adjustment Factors: Treated lumber is to be tested in accordance with ASTM D5664 and design value adjustment factors are to be calculated in accordance with ASTM D6841.
- C. Kiln-dry lumber after treatment to maximum moisture content of 19 percent. Kiln-dry plywood after treatment to maximum moisture content of 15 percent.
- D. Identify fire-retardant-treated wood with appropriate classification marking of qualified testing agency and other information required by authorities having jurisdiction.

2.3 MISCELLANEOUS LUMBER

- A. Provide miscellaneous lumber indicated and lumber for support or attachment of other construction, including the following:
 1. Blocking.
 2. Nailers.
 3. Furring.
- B. Dimension Lumber Items:
 1. Grade: Construction or No. 2.
 2. Species: The following species:
 - a. Mixed southern pine or southern pine; SPIB.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- C. Concealed Boards:
 - 1. Lumber Moisture Content: 15 percent maximum.
 - 2. Species and Grade: The following:
 - a. Mixed southern pine or southern pine; No. 2 grade; SPIB.
 - b. Spruce-pine-fir (south) or spruce-pine-fir; Construction or No. 2 Common grade; NeLMA, NLGA, WCLIB, or WWPA.
- D. Wood Blocking: For blocking not used for attachment of other construction, Utility, Stud, or No. 3 grade lumber of any species may be used provided that it is cut and selected to eliminate defects that will interfere with its attachment and purpose.

2.4 FASTENERS

- A. General: Fasteners are to be of size and type indicated and comply with requirements specified in this article for material and manufacture. Provide screws, in sufficient length, to penetrate into substrate.
 - 1. Where rough carpentry is exposed to weather, in ground contact, pressure-preservative treated, or in area of high relative humidity, provide fasteners with hot-dip zinc coating complying with ASTM A153/A153M or ASTM F2329.
- B. Nails, Brads, Screws and Staples: ASTM F1667.
- C. Power-Driven Fasteners: Fastener systems with an evaluation report acceptable to authorities having jurisdiction, based on ICC-ES AC70.

2.5 ACCESSORIES

- A. Adhesives for Gluing Furring and Sleepers to Concrete or Masonry: Formulation complying with ASTM D3498 that is approved for use indicated by adhesive manufacturer.

PART 3 - EXECUTION

3.1 INSTALLATION OF ROUGH CARPENTRY, GENERAL

- A. Set work to required levels and lines, with members plumb, true to line, cut, and fitted. Fit rough carpentry accurately to other construction. Locate furring, nailers, blocking, and similar supports to comply with requirements for attaching other construction.
- B. Provide blocking and framing as indicated and as required to support facing

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

materials, fixtures, specialty items, and trim.

1. Provide metal clips for fastening gypsum board or lath at corners and intersections where framing or blocking does not provide a surface for fastening edges of panels. Space clips not more than 16 inches o.c.
- C. Provide fire blocking in furred spaces, stud spaces, and other concealed cavities as indicated and as follows:
1. Fire block furred spaces of walls, at each floor level, at ceiling, and at not more than 96 inches o.c. with solid wood blocking or noncombustible materials accurately fitted to close furred spaces.
 2. Fire block concealed spaces of wood-framed walls and partitions at each floor level, at ceiling line of top story, and at not more than 96 inches o.c. Where fire blocking is not inherent in framing system used, provide closely fitted solid wood blocks of same width as framing members and 2-inch nominal thickness.
- D. Sort and select lumber so that natural characteristics do not interfere with installation or with fastening other materials to lumber. Do not use materials with defects that interfere with function of member or pieces that are too small to use with minimum number of joints or optimum joint arrangement.
- E. Securely attach rough carpentry work to substrate by anchoring and fastening as indicated, complying with the following:
1. Table 2304.10.1, "Fastening Schedule," in ICC's "International Building Code" (IBC).
- F. Select fasteners of size that will not fully penetrate members where opposite side will be exposed to view or will receive finish materials. Make tight connections between members. Install fasteners without splitting wood. Drive nails and screws snug but do not countersink nail heads unless otherwise indicated.

3.2 INSTALLATION OF WOOD BLOCKING

- A. Install wood blocking where indicated on Drawings and where required for attaching other work. Form to shapes indicated and cut as required for true line and level of attached work. Coordinate locations with other work involved.

3.3 INSTALLATION OF WALL AND PARTITION FRAMING

- A. General: Provide single bottom plate and double top plates using members of 2-inch nominal thickness whose widths equal that of studs, except single top plate may be used for non-load-bearing partitions. Fasten plates to supporting construction unless otherwise indicated.
1. For interior partitions and walls, provide 2-by-4-inch nominal- size metal

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- studs.
2. Provide continuous horizontal blocking at midheight of partitions more than 96 inches high, using members of 2-inch nominal thickness and of same width as wall or partitions.
- B. Construct corners and intersections with three or more studs.
- C. Frame openings with multiple studs and headers. Provide nailed header members of thickness equal to width of studs. Support headers on jamb studs.
1. For non-load-bearing partitions, provide double-jamb studs and headers not less than 4-inch nominal depth for openings 48 inches and less in width, 6-inch nominal depth for openings 48 to 72 inches in width, 8-inch nominal depth for openings 72 to 120 inches in width, and not less than 10-inch nominal depth for openings 10 to 12 ft. in width.

END OF SECTION 06 10 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 06 41 16 - PLASTIC-LAMINATE-CLAD ARCHITECTURAL CABINETS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Plastic-laminate-clad architectural cabinets.
2. Cabinet hardware and accessories.
3. Miscellaneous materials.

B. Related Requirements:

1. Section 061000 "Rough Carpentry" for wood furring, blocking, shims, and hanging strips required for installing cabinets that are concealed within other construction before cabinet installation.

1.2 COORDINATION

- A. Coordinate sizes and locations of framing, blocking, furring, reinforcements, and other related units of Work specified in other Sections to support loads imposed by installed and fully loaded cabinets.

1.3 ACTION SUBMITTALS

A. Product Data:

1. Plastic-laminate-clad architectural cabinets.
2. Cabinet hardware and accessories.
3. Miscellaneous materials.

B. Product Data Submittals: For each product.

C. Shop Drawings:

1. Include plans, elevations, sections, and attachment details.
2. Show large-scale details.
3. Show locations and sizes of furring, blocking, and hanging strips, including concealed blocking and reinforcement specified in other Sections.
4. Show locations and sizes of cutouts and holes for items installed in plastic-laminate architectural cabinets.

D. Samples: For each exposed product and for each color and texture specified, in manufacturer's or manufacturer's standard size.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- E. Samples for Initial Selection: For each type of exposed finish.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Do not deliver cabinets until painting and similar finish operations that might damage architectural cabinets have been completed in installation areas. Store cabinets in installation areas or in areas where environmental conditions comply with requirements specified in "Field Conditions" Article.

1.5 FIELD CONDITIONS

- A. Environmental Limitations without Humidity Control: Do not deliver or install cabinets until building is enclosed, wet-work is complete, and HVAC system is operating and maintaining temperature and relative humidity at levels planned for building occupants during the remainder of the construction period.
- B. Field Measurements: Where cabinets are indicated to fit to other construction, verify dimensions of other construction by field measurements before fabrication, and indicate measurements on Shop Drawings. Coordinate fabrication schedule with construction progress to avoid delaying the Work.
 - 1. Locate concealed framing, blocking, and reinforcements that support cabinets by field measurements before being enclosed/concealed by construction, and indicate measurements on Shop Drawings.
- C. Established Dimensions: Where cabinets are indicated to fit to other construction, establish dimensions for areas where cabinets are to fit. Provide allowance for trimming at site, and coordinate construction to ensure that actual dimensions correspond to established dimensions.

PART 2 - PRODUCTS

2.1 PLASTIC-LAMINATE-CLAD ARCHITECTURAL CABINETS

- A. Quality Standard: Unless otherwise indicated, comply with the Architectural Woodwork Standards for grades of cabinets indicated for construction, finishes, installation, and other requirements.
- B. Architectural Woodwork Standards Grade: Custom.
- C. Type of Construction: Frameless.
- D. Door and Drawer-Front Style: Flush overlay.
 - 1. Reveal Dimension: 1/2 inch.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- E. High-Pressure Decorative Laminate: ISO 4586-3, grades as indicated or if not indicated, as required by quality standard.
1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Formica Corporation
 - b. Wilsonart LLC
 2. Basis-of-Design Product: Subject to compliance with requirements, provide or comparable product by one of the following:
 - a. Formica Corporation
 - b. Wilsonart LLC
- F. Exposed Surfaces:
1. Plastic-Laminate Grade: VGS.
 2. Edges: PVC edge banding, 3.0 mm thick, matching laminate in color, pattern, and finish.
 3. Pattern Direction: Vertically for drawer fronts, doors, and fixed panels.
- G. Semi-exposed Surfaces:
1. Surfaces Other Than Drawer Bodies: Thermally fused laminate panels.
 - a. Edges of Plastic-Laminate Shelves: PVC edge banding, 3.0 mm thick, matching laminate in color, pattern, and finish.
 - b. Edges of Thermally Fused Laminate Panel Shelves: PVC or polyester edge banding.
 - c. For semi-exposed backs of panels with exposed plastic-laminate surfaces, provide surface of high-pressure decorative laminate, ISO 4586-3, grade to match exposed surface.
 2. Drawer Sides and Backs: Solid-hardwood lumber.
 3. Drawer Bottoms: Hardwood plywood.
- H. Concealed Backs of Panels with Exposed Plastic-Laminate Surfaces: High-pressure decorative laminate, ISO 4583-3, grade to match exposed surface.
- I. Drawer Construction: Fabricate with exposed fronts fastened to subfront with mounting screws from interior of body.
1. Join subfronts, backs, and sides with glued rabbeted joints supplemented by mechanical fasteners.
- J. Colors, Patterns, and Finishes: Provide materials and products that result in colors and textures of exposed laminate surfaces complying with the following requirements:

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1. As selected by Architect from laminate manufacturer's full range in the following categories:
 - a. Solid colors, matte finish.
 - b. Solid colors with core same color as surface, matte finish.
 - c. Wood grains, matte finish.
 - d. Patterns, matte finish.

2.2 WOOD MATERIALS

- A. Wood Products: Provide materials that comply with requirements of referenced quality standard for each type of architectural cabinet and quality grade specified unless otherwise indicated.
 1. Wood Moisture Content: 8 to 13 percent.
- B. Composite Wood Products: Provide materials that comply with requirements of referenced quality standard for each type of architectural cabinet and quality grade specified unless otherwise indicated.
 - a. Hardwood Plywood: 0.05 ppm.
 - b. Particleboard: 0.09 ppm.
 - c. MDF More Than 5/16 Inch Thick: 0.11 ppm.
 - d. MDF 5/16 Inch or Less in Thickness: 0.13 ppm.
2. Medium-Density Fiberboard (MDF): ANSI A208.2, Grade 130.
3. Particleboard (Medium Density): ANSI A208.1, Grade M-2-Exterior Glue.
4. Softwood Plywood: DOC PS 1, medium-density overlay.

2.3 CABINET HARDWARE AND ACCESSORIES

1. Basis-of-Design Product: Subject to compliance with requirements, provide or comparable product by one of the following:
 - a. Accuride International Inc.
 - b. CompX International, Inc.
 - c. Grass America
 - d. Hardware Resources
 - e. Hettich America L.P.
 - f. Julius Blum & Co., Inc.
 - g. Knape & Vogt Manufacturing Company
- B. Butt Hinges: 2-3/4-inch, five-knuckle steel hinges made from 0.095-inch- thick metal, and as follows:
 1. Semi-concealed Hinges for Flush Doors: ANSI/BHMA A156.9, B01361.
 2. Semi-concealed Hinges for Overlay Doors: ANSI/BHMA A156.9, B01521.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- C. Back-Mounted Pulls: ANSI/BHMA A156.9, B02011.
- D. Wire Pulls: Back mounted, solid metal, 4 inches long, 5/16 inch in diameter.
- E. Catches: Magnetic catches, ANSI/BHMA A156.9, B03141.
- F. Adjustable Shelf Standards and Supports: ANSI/BHMA A156.9, B04102; with shelf brackets, B04112.
- G. Shelf Rests: ANSI/BHMA A156.9, B04013; metal.
- H. Drawer Slides: ANSI/BHMA A156.9.
 - 1. Heavy-Duty (Grade 1HD-100 and Grade 1HD-200): Side mount.
 - a. Type: Full extension.
 - b. Material: Galvanized steel ball bearing slides.
 - 2. Pencil drawers not more than 3 inches high and not more than 24 inches wide, provide 50 lb load capacity.
 - 3. General-purpose drawers more than 3 inches high, but not more than 6 inches high and not more than 24 inches wide, provide 75 lb load capacity.
 - 4. File drawers more than 6 inches high or more than 24 inches wide, provide 100 lb load capacity.
 - 5. Computer keyboard tray, provide 75 lb load capacity.
- I. Door Locks: ANSI/BHMA A156.11, E07121.
- J. Drawer Locks: ANSI/BHMA A156.11, E07041.
- K. Door and Drawer Silencers: ANSI/BHMA A156.16, L03011.
- L. Grommets for Cable Passage: 2-inch OD, molded-plastic grommets and matching plastic caps with slot for wire passage.
 - 1. Color: Black.
- M. Exposed Hardware Finishes: For exposed hardware, provide finish that complies with ANSI/BHMA A156.18 for ANSI/BHMA finish number indicated.
 - 1. Satin Chromium Plated: ANSI/BHMA 626 for brass or bronze base; ANSI/BHMA 652 for steel base.
- N. For concealed hardware, provide manufacturer's standard finish that complies with product class requirements in ANSI/BHMA A156.9.

2.4 MISCELLANEOUS MATERIALS

- A. Furring, Blocking, Shims, and Hanging Strips: Softwood or hardwood lumber,

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

kiln-dried to less than 15 percent moisture content.

- B. Anchors: Select material, type, size, and finish required for each substrate for secure anchorage. Provide metal expansion sleeves or expansion bolts for post-installed anchors. Use nonferrous-metal or hot-dip galvanized anchors and inserts at inside face of exterior walls and at floors.
- C. Adhesive for Bonding Plastic Laminate: Type I, waterproof type as selected by fabricator to comply with requirements.
 - 1. Adhesive for Bonding Edges: Hot-melt adhesive or adhesive specified above for faces.

2.5 FABRICATION

- A. Fabricate architectural cabinets to dimensions, profiles, and details indicated.
- B. Complete fabrication, including assembly and hardware application, to maximum extent possible before shipment to Project site. Disassemble components only as necessary for shipment and installation. Where necessary for fitting at site, provide ample allowance for scribing, trimming, and fitting.
- C. Shop-cut openings to maximum extent possible to receive hardware, appliances, electrical work, and similar items. Locate openings accurately and use templates or roughing-in diagrams to produce accurately sized and shaped openings. Sand edges of cutouts to remove splinters and burrs.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Before installation, condition cabinets to humidity conditions in installation areas for not less than 72 hours.

3.2 INSTALLATION

- A. Architectural Woodwork Standards Grade: Install cabinets to comply with quality standard grade of item to be installed.
- B. Assemble cabinets and complete fabrication at Project site to extent that it was not completed in the shop.
- C. Anchor cabinets to anchors or blocking built in or directly attached to substrates. Secure with wafer-head cabinet installation screws.
- D. Install cabinets level, plumb, and true in line to a tolerance of 1/8 inch in 96

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

inches using concealed shims.

1. Scribe and cut cabinets to fit adjoining work, refinish cut surfaces, and repair damaged finish at cuts.
2. Install cabinets without distortion so doors and drawers fit openings and are accurately aligned. Adjust hardware to center doors and drawers in openings and to provide unencumbered operation. Complete installation of hardware and accessory items as indicated.
3. Fasten wall cabinets through back, near top and bottom, and at ends not more than 16 inches o.c. with No. 10 wafer-head screws sized for not less than 1-1/2-inch penetration into wood framing, blocking, or hanging strips.

3.3 ADJUSTING AND CLEANING

- A. Repair damaged and defective cabinets, where possible, to eliminate functional and visual defects. Where not possible to repair, replace architectural cabinets. Adjust joinery for uniform appearance.
- B. Clean, lubricate, and adjust hardware.
- C. Clean cabinets on exposed and semi-exposed surfaces.

END OF SECTION 06 41 16

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 07 21 00 - THERMAL INSULATION

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Mineral-wool blanket insulation.
- B. Related Requirements:

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1.3 DELIVERY, STORAGE, AND HANDLING

- A. Protect insulation materials from physical damage and from deterioration due to moisture, soiling, and other sources. Store inside and in a dry location. Comply with manufacturer's written instructions for handling, storing, and protecting during installation.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Surface-Burning Characteristics: Maximum flame-spread and smoke-developed indexes less than Class A, 25 and 450 when tested in accordance with ASTM E84.
- B. Fire-Resistance Ratings: Comply with ASTM E119 or UL 263; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 - 1. Indicate design designations from UL's "Fire Resistance Directory" or from listings of another qualified testing agency.
- C. Fire Propagation Characteristics: Passes NFPA 285 testing as part of an approved assembly.
- D. Labeling: Provide identification of mark indicating R-value of each piece of insulation 12 inches and wider in width.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- E. Thermal-Resistance Value (R-Value): R-value as indicated on Drawings in accordance with ASTM C518.

2.2 MINERAL-WOOL BLANKET INSULATION

- A. Mineral-Wool Blanket Insulation, Unfaced: ASTM C665, Type I (blankets without membrane facing); consisting of fibers; complying with ASTM E136 for combustion characteristics.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by the following:
 - a. Johns Manville; a Berkshire Hathaway company
 - b. Owens Corning
 - c. ROCKWOOL

2.3 INSULATION FASTENERS

- A. Insulation Fastener Accessories: Provide double-pointed weld pins, lagging pins, quilting pins, duct liner pins, insulation hangers, specialty washers, special caps, j-hooks, capacitor discharge annular weld pins, capacitor discharge acoustical lagging pins, and other accessory materials that are recommended in writing by insulation fastener manufacturer to produce complete insulation supports.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Clean substrates of substances that are harmful to insulation, including removing projections capable of puncturing insulation or vapor retarders, or those that interfere with insulation attachment.

3.2 INSTALLATION, GENERAL

- A. Comply with insulation manufacturer's written instructions applicable to products, applications and applicable codes.
- B. Install insulation that is undamaged, dry, and unsoiled and that has not been left exposed to ice, rain, or snow at any time.
- C. Install insulation with manufacturer's R-value label exposed after insulation is installed.
- D. Extend insulation to envelop entire area to be insulated. Fit tightly around obstructions and fill voids with insulation. Remove projections that interfere with

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

placement.

- E. Provide sizes to fit applications and selected from manufacturer's standard thicknesses, widths, and lengths. Apply single layer of insulation units unless multiple layers are otherwise shown or required to make up total thickness or to achieve R-value.

3.3 INSTALLATION OF INSULATION IN FRAMED CONSTRUCTION

- A. Blanket Insulation: Install in cavities formed by framing members in accordance with the following requirements:
 - 1. Use insulation widths and lengths that fill the cavities formed by framing members. If more than one length is required to fill the cavities, provide lengths that will produce a snug fit between ends.
 - 2. Place insulation in cavities formed by framing members to produce a friction fit between edges of insulation and adjoining framing members.
 - 3. For metal-framed wall cavities where cavity heights exceed 96 inches, support unfaced blankets mechanically and support faced blankets by taping flanges of insulation to flanges of metal studs.
- B. Miscellaneous Voids: Install insulation in miscellaneous voids and cavity spaces where required to prevent gaps in insulation using the following materials:
 - 1. Glass-Fiber Insulation: Compact to approximately 40 percent of normal maximum volume equaling a density of approximately 2.5 lb/cu. ft..

3.4 PROTECTION

- A. Protect installed insulation from damage due to harmful weather exposures, physical abuse, and other causes.
- B. Provide temporary coverings or enclosures where insulation is subject to abuse and cannot be concealed and protected by permanent construction immediately after installation.

END OF SECTION 07 21 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 07 81 00 - APPLIED FIRE PROTECTION

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes: Sprayed fire-resistive materials.

1.2 DEFINITIONS

- A. SFRM: Sprayed fire-resistive materials.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: Framing plans or schedules, or both, indicating the following:
 - 1. Extent of applied fire protection for each construction and fire-resistance rating.
 - 2. Applicable fire-resistance design designations of a qualified testing and inspecting agency acceptable to authorities having jurisdiction.
 - 3. Minimum applied fire protection material thicknesses needed to achieve required fire-resistance rating of each structural component and assembly.
 - 4. Treatment of sprayed fire-resistive material after application.

1.4 QUALITY ASSURANCE

- A. Installer Qualifications: A firm or individual certified, licensed, or otherwise qualified by applied fire protection material manufacturer as experienced and with sufficient trained staff to install manufacturer's products in accordance with specified requirements.

1.5 FIELD CONDITIONS

- A. Environmental Limitations: Do not apply applied fire protection when ambient or substrate temperature is or lower unless temporary protection and heat are provided to maintain temperature at or above this level for 24 hours before, during, and for 24 hours after product application.
- B. Ventilation: Ventilate building spaces during and after application of fire protection, providing complete air exchanges in accordance with manufacturer's written instructions. Use natural means or, if they are inadequate, forced-air

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

circulation until fire protection dries thoroughly.

- C. Provide temporary enclosure to prevent spray from contaminating air in space where application is being made or in adjacent spaces.

PART 2 - PRODUCTS

2.1 SOURCE LIMITATIONS

- A. Obtain applied fire protection for each fire-resistance design from single source.

2.2 PERFORMANCE REQUIREMENTS

- A. Assemblies: Provide applied fire protection, including auxiliary materials, in accordance with requirements of each fire-resistance design and manufacturer's written instructions.
- B. Fire-Resistance Design: Indicated on Drawings, tested in accordance with ASTM E119 or UL 263; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 - 1. Steel members are to be considered unrestrained unless specifically noted otherwise.
- C. Asbestos: Provide products containing no detectable asbestos.

2.3 SPRAYED FIRE-RESISTIVE MATERIALS

- A. Sprayed Fire-Resistive Material: UL X829, UL X827, UL D902 Manufacturer's standard, factory-mixed, lightweight, dry formulation, complying with indicated fire-resistance design, and conveyed in a dry state and mixed with atomized water at place of application.
 - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. GCP Applied Technologies Inc.
 - b. Isolatek International
 - c. Southwest Fireproofing Products Co.
 - 2. Bond Strength: Minimum 150-lbf/sq. ft. cohesive and adhesive strength based on field testing in accordance with ASTM E736/E736M.
 - 3. Density: Not less than density specified in the approved fire-resistance design, in accordance with ASTM E605/E605M.
 - 4. Thickness: As required for fire-resistance design indicated, measured in

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

accordance with requirements of fire-resistance design or ASTM E605/E605M, whichever is thicker, but not less than 0.375 inch.

5. Combustion Characteristics: ASTM E136.
6. Surface-Burning Characteristics: Comply with ASTM E84; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 - a. Flame-Spread Index: 0 or less.
 - b. Smoke-Developed Index: 0 or less.
7. Compressive Strength: Minimum 31 lbf/sq in in accordance with ASTM E761/E761M.
8. Corrosion Resistance: No evidence of corrosion in accordance with ASTM E937/E937M.
9. Deflection: No cracking, spalling, or delamination in accordance with ASTM E759/E759.
10. Effect of Impact on Bonding: No cracking, spalling, or delamination in accordance with ASTM E760/E760M.
11. Air Erosion: Maximum weight loss of 0.025 g/sq. ft. in 24 hours in accordance with ASTM E859/E859M.
12. Fungal Resistance: Treat products with manufacturer's standard antimicrobial formulation to result in no growth on specimens per ASTM G21.

2.4 AUXILIARY MATERIALS

- A. Provide auxiliary materials that are compatible with sprayed fire-resistive material and substrates and are approved by UL or another testing and inspecting agency acceptable to authorities having jurisdiction for use in fire-resistance designs indicated.
- B. Substrate Primers: Primers approved in writing by sprayed fire-resistive material manufacturer and complying with one or both of the following requirements:
 1. Primer and substrate are identical to those tested in required fire-resistance design by UL or another testing and inspecting agency acceptable to authorities having jurisdiction.
 2. Primer's bond strength in required fire-resistance design complies with specified bond strength for sprayed fire-resistive material and with requirements in UL's "Product iQ" online directory or in the listings of another qualified testing agency acceptable to authorities having jurisdiction, based on a series of bond tests in accordance with ASTM E736/E736M.
- C. Bonding Agent: Product approved in writing by sprayed fire-resistive material manufacturer and complying with requirements in UL's "Product iQ" online directory or in the listings of another qualified testing agency acceptable to authorities having jurisdiction.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- D. Metal Lath: Expanded metal lath fabricated from material of weight, configuration, and finish required, in accordance with fire-resistance designs indicated and sprayed fire-resistive material manufacturer's written instructions. Include clips, lathing accessories, corner beads, and other anchorage devices required to attach lath to substrates and to receive sprayed fire-resistive material.
- E. Sealer: Transparent-drying, water-dispersible, tinted protective coating recommended in writing by sprayed fire-resistive material manufacturer for each fire-resistance design.
- F. Topcoat: Suitable for application over sprayed fire-resistive material; of type recommended in writing by sprayed fire-resistive material manufacturer for each fire-resistance design.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for substrates and other conditions affecting performance of the Work and in accordance with each fire-resistance design.
 - 1. Verify that substrates are free of dirt, oil, grease, release agents, rolling compounds, mill scale, loose scale, incompatible primers, paints, and encapsulants, or other foreign substances capable of impairing bond of applied fire protection with substrates under conditions of normal use or fire exposure.
 - 2. Verify that objects penetrating applied fire protection, including clips, hangers, support sleeves, and similar items, are securely attached to substrates.
 - 3. Verify that substrates receiving applied fire protection are not obstructed by ducts, piping, equipment, or other suspended construction that will interfere with fire protection application.

3.2 PREPARATION

- A. Cover other work subject to damage from fallout or overspray of applied fire protection materials during application.
- B. Clean substrates of substances that could impair bond of applied fire protection.
- C. Prime substrates where included in fire-resistance design and where recommended in writing by sprayed fire-resistive material manufacturer unless compatible shop primer has been applied and is in satisfactory condition to receive applied fire protection.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- D. For applications visible on completion of Project, repair substrates to remove surface imperfections that could affect uniformity of texture and thickness in finished surface of applied fire protection. Remove minor projections and fill voids that would telegraph through applied fire protection after application.

3.3 APPLICATION

- A. Construct applied fire protection assemblies that are identical to fire-resistance design indicated and products as specified, tested, and substantiated by test reports; for thickness, primers, sealers, topcoats, finishing, and other materials and procedures affecting applied fire protection Work.
- B. Comply with sprayed fire-resistive material manufacturer's written instructions for mixing materials, application procedures, and types of equipment used to mix, convey, and apply fire protection; as applicable to particular conditions of installation and as required to achieve fire-resistance ratings indicated.
- C. Coordinate application of fire protection with other construction to minimize need to cut or remove applied fire protection.
 - 1. Do not begin applying fire protection until clips, hangers, supports, sleeves, and other items penetrating fire protection are in place.
 - 2. Defer installing ducts, piping, and other items that would interfere with applying fire protection until application of fire protection is completed.
- D. Install auxiliary materials as required, as detailed, and in accordance with fire-resistance design and sprayed fire-resistive material manufacturer's written instructions for conditions of exposure and intended use. For auxiliary materials, use attachment and anchorage devices of type recommended in writing by sprayed fire-resistive material manufacturer.
- E. Spray apply fire protection to maximum extent possible. After the spraying operation in each area, complete the coverage by trowel application or other placement method recommended in writing by sprayed fire-resistive material manufacturer.
- F. Extend applied fire protection in full thickness over entire area of each substrate to be protected.
- G. Install body of applied fire protection in a single course unless otherwise recommended in writing by sprayed fire-resistive material manufacturer.
- H. Where sealers are used, apply products that are tinted to differentiate them from applied fire protection over which they are applied.
- I. Provide a uniform finish complying with description indicated for each type of applied fire protection material and matching finish approved for required mockups.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- J. Cure applied fire protection in accordance with sprayed fire-resistive material manufacturer's written instructions.
- K. Do not install enclosing or concealing construction until after applied fire protection has been inspected, tested, and corrections have been made to deficient applications.
- L. Finishes: Where indicated, apply fire protection to produce the following finishes:
 - 1. Manufacturer's Standard Finishes: Finish in accordance with manufacturer's written instructions for each finish selected.
 - 2. Spray-Textured Finish: Finish left as spray applied with no further treatment.
 - 3. Skip-Troweled Finish: Even leveled surface produced by troweling spray-applied finish to smooth out the texture and neaten edges.
 - 4. Skip-Troweled Finish with Corner Beads: Even, leveled surface produced by troweling spray-applied finish to smooth out the texture, eliminate surface markings, and square off edges.

3.4 FIELD QUALITY CONTROL

- A. Special Inspections: Engage a qualified special inspector to perform the following special inspections:
 - 1. Test and inspect as required by the IBC , Subsection 1705.15, "Sprayed Fire-Resistant Materials."
- B. Perform the tests and inspections of completed Work in successive stages. Do not proceed with application of fire protection for the next area until test results for previously completed applications of fire protection show compliance with requirements. Tested values must equal or exceed values as specified and as indicated and required for approved fire-resistance design.
- C. Applied fire protection will be considered defective if it does not pass tests and inspections.
 - 1. Remove and replace applied fire protection that does not pass tests and inspections, and retest.
 - 2. Apply additional applied fire protection, in accordance with manufacturer's written instructions, where test results indicate insufficient thickness, and retest.
- D. Prepare test and inspection reports.

3.5 CLEANING

- A. Immediately after completing spraying operations in each containable area of Project, remove material overspray and fallout from surfaces of other

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

construction and clean exposed surfaces to remove evidence of soiling.

3.6 PROTECTION

- A. Protect applied fire protection from damage resulting from construction operations or other causes in accordance with manufacturer's and Installer's written instructions, so applied fire protection is without damage or deterioration at time of Substantial Completion.

3.7 REPAIRS

- A. As installation of other adjacent construction proceeds, inspect applied fire protection and repair damaged areas due to work of other trades before concealing it with other construction.
- B. Repair applied fire protection using same method and materials as original installation or using manufacturer's recommended trowel-applied repair product.

END OF SECTION 07 81 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 08 12 13 - HOLLOW METAL FRAMES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. Interior standard steel frames.
 2. Borrowed lites.

1.2 DEFINITIONS

- A. Minimum Thickness: Minimum thickness of base metal without coatings according to NAAMM-HMMA 803 or SDI A250.8.

1.3 COORDINATION

- A. Coordinate anchorage installation for hollow-metal frames. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors. Deliver such items to Project site in time for installation.
- B. Coordinate requirements for installation of door hardware, electrified door hardware, and access control and security systems.

1.4 ACTION SUBMITTALS

- A. Product Data:
1. Interior standard steel frames.
 2. Borrowed lites.
- B. Product Data Submittals: For each product.
1. Include construction details, material descriptions, and finishes.
- C. Shop Drawings: Include the following:
1. Elevations of each frame type.
 2. Frame details for each frame type, including dimensioned profiles and metal thicknesses.
 3. Locations of reinforcement and preparations for hardware.
 4. Details of anchorages, joints, field splices, and connections.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- 5. Details of moldings, removable stops, and glazing.
- D. Samples for Initial Selection: For hollow-metal frames with factory-applied color finishes.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Deliver hollow-metal frames palletized, packaged, or crated to provide protection during transit and Project-site storage. Do not use non-vented plastic.
 - 1. Provide additional protection to prevent damage to factory-finished units.
- B. Deliver welded frames with two removable spreader bars across bottom of frames, tack welded to jambs and mullions.
- C. Store hollow-metal frames vertically under cover at Project site with head up. Place on minimum 4-inch- high wood blocking. Provide minimum 1/4-inch space between each stacked door to permit air circulation.

PART 2 - PRODUCTS

2.1 HOLLOW METAL FRAMES

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - 1. Apex Industries, Inc
 - 2. Ceco Door; AADG, Inc.; ASSA ABLOY
 - 3. Concept Frames, AADG, Inc.; ASSA ABLOY Group
 - 4. Curries, AADG, Inc.; ASSA ABLOY Group
 - 5. Custom Metal Products
 - 6. Daybar Industries, Ltd
 - 7. DCI Hollow Metal on Demand
 - 8. Gensteel Doors
 - 9. JR Metal Frames, Inc.
 - 10. National Custom Hollow Metal Doors & Frames
 - 11. North American Door Corp
 - 12. Republic Doors and Frames; an Allegion brand
 - 13. Steelcraft; Allegion plc

2.2 STANDARD STEEL FRAMES

- A. Construct hollow-metal frames to comply with standards indicated for materials, fabrication, hardware locations, hardware reinforcement, tolerances, and clearances, and as specified.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- B. Interior Standard Steel Frames: SDI A250.8. At locations indicated in the Door and Frame Schedule on Drawings.
 - 1. Materials: Metallic-coated steel sheet, minimum thickness of 0.053 inch.
 - 2. Sidelite and Transom Frames: Fabricated from same thickness material as adjacent door frame.
 - 3. Exposed Finish: Prime.

2.3 BORROWED LITES

- A. Fabricate of metallic-coated steel sheet, minimum thickness of 0.053 inch.
- B. Fabricate in one piece except where handling and shipping limitations require multiple sections. Where frames are fabricated in sections due to shipping or handling limitations, provide alignment plates or angles at each joint, fabricated of metal of same or greater thickness as metal as frames.
- C. Provide countersunk, flat- or oval-head exposed screws and bolts for exposed fasteners unless otherwise indicated.

2.4 FRAME ANCHORS

- A. Jamb Anchors:
 - 1. Type: Anchors of minimum size and type required by applicable door and frame standard, and suitable for performance level indicated.
 - 2. Quantity: Minimum of three anchors per jamb, with one additional anchor for frames with no floor anchor. Provide one additional anchor for each 24 inches of frame height above 7 feet.
 - 3. Post installed Expansion Anchor: Minimum 3/8-inch- diameter bolts with expansion shields or inserts, with manufacturer's standard pipe spacer.
- B. Floor Anchors: Provide floor anchors for each jamb and mullion that extends to floor.
- C. Material: ASTM A879/A879M, Commercial Steel (CS), 04Z coating designation; mill phosphatized.
 - 1. For anchors built into exterior walls, steel sheet complying with ASTM A1008/A1008M or ASTM A1011/A1011M; hot-dip galvanized according to ASTM A153/A153M, Class B.

2.5 MATERIALS

- A. Cold-Rolled Steel Sheet: ASTM A1008/A1008M, Commercial Steel (CS), Type B; suitable for exposed applications.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- B. Hot-Rolled Steel Sheet: ASTM A1011/A1011M, Commercial Steel (CS), Type B; free of scale, pitting, or surface defects; pickled and oiled.
- C. Metallic-Coated Steel Sheet: ASTM A653/A653M, Commercial Steel (CS), Type B.
- D. Inserts, Bolts, and Fasteners: Hot-dip galvanized according to ASTM A153/A153M.
- E. Power-Actuated Fasteners in Concrete: Fastener system of type suitable for application indicated, fabricated from corrosion-resistant materials, with clips or other accessory devices for attaching hollow-metal frames of type indicated.
- F. Glazing: Comply with requirements in Section 088000 "Glazing."

2.6 FABRICATION

- A. Hollow-Metal Frames: Fabricate in one piece except where handling and shipping limitations require multiple sections. Where frames are fabricated in sections, provide alignment plates or angles at each joint, fabricated of metal of same or greater thickness as frames.
 - 1. Sidelite and Transom Bar Frames: Provide closed tubular members with no visible face seams or joints, fabricated from same material as door frame. Fasten members at crossings and to jambs by welding.
 - 2. Provide countersunk, flat- or oval-head exposed screws and bolts for exposed fasteners unless otherwise indicated.
 - 3. Door Silencers: Except on weather-stripped frames, drill stops to receive door silencers as follows. Keep holes clear during construction.
 - a. Single-Door Frames: Drill stop in strike jamb to receive three door silencers.
 - 4. Terminated Stops: Terminate stops 6 inches above finish floor with a 90 - degree angle cut, and close open end of stop with steel sheet closure. Cover opening in extension of frame with welded-steel filler plate, with welds ground smooth and flush with frame.
- B. Hardware Preparation: Factory prepare hollow-metal frames to receive templated mortised hardware, and electrical wiring; include cutouts, reinforcement, mortising, drilling, and tapping according to SDI A250.6, the Door Hardware Schedule on Drawings, and templates.
 - 1. Reinforce frames to receive non-templated, mortised, and surface-mounted door hardware.
 - 2. Comply with BHMA A156.115 for preparing hollow-metal frames for hardware.
- C. Glazed Lites: Provide stops and moldings around glazed lites where indicated.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

Form corners of stops and moldings with mitered hairline joints.

1. Multiple Glazed Lites: Provide fixed and removable stops and moldings so that each glazed lite is capable of being removed independently.
2. Provide fixed frame moldings on outside of exterior and on secure side of interior frames. Provide loose stops and moldings on inside of hollow-metal frames.
3. Coordinate rabbet width between fixed and removable stops with glazing and installation types indicated.
4. Provide stops for installation with countersunk flat- or oval-head machine screws spaced uniformly not more than 9 inches o.c. and not more than 2 inches o.c. from each corner.

2.7 STEEL FINISHES

- A. Prime Finish: Clean, pretreat, and apply manufacturer's standard primer.
 1. Shop Primer: Manufacturer's standard, fast-curing, lead- and chromate-free primer complying with SDI A250.10; recommended by primer manufacturer for substrate; compatible with substrate and field-applied coatings despite prolonged exposure.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Remove welded-in shipping spreaders installed at factory. Restore exposed finish by grinding, filling, and dressing, as required to make repaired area smooth, flush, and invisible on exposed faces. Touch up factory-applied finishes where spreaders are removed.
- B. Drill and tap frames to receive non-templated, mortised, and surface-mounted door hardware.

3.2 INSTALLATION

- A. General: Install hollow-metal frames plumb, rigid, properly aligned, and securely fastened in place. Comply with approved Shop Drawings and with manufacturer's written instructions. Comply with SDI A250.11
- B. Set frames accurately in position; plumbed, aligned, and braced securely until permanent anchors are set. After wall construction is complete, remove temporary braces without damage to completed Work.
 1. Where frames are fabricated in sections, field splice at approved locations by welding face joint continuously; grind, fill, dress, and make splice

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- smooth, flush, and invisible on exposed faces. Touch-up finishes.
2. Install frames with removable stops located on secure side of opening.
- C. Fire-Rated Openings: Install frames according to NFPA 80.
- D. Floor Anchors: Secure with post installed expansion anchors.
1. Floor anchors may be set with power-actuated fasteners instead of post installed expansion anchors if so indicated and approved on Shop Drawings.
- E. Solidly pack mineral-fiber insulation inside frames.
- F. Masonry Walls: Coordinate installation of frames to allow for solidly filling space between frames and masonry with grout or mortar.
- G. In-Place Concrete or Masonry Construction: Secure frames in place with post installed expansion anchors.
- H. Installation Tolerances: Adjust hollow-metal frames to the following tolerances:
1. Squareness: Plus or minus 1/16 inch, measured at door rabbet on a line 90 degrees from jamb perpendicular to frame head.
 2. Alignment: Plus or minus 1/16 inch, measured at jambs on a horizontal line parallel to plane of wall.
 3. Twist: Plus or minus 1/16 inch, measured at opposite face corners of jambs on parallel lines, and perpendicular to plane of wall.
 4. Plumbness: Plus or minus 1/16 inch, measured at jambs at floor.
- I. Glazing: Comply with installation requirements in Section 088000 "Glazing" and with hollow-metal manufacturer's written instructions.

3.3 CLEANING AND TOUCHUP

- A. Prime-Coat Touchup: Immediately after erection, sand smooth rusted or damaged areas of prime coat and apply touchup of compatible air-drying, rust-inhibitive primer.
- B. Metallic-Coated Surface Touchup: Clean abraded areas and repair with galvanizing repair paint according to manufacturer's written instructions.
- C. Factory-Finish Touchup: Clean abraded areas and repair with same material used for factory finish according to manufacturer's written instructions.
- D. Touchup Painting: Cleaning and touchup painting of abraded areas of paint are specified in painting Sections.

END OF SECTION 08 12 13

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 08 14 16 - FLUSH WOOD DOORS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Solid-core five-ply flush wood doors and transom panels for opaque finish.

B. Related Requirements:

1. Section 064023 "Interior Architectural Woodwork" for wood door frames.
2. Section 099123 "Interior Painting" for field finishing doors.

1.2 COORDINATION

- A. Coordinate requirements for installing door hardware, including electrified door hardware, and access control and security systems.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of specified product. Include information indicating compliance with performance requirements indicated.

1. Door core materials and construction.
2. Door edge construction.
3. Door face type and characteristics.
4. Door frame construction.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Comply with requirements of referenced standard and manufacturer's written instructions.
- B. Package doors individually in plastic bags or cardboard cartons.

1.5 FIELD CONDITIONS

A. Environmental Limitations:

1. Do not deliver or install doors until spaces are enclosed and weathertight, wet-work in spaces is complete and dry, and HVAC system is operating

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

and maintaining temperature and relative humidity at levels designed for building occupants for the remainder of construction period.

1.6 WARRANTY

- A. Special Warranty: Manufacturer agrees to repair or replace doors that fail in materials or workmanship within specified warranty period.
 - 1. Failures include, but are not limited to, the following:
 - a. Delamination of veneer.
 - b. Warping (bow, cup, or twist) more than 1/8 inch in a 42-by-84-inch section.
 - c. Telegraphing of core construction in face veneers exceeding 0.01 inch in a 3-inch span.
 - 2. Warranty also includes installation and finishing that may be required due to repair or replacement of defective doors and frames.
 - 3. Warranty Period for Solid-Core Interior Doors: Life of installation.

PART 2 - PRODUCTS

2.1 SOURCE LIMITATIONS

- A. Obtain flush wood doors from single manufacturer.

2.2 FLUSH WOOD DOORS AND FRAMES, GENERAL

- A. Quality Standard: In addition to requirements specified, comply with AWI/AWMAC/WI's "Architectural Woodwork Standards."
 - 1. Provide labels from AWI certification program indicating that doors comply with requirements of grades specified.

2.3 SOLID-CORE FIVE-PLY FLUSH WOOD DOORS AND TRANSOM PANELS FOR OPAQUE FINISH

- A. Interior Doors, Solid-Core Five-Ply for Opaque Finish:
 - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Lambton Doors
 - b. Lynden Door, Inc.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- c. Manhattan Door Corp.
 - d. Oregon Door
 - e. VT Industries, Inc.
- 2. Performance Grade: ANSI/WDMA I.S. 1A as indicated on Drawings.
 - 3. ANSI/WDMA I.S. 1A Quality Grade: Premium.
 - 4. Architectural Woodwork Standards Quality Grade: Premium.
 - 5. Faces: Any closed-grain hardwood of mill option.
 - a. Hardboard Faces: ANSI A135.4, Class 1 (tempered) or Class 2 (standard).
 - 6. Exposed Vertical and Top Edges: Any closed-grain hardwood.
 - a. Mineral-Core Doors: At hinge stiles, provide laminated-edge construction with improved screw-holding capability and split resistance. Comply with specified requirements for exposed edges.
 - 1) Screw-Holding Capability: 550 lbf in accordance with WDMA T.M. 10.
 - 7. Core for Non-Fire-Rated Doors:
 - a. Particleboard: ANSI A208.1, Grade LD-1.
 - b. Structural Composite Lumber:
 - 1) Screw Withdrawal, Door Face: 475 lbf in accordance with WDMA T.M. 10.
 - 2) Screw Withdrawal, Vertical Door Edge: 475 lbf in accordance with WDMA T.M. 10.
 - 8. Construction: Five plies, hot-pressed bonded (vertical and horizontal edging is bonded to core), with entire unit abrasive planed before veneering.

2.4 FABRICATION

- A. Factory fit doors to suit frame-opening sizes indicated.
 - 1. Comply with clearance requirements of referenced quality standard for fitting unless otherwise indicated.
- B. Factory machine doors for hardware that is not surface applied.
 - 1. Locate hardware to comply with DHI-TDH-007.
 - 2. Coordinate with hardware mortises in metal frames, to verify dimensions and alignment before factory machining.
- C. Transom and Side Panels:

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1. Fabricate matching panels with same construction, exposed surfaces, and finish as specified for associated doors.
2. Finish bottom edges of transoms and top edges of rabbeted doors same as door stiles.
3. Fabricate door and transom panels with full-width, solid-lumber, meeting rails.
4. Provide factory-installed spring bolts for concealed attachment into jambs of metal door frames.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine doors and installed door frames, with Installer present, before hanging doors.
 1. Verify that installed frames comply with indicated requirements for type, size, location, and swing characteristics and have been installed with level heads and plumb jambs.
 2. Reject doors with defects.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION OF FLUSH WOOD DOORS AND TRANSOM PANELS

- A. Install doors to comply with manufacturer's written instructions and referenced quality standard, and as indicated.
- B. Install frames level, plumb, true, and straight.
 1. Shim as required with concealed shims. Install level and plumb to a tolerance of 1/8 inch in 96 inches.
 2. Anchor frames to anchors or blocking built in or directly attached to substrates.
 - a. Secure with countersunk, concealed fasteners and blind nailing.
 - b. Use fine finishing nails for exposed fastening, countersunk and filled flush with woodwork.
 - 1) For factory-finished items, use filler matching finish of items being installed.
- C. Job-Fitted Doors:
 1. Align and fit doors in frames with uniform clearances and bevels as indicated below.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- a. Do not trim stiles and rails in excess of limits set by manufacturer or permitted for fire-rated doors.
 2. Machine doors for hardware.
 3. Seal edges of doors, edges of cutouts, and mortises after fitting and machining.
 4. Clearances:
 - a. Provide 1/8 inch at heads, jambs, and between pairs of doors.
 - b. Provide 1/8 inch from bottom of door to top of decorative floor finish or covering unless otherwise indicated on Drawings.
 - c. Where threshold is shown or scheduled, provide 1/4 inch from bottom of door to top of threshold unless otherwise indicated.
 5. Bevel non-fire-rated doors 1/8 inch in 2 inches at lock and hinge edges.
- D. Factory-Fitted Doors: Align in frames for uniform clearance at each edge.

3.3 FIELD QUALITY CONTROL

- A. Inspections: Provide inspection of installed Work through certifying that wood doors and frames, including installation, comply with the specified grade.
- B. Repair or remove and replace installations where inspections indicate that they do not comply with specified requirements.
- C. Reinspect repaired or replaced installations to determine if replaced or repaired door assembly installations comply with specified requirements.

3.4 ADJUSTING

- A. Operation: Rehang or replace doors that do not swing or operate freely.

END OF SECTION 08 14 16

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 08 41 13 - ALUMINUM-FRAMED ENTRANCES AND STOREFRONTS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Aluminum-framed entrance and storefront systems.

1.2 ACTION SUBMITTALS

A. Product Data: For each type of product.

1. Construction details, material descriptions, dimensions of individual components and profiles, and finishes.
2. Operating characteristics, electrical characteristics, and furnished accessories.

B. Shop Drawings:

1. Plans, elevations, sections, full-size details, and attachments to other work.
2. Details of provisions for assembly expansion and contraction and for draining moisture occurring within the assembly to the exterior.
3. Connection to and continuity with adjacent thermal, weather, air, and vapor barriers.
4. Point-to-point wiring diagrams showing the following:
 - a. Power requirements for each electrically operated door hardware.
 - b. Location and types of switches, signal device, conduit sizes, and number and size of wires.

C. Samples for Initial Selection: Manufacturer's standard color sheets, showing full range of available colors for each type of exposed finish.

D. Samples for Verification: Actual sample of finished products for each type of exposed finish.

E. Fabrication Sample: Of each vertical-to-horizontal intersection of assemblies, made from 12-inch lengths of full-size components and showing details of the following:

1. Joinery, including concealed welds.
2. Anchorage.
3. Expansion provisions.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

4. Glazing.
 5. Flashing and drainage.
- F. Entrance Door Hardware Schedule: Prepared by or under supervision of supplier, detailing fabrication and assembly of entrance door hardware, as well as procedures and diagrams. Coordinate final entrance door hardware schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of entrance door hardware.

1.3 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For aluminum-framed entrance and storefront systems.

1.4 QUALITY ASSURANCE

- A. Installer Qualifications:
1. Entity that employs installers and supervisors who are trained and approved by manufacturer.
- B. Product Options: Information on Drawings and in Specifications establishes requirements for aesthetic effects and performance characteristics of assemblies. Aesthetic effects are indicated by dimensions, arrangements, alignment, and profiles of components and assemblies as they relate to sightlines, to one another, and to adjoining construction.
1. Do not change intended aesthetic effects, as judged solely by Architect, except with Architect's approval. If changes are proposed, submit comprehensive explanatory data to Architect for review.
- C. Structural-Sealant Glazing: Comply with ASTM C1401 for design and installation of storefront systems that include structural glazing.

1.5 WARRANTY

- A. Special Warranty: Manufacturer and Installer agree to repair or replace components of aluminum-framed entrance and storefront systems that fail in materials or workmanship within specified warranty period.
1. Failures include, but are not limited to, the following:
 - a. Structural failures, including water, wind and sound intrusion.
 - b. Faulty operation of Insert components.
 - c. Deterioration of metals, metal finishes, and other materials beyond normal use.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

2. Warranty Period: 1 years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 SOURCE LIMITATIONS

- A. Obtain all components of aluminum-framed entrance and storefront system, including framing and accessories, from single manufacturer.

2.2 PERFORMANCE REQUIREMENTS

- A. General Performance: Comply with performance requirements specified, as determined by testing of aluminum-framed entrance and storefront systems representing those indicated for this Project without failure due to defective manufacture, fabrication, installation, or other defects in construction.
1. Aluminum-framed entrance and storefront systems to withstand movements of supporting structure, including, but not limited to, twist, column shortening, long-term creep, and deflection from uniformly distributed and concentrated live loads.
 2. Failure also includes the following:
 - a. Thermal stresses transferring to building structure.
 - b. Glass breakage.
 - c. Noise or vibration created by wind and thermal and structural movements.
 - d. Loosening or weakening of fasteners, attachments, and other components.
 - e. Failure of operating units.
- B. Structural Loads:
1. Wind Loads: As indicated on Drawings.
 2. Other Design Loads: As indicated on Drawings.
- C. Water Penetration under Static Pressure: Test in accordance with ASTM E331 as follows:
1. No evidence of water penetration through fixed glazing and framing areas, including entrance doors, when tested in accordance with a minimum static-air-pressure differential of 20 percent of positive wind-load design pressure, but not less than 10 lbf/sq. ft..
- D. Water Penetration under Dynamic Pressure: Test in accordance with AAMA 501.1 as follows:

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1. No evidence of water penetration through fixed glazing and framing areas when tested at dynamic pressure equal to 20 percent of positive wind-load design pressure, but not less than 10 lbf/sq. ft..
 2. Maximum Water Leakage: In accordance with AAMA 501.1. Water leakage does not include water controlled by flashing and gutters, or water that is drained to exterior.
- E. Energy Performance: Certified and labeled by manufacturer for energy performance as follows:
1. Thermal Transmittance (U-factor):
 - a. Fixed Glazing and Framing Areas: U-factor for the system of not more than 0.45 Btu/sq. ft. x h x deg F as determined in accordance with NFRC 100.
 - b. Entrance Doors: U-factor of not more than 0.68 Btu/sq. ft. x h x deg F as determined in accordance with NFRC 100.
 2. Solar Heat-Gain Coefficient (SHGC):
 - a. Fixed Glazing and Framing Areas: SHGC for the system of not more than 0.45 as determined in accordance with NFRC 200.
 - b. Entrance Doors: SHGC of not more than 0.45 as determined in accordance with NFRC 200.
 3. Air Leakage:
 - a. Fixed Glazing and Framing Areas: Air leakage for the system of not more than 0.06 cfm/sq. ft. at a static-air-pressure differential of 6.24 lbf/sq. ft. when tested in accordance with ASTM E283.
 - b. Entrance Doors: Air leakage of not more than 1.0 cfm/sq. ft. at a static-air-pressure differential of 1.57 lbf/sq. ft..
 4. Condensation Resistance Factor (CRF):
 - a. Fixed Glazing and Framing Areas: CRF for the system of not less than 55 as determined in accordance with AAMA 1503.
 - b. Entrance Doors: CRF of not less than 63 as determined in accordance with AAMA 1503.
- F. Noise Reduction: Test in accordance with ASTM E90, with ratings determined by ASTM E1332, as follows.
1. Outdoor-Indoor Transmission Class: Minimum 30.
- G. Thermal Movements: Allow for thermal movements resulting from ambient and surface temperature changes.
1. Temperature Change: 120 deg F, ambient; 180 deg F, material surfaces.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

2.3 ALUMINUM-FRAMED ENTRANCE AND STOREFRONT SYSTEMS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
1. Arcadia Inc.
 2. Boyd Aluminum Mfg. Co.
 3. EFCO Corporation; Architectural Metals; Apogee Enterprises, Inc.
 4. Kawneer Company, Inc.; Arconic Corporation
 5. Manko Window Systems, Inc.
 6. Trulite Glass & Aluminum Solutions, LLC.
 7. Tubelite Inc.; Architectural Metals; Apogee Enterprises, Inc.
- B. Framing Members: Manufacturer's extruded- or formed-aluminum framing members of thickness required and reinforced as required to support imposed loads.
1. Exterior Framing Construction: Thermally broken.
 2. Glazing System: Retained mechanically with gaskets on four sides
Retained mechanically with gaskets on two sides and structural sealant on two sides.
 3. Glazing Plane: Front.
 4. Finish: Color anodic finish.
 5. Fabrication Method: Field-fabricated stick system.
 6. Aluminum: Alloy and temper recommended by manufacturer for type of use and finish indicated.
 7. Steel Reinforcement: As required by manufacturer.
- C. Backer Plates: Manufacturer's standard, continuous backer plates for framing members, if not integral, where framing abuts adjacent construction.
- D. Brackets and Reinforcements: Manufacturer's standard high-strength aluminum with nonstaining, nonferrous shims for aligning system components.
- E. Entrance Doors: Manufacturer's standard glazed entrance doors for manual-swing or automatic operation.
1. Door Construction: 2-inch overall thickness, with minimum 0.188-inch-thick, extruded-aluminum tubular rail and stile members. Mechanically fasten corners with reinforcing brackets that are deeply penetrated and fillet welded or that incorporate concealed tie rods.
 - a. Thermal Construction: High-performance plastic connectors separate aluminum members exposed to the exterior from members exposed to the interior.
 2. Door Design: As indicated.
 3. Glazing Stops and Gaskets: Square, snap-on, extruded-aluminum stops

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

and preformed gaskets.

a. Provide nonremovable glazing stops on outside of door.

4. Finish: Match adjacent storefront framing finish.

2.4 ENTRANCE DOOR HARDWARE

- A. General: Provide entrance door hardware and entrance door hardware sets indicated in door and frame schedule for each entrance door, to comply with requirements in this Section.
1. Entrance Door Hardware Sets: Provide quantity, item, size, finish or color indicated, and products complying with BHMA standard referenced.
 2. Sequence of Operation: Provide electrified door hardware function, sequence of operation, and interface with other building control systems indicated.
 3. Opening-Force Requirements:
 - a. Egress Doors: Not more than 15 lbf to release the latch and not more than 30 lbf to set the door in motion and not more than 15 lbf to open the door to its minimum required width.
- B. Designations: Requirements for design, grade, function, finish, quantity, size, and other distinctive qualities of each type of entrance door hardware are indicated in "Entrance Door Hardware Sets" Article. Products are identified by using entrance door hardware designations as follows:
1. Named Manufacturers' Products: Manufacturer and product designation are listed for each door hardware type required for the purpose of establishing minimum requirements. Manufacturers' names are abbreviated in "Entrance Door Hardware Sets" Article.
 2. References to BHMA Standards: Provide products complying with these standards and requirements for description, quality, and function.
- C. Pivot Hinges: BHMA A156.4, Grade 1.
1. Offset-Pivot Hinges: Provide top, bottom, and intermediate offset pivots at each door leaf.
- D. Butt Hinges: BHMA A156.1, Grade 1, radius corner.
1. Nonremovable Pins: Provide setscrew in hinge barrel that, when tightened into a groove in hinge pin, prevents removal of pin while entrance door is closed.
 2. Exterior Hinges: Stainless steel, with stainless steel pin.
 3. Quantities:

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- a. For doors up to 87 inches high, provide three hinges per leaf.
- E. Mortise Auxiliary Locks: BHMA A156.5, Grade 1.
- F. Manual Flush Bolts: BHMA A156.16, Grade 1.
- G. Automatic and Self-Latching Flush Bolts: BHMA A156.3, Grade 1.
- H. Panic Exit Devices: BHMA A156.3, Grade 1, listed and labeled by a testing and inspecting agency acceptable to authorities having jurisdiction, for panic protection, based on testing in accordance with UL 305.
- I. Cylinders:
 - 1. As specified in Section 087100 "Door Hardware."
 - 2. BHMA A156.5, Grade 1.
- J. Strikes: Provide strike with black-plastic dust box for each latch or lock bolt; fabricated for aluminum framing.
- K. Operating Trim: BHMA A156.6.
- L. Closers: BHMA A156.4, Grade 1, with accessories required for a complete installation, sized as required by door size, exposure to weather, and anticipated frequency of use; adjustable to comply with field conditions and requirements for opening force.
- M. Concealed Overhead Holders and Stops: BHMA A156.8, Grade 1.
- N. Door Stops: BHMA A156.16, Grade 1, floor or wall mounted, as appropriate for door location indicated, with integral rubber bumper.
- O. Weather Stripping: Manufacturer's standard replaceable components.
 - 1. Compression Type: Made of ASTM D2000 molded neoprene or ASTM D2287 molded PVC.
 - 2. Sliding Type: AAMA 701/702, made of wool, polypropylene, or nylon woven pile with nylon-fabric or aluminum-strip backing.
- P. Weather Sweeps: Manufacturer's standard exterior-door bottom sweep with concealed fasteners on mounting strip.
- Q. Thresholds: BHMA A156.21 raised thresholds beveled with a slope of not more than 1:2, with maximum height of 1/2 inch.
- R. Finger Guards: Manufacturer's standard collapsible neoprene or PVC gasket anchored to frame hinge-jamb at center-pivoted doors.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

2.5 MATERIALS

- A. Sheet and Plate: ASTM B209.
- B. Extruded Bars, Rods, Profiles, and Tubes: ASTM B221.
- C. Structural Profiles: ASTM B308/B308M.
- D. Steel Reinforcement:
 - 1. Structural Shapes, Plates, and Bars: ASTM A36/A36M.
 - 2. Cold-Rolled Sheet and Strip: ASTM A1008/A1008M.
 - 3. Hot-Rolled Sheet and Strip: ASTM A1011/A1011M.
- E. Steel Reinforcement Primer: Manufacturer's standard zinc-rich, corrosion-resistant primer complying with SSPC-PS Guide No. 12.00; applied immediately after surface preparation and pretreatment. Select surface preparation methods in accordance with recommendations in SSPC-SP COM, and prepare surfaces in accordance with applicable SSPC standard.

2.6 ACCESSORIES

- A. Fasteners and Accessories: Manufacturer's standard corrosion-resistant, nonstaining, nonbleeding fasteners and accessories compatible with adjacent materials.
 - 1. Use self-locking devices where fasteners are subject to loosening or turning out from thermal and structural movements, wind loads, or vibration.
 - 2. Reinforce members as required to receive fastener threads.
 - 3. Use exposed fasteners with countersunk Phillips screw heads , finished to match framing system.
- B. Anchors: Three-way adjustable anchors with minimum adjustment of **[1 inch]<Insert dimension>** that accommodate fabrication and installation tolerances in material and finish compatible with adjoining materials and recommended by manufacturer.
 - 1. Concrete and Masonry Inserts: Hot-dip galvanized cast-iron, malleable-iron, or steel inserts complying with ASTM A123/A123M or ASTM A153/A153M requirements.
- C. Concealed Flashing: Manufacturer's standard corrosion-resistant, nonstaining, nonbleeding flashing compatible with adjacent materials.
- D. Bituminous Paint: Cold-applied asphalt-mastic paint containing no asbestos, formulated for 30-mil thickness per coat.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

2.7 FABRICATION

- A. Form or extrude aluminum shapes before finishing.
- B. Fabricate components that, when assembled, have the following characteristics:
 - 1. Profiles that are sharp, straight, and free of defects or deformations.
 - 2. Accurately fitted joints with ends coped or mitered.
 - 3. Physical and thermal isolation of glazing from framing members.
 - 4. Accommodations for thermal and mechanical movements of glazing and framing to maintain required glazing edge clearances.
 - 5. Fasteners, anchors, and connection devices that are concealed from view to greatest extent possible.
- C. Mechanically Glazed Framing Members: Fabricate for flush glazing without projecting stops.
- D. Entrance Door Frames: Reinforce as required to support loads imposed by door operation and for installing entrance door hardware.
 - 1. At interior and exterior doors, provide compression weather stripping at fixed stops.
- E. Entrance Doors: Reinforce doors as required for installing entrance door hardware.
 - 1. At pairs of exterior doors, provide sliding-type weather stripping retained in adjustable strip and mortised into door edge.
 - 2. At exterior doors, provide weather sweeps applied to door bottoms.
- F. Entrance Door Hardware Installation: Factory install entrance door hardware to the greatest extent possible. Cut, drill, and tap for factory-installed entrance door hardware before applying finishes.
- G. After fabrication, clearly mark components to identify their locations in Project in accordance with Shop Drawings.

2.8 ALUMINUM FINISHES

- A. Color Anodic Finish: AAMA 611, AA-M12C22A32/A34, Class II, 0.010 mm or thicker.
 - 1. Color: to match existing.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION OF ALUMINUM-FRAMED ENTRANCE AND STOREFRONT SYSTEMS

- A. Comply with manufacturer's written instructions.
- B. Do not install damaged components.
- C. Fit joints to produce hairline joints free of burrs and distortion.
- D. Rigidly secure nonmovement joints.
- E. Install anchors with separators and isolators to prevent metal corrosion and electrolytic deterioration and to prevent impeding movement of moving joints.
- F. Seal perimeter and other joints watertight unless otherwise indicated.
- G. Metal Protection:
 - 1. Where aluminum is in contact with dissimilar metals, protect against galvanic action by painting contact surfaces with materials recommended by manufacturer for this purpose or by installing nonconductive spacers.
 - 2. Where aluminum is in contact with concrete or masonry, protect against corrosion by painting contact surfaces with bituminous paint.
- H. Install components plumb and true in alignment with established lines and grades.
- I. Install operable units level and plumb, securely anchored, and without distortion. Adjust weather-stripping contact and hardware movement to produce proper operation.
- J. Install entrance doors to produce smooth operation and tight fit at contact points.
 - 1. Exterior Doors: Install to produce weathertight enclosure and tight fit at weather stripping.
 - 2. Field-Installed Entrance Door Hardware: Install surface-mounted entrance door hardware in accordance with entrance door hardware manufacturers'

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

written instructions using concealed fasteners to greatest extent possible.

3.3 ERECTION TOLERANCES

- A. Install aluminum-framed entrance and storefront systems to comply with the following maximum tolerances:
1. Plumb: 1/8 inch in 10 feet; 1/4 inch in 40 feet.
 2. Level: 1/8 inch in 20 feet; 1/4 inch in 40 feet.
 3. Alignment:
 - a. Where surfaces abut in line or are separated by reveal or protruding element up to 1/2 inch wide, limit offset from true alignment to 1/16 inch.
 - b. Where surfaces are separated by reveal or protruding element from 1/2 to 1 inch wide, limit offset from true alignment to 1/8 inch.
 - c. Where surfaces are separated by reveal or protruding element of 1 inch wide or more, limit offset from true alignment to 1/4 inch.
 4. Location: Limit variation from plane to 1/8 inch in 12 feet; 1/2 inch over total length.

3.4 FIELD QUALITY CONTROL

- A. Aluminum-framed entrance and storefront systems will be considered defective if they do not pass tests and inspections.
- B. Prepare test and inspection reports.

END OF SECTION 08 41 13

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 09 29 00 - GYPSUM BOARD

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Interior gypsum board.
- B. Related Requirements:
 - 1. Section 061600 "Sheathing" for gypsum sheathing for exterior applications.
 - 2. Section 079219 "Acoustical Joint Sealants" for acoustical joint sealants installed in gypsum board assemblies.
 - 3. Section 092216 "Non-Structural Metal Framing" for nonstructural steel framing and suspension systems that support gypsum board panels.
 - 4. Section 092613 "Gypsum Veneer Plastering" for gypsum base for veneer plaster and for other components of gypsum-veneer-plaster finishes.
 - 5. Section 093013 "Ceramic Tiling" for tile backing panels installed as substrates for ceramic tile.

1.2 DELIVERY, STORAGE, AND HANDLING

- A. Store materials inside under cover and keep them dry and protected against weather, condensation, direct sunlight, construction traffic, and other potential causes of damage. Stack panels flat and supported on risers on a flat platform to prevent sagging.

1.3 FIELD CONDITIONS

- A. Environmental Limitations: Comply with ASTM C840 requirements or manufacturer's written instructions, whichever are more stringent.
- B. Do not install paper-faced gypsum panels until installation areas are enclosed and conditioned.
- C. Do not install panels that are wet, moisture damaged, or mold damaged.
 - 1. Indications that panels are wet or moisture damaged include, but are not limited to, discoloration, sagging, or irregular shape.
 - 2. Indications that panels are mold damaged include, but are not limited to, fuzzy or splotchy surface contamination and discoloration.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

PART 2 - PRODUCTS

2.1 SOURCE LIMITATIONS

- A. Obtain each type of gypsum board and joint finishing material from single source with resources to provide products of consistent quality in appearance and physical properties.

2.2 INTERIOR GYPSUM BOARD

- A. Gypsum Board, Type X: ASTM C1396/C1396M.
1. Basis-of-Design Product: Subject to compliance with requirements, provide or comparable product by one of the following:
 - a. American Gypsum
 - b. CertainTeed; SAINT-GOBAIN
 - c. Georgia-Pacific Gypsum LLC
 - d. USG Corporation
 2. Thickness: As indicated on Drawings.
 3. Long Edges: Tapered.
- B. Trim for Interior Gypsum Board: ASTM C1047.
1. Material: Galvanized-steel sheet or aluminum-coated steel sheet, rolled zinc, plastic, or paper-faced galvanized-steel sheet.
 2. Shapes:
 - a. Cornerbead.
 - b. Bullnose bead.
 - c. LC-Bead: J-shaped; exposed long flange receives joint compound.
 - d. L-Bead: L-shaped; exposed long flange receives joint compound.
 - e. Expansion (Control) Joint: One-piece, rolled zinc with V-shaped slot and removable strip covering slot opening.
- C. Joint Treatment Materials for Interior Gypsum Board: Comply with ASTM C475/C475M requirements.
1. Joint Tape: Paper.
 2. Joint Compound: For each coat, use formulation that is compatible with other compounds applied on previous or for successive coats.
 - a. Mold-Resistant Joint Compound: Use mold-resistant formulations with mold-resistant gypsum board products.
 - b. Prefilling: At open joints and damaged surface areas, use setting-type taping compound.
 - c. Embedding and First Coat: For embedding tape and first coat on

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

joints, fasteners, and trim flanges, use drying-type, all-purpose compound.

- d. Fill Coat: For second coat, use drying-type, all-purpose compound.
- e. Finish Coat: For third coat, use drying-type, all-purpose compound.
- f. Skim Coat: For final coat of Level 5 finish, use drying-type, all-purpose compound.

2.3 AUXILIARY MATERIALS

- A. Provide auxiliary materials that comply with referenced installation standards and manufacturer's written instructions.
- B. Laminating Adhesive: Adhesive or joint compound recommended in writing by manufacturer for directly adhering gypsum panels to continuous substrate.
- C. Steel Drill Screws: ASTM C1002 unless otherwise specified or indicated on Drawings.
 - 1. Use screws complying with ASTM C954 for fastening panels to steel members from 0.033 to 0.112 inch thick.
- D. Sound-Attenuation Blankets: ASTM C665, Type I (blankets without membrane facing) produced by combining thermosetting resins with mineral fibers as follows:
- E. Thermal Insulation: As specified in Section 072100 "Thermal Insulation."

2.4 TEXTURE FINISH

- A. Primer: As recommended in writing by texture finish manufacturer.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas and substrates including welded hollow-metal frames and support framing, with Installer present, for compliance with requirements and other conditions affecting performance of the Work.
- B. Examine panels before installation. Reject panels that are wet, moisture damaged, or mold damaged.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3.2 INSTALLATION AND FINISHING OF GYPSUM BOARD, GENERAL

- A. Comply with ASTM C840 requirements.
- B. Install ceiling panels across framing to minimize the number of abutting end joints and to avoid abutting end joints in central area of each ceiling. Stagger abutting end joints of adjacent panels not less than one framing member.
- C. Install panels with face side out. Butt panels together for a light contact at edges and ends with not more than 1/16 inch of open space between panels. Do not force into place.
- D. Locate edge and end joints over supports, except in ceiling applications where intermediate supports or gypsum board back-blocking is provided behind end joints. Do not place tapered edges against cut edges or ends. Stagger vertical joints on opposite sides of partitions. Do not make joints other than control joints at corners of framed openings.
- E. Form expansion (control) joints with space between edges of adjoining gypsum panels.
- F. Cover both faces of support framing with gypsum panels in concealed spaces (above ceilings, etc.), except in chases braced internally.
 - 1. Unless concealed application is indicated or required for sound, fire, air, or smoke ratings, coverage may be accomplished with scraps of not less than 8 sq. ft. in area.
 - 2. Fit gypsum panels around ducts, pipes, and conduits.
 - 3. Where partitions intersect structural members projecting below underside of floor/roof slabs and decks, cut gypsum panels to fit profile formed by structural members; allow 1/4- to 3/8-inch- wide joints to install sealant.
- G. Isolate perimeter of gypsum board applied to non-load-bearing partitions at structural abutments. Provide 1/4- to 1/2-inch- wide spaces at these locations and trim edges with edge trim where edges of panels are exposed. Seal joints between edges and abutting structural surfaces with acoustical sealant.
- H. Attachment to Steel Framing: Attach panels so leading edge or end of each panel is attached to open (unsupported) edges of stud flanges first.
- I. Wood Framing: Install gypsum panels over wood framing, with floating internal corner construction. Do not attach gypsum panels across the flat grain of wide-dimension lumber, including floor joists and headers. Float gypsum panels over these members or provide control joints to counteract wood shrinkage.
- J. STC-Rated Assemblies: Seal construction at perimeters, behind control joints, and at openings and penetrations with a continuous bead of acoustical sealant. Install acoustical sealant at both faces of partitions at perimeters and through penetrations. Comply with ASTM C919 requirements and with manufacturer's written instructions for locating edge trim and closing off sound-flanking paths

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

around or through assemblies, including sealing partitions above acoustical ceilings.

- K. Install sound-attenuation blankets before installing gypsum panels unless blankets are readily installed after panels have been installed on one side.

3.3 INSTALLATION OF INTERIOR GYPSUM BOARD

A. Single-Layer Application:

1. On ceilings, apply gypsum panels before wall/partition board application to greatest extent possible and at right angles to framing unless otherwise indicated on Drawings.
2. On partitions/walls, apply gypsum panels horizontally (perpendicular to framing) unless otherwise specified or indicated on Drawings or required by fire-resistance-rated assembly, and minimize end joints.
 - a. Stagger abutting end joints not less than one framing member in alternate courses of panels.
 - b. At stairwells and other high walls, install panels horizontally unless otherwise indicated on Drawings or required by fire-resistance-rated assembly.
3. Fastening Methods: Apply gypsum panels to supports with steel drill screws.

B. Multilayer Application:

1. On ceilings, apply gypsum board indicated for base layers before applying base layers on walls/partitions; apply face layers in same sequence. Apply base layers at right angles to framing members and offset face-layer joints one framing member, 16 inches minimum, from parallel base-layer joints, unless otherwise indicated on Drawings or required by fire-resistance-rated assembly.
2. On partitions/walls, apply gypsum board indicated for base layers and face layers vertically (parallel to framing) with joints of base layers located over studs or furring members and face-layer joints offset at least one stud or furring member with base-layer joints unless otherwise indicated on Drawings or required by fire-resistance-rated assembly. Stagger joints on opposite sides of partitions.
3. Fastening Methods: Fasten base layers and face layers separately to supports with screws.

- #### **C. Trim for Interior Gypsum Board:** For trim with back flanges intended for fasteners, attach to framing with same fasteners used for panels. Otherwise, attach trim in accordance with manufacturer's written instructions.

1. Cornerbead: Install at outside corners unless otherwise specified or indicated on Drawings.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

2. Bullnose Bead: Install at outside corners.
 3. LC-Bead: Install at exposed panel edges.
 4. L-Bead: Install where indicated on Drawings.
 5. U-Bead: Install where indicated on Drawings.
 6. Expansion (Control) Joint: Install control joints at locations indicated on Drawings.
- D. Joint Treatment Materials for Interior Gypsum Board: Treat joints, interior angles, edge trim, control joints, penetrations, fastener heads, surface defects, and elsewhere as required to prepare panel surfaces for decoration. Promptly remove residual joint compound from adjacent surfaces.
1. Prefill open joints and damaged surface areas.
 2. Apply joint tape over panel joints, except for trim products specifically indicated as not intended to receive tape.
- E. Finish interior gypsum board panels to comply with levels indicated below and in accordance with ASTM C840:
1. Level 1: Ceiling plenum areas, concealed areas, and where indicated on Drawings.
 2. Level 2: Where indicated on Drawings.
 3. Level 3: Where indicated on Drawings.
 - a. Primer and its application to surfaces are specified in Section 099123 "Interior Painting."
 4. Level 4: At panel surfaces that will be exposed to view unless otherwise indicated.
 - a. Primer and its application to surfaces are specified in Section 099123 "Interior Painting."

3.4 PROTECTION

- A. Protect adjacent surfaces from joint compound and promptly remove from floors and other non-gypsum board surfaces. Repair surfaces stained, marred, or otherwise damaged during gypsum board installation and finishing.
- B. Protect installed products from damage from weather, condensation, direct sunlight, construction, and other causes during remainder of the construction period.
- C. Remove and replace panels that have gotten wet, moisture damaged, or mold damaged.
 1. Indications that panels are wet or moisture damaged include, but are not limited to, discoloration, sagging, or irregular shape.
 2. Indications that panels are mold damaged include, but are not limited to,

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

fuzzy or splotchy surface contamination and discoloration.

END OF SECTION 09 29 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 09 51 23 - ACOUSTICAL TILE CEILINGS

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. Acoustical tiles.
 2. Metal suspension system.
 3. Metal edge moldings and trim.

1.2 ACTION SUBMITTALS

- A. Product Data:
1. For each type of product.
- B. Samples: For each exposed product and for each color and texture specified, 6 inches in size.

1.3 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
1. Acoustical Ceiling Units: Full-size tiles equal to 4 percent of quantity installed.
 2. Suspension-System Components: Quantity of each concealed grid and exposed component equal to 1 percent of quantity installed.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Deliver acoustical tiles, suspension-system components, and accessories to Project site and store them in a fully enclosed, conditioned space where they will be protected against damage from moisture, humidity, temperature extremes, direct sunlight, surface contamination, and other causes.
- B. Before installing acoustical tiles, permit them to reach room temperature and a stabilized moisture content.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1.5 FIELD CONDITIONS

- A. Environmental Limitations: Do not install acoustical tile ceilings until spaces are enclosed and weathertight, wet-work in spaces is complete and dry, work above ceilings is complete, and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.
 - 1. Pressurized Plenums: Operate ventilation system for not less than 48 hours before beginning acoustical tile ceiling installation.

PART 2 - PRODUCTS

2.1 SOURCE LIMITATIONS

- A. Source Limitations for Suspended Acoustical Tile Ceiling System: Obtain each type of acoustical ceiling tile and its suspension system from single source from single manufacturer.

2.2 PERFORMANCE REQUIREMENTS

- A. Surface-Burning Characteristics: Comply with ASTM E84; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 - 1. Flame-Spread Index: Class A in accordance with ASTM E1264.
 - 2. Smoke-Developed Index: 50 or less.

2.3 ACOUSTICAL TILES

- A. Acoustical Tiles:
 - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Armstrong World Industries
 - b. CertainTeed; SAINT-GOBAIN
 - c. USG Corporation
 - 2. Acoustical Tile Standard: Provide manufacturer's standard tiles of configuration indicated that comply with ASTM E1264 classifications as designated by type, form, pattern, acoustical rating, and light reflectance unless otherwise indicated.
 - 3. Classification: Provide tiles as follows:
 - a. Type and Form, Type III: Mineral base with painted finish; Form 1,

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- nodular.
- b. Pattern: CD (perforated, small holes and fissured).
- 4. Color: White.
- 5. Light Reflectance (LR): Not less than 0.70.
- 6. Ceiling Attenuation Class (CAC): Not less than 25.
- 7. Noise Reduction Coefficient (NRC): Not less than 0.55.
- 8. Edge/Joint Detail: Square, kerfed, and rabbeted; tongue and grooved; or butt.
- 9. Thickness: As indicated on Drawings.
- 10. Modular Size: As indicated on Drawings.
- 11. Antimicrobial Treatment: Manufacturer's standard broad spectrum, antimicrobial formulation that inhibits fungus, mold, mildew, and gram-positive and gram-negative bacteria and showing no mold, mildew, or bacterial growth when tested in accordance with ASTM D3273, ASTM D3274, or ASTM G21 and evaluated in accordance with ASTM D3274 or ASTM G21.

2.4 METAL SUSPENSION SYSTEM

- A. Concealed or Semi-Exposed Metal Suspension System:
 - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Armstrong World Industries
 - b. CertainTeed; SAINT-GOBAIN
 - c. USG Corporation
 - 2. Metal Suspension-System Standard: Provide manufacturer's standard, direct-hung, fully concealed, metal suspension system and accessories of type, structural classification, and finish indicated that complies with applicable requirements in ASTM C635/C635M.
 - a. High-Humidity Finish: Where indicated, provide coating tested and classified for "severe environment performance" in accordance with ASTM C635/C635M.

2.5 ACCESSORIES

- A. Attachment Devices: Size for five times the design load indicated in ASTM C635/C635M, Table 1, "Direct Hung," unless otherwise indicated. Comply with seismic design requirements.
- B. Wire Hangers, Braces, and Ties: Provide wires as follows:
 - 1. Zinc-Coated, Carbon-Steel Wire: ASTM A641/A641M, Class 1 zinc coating,

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- soft temper.
 - 2. Stainless Steel Wire: ASTM A580/A580M, Type 304, nonmagnetic.
 - 3. Size: Wire diameter sufficient for its stress at three times hanger design load (ASTM C635/C635M, Table 1, "Direct Hung).
- C. Hanger Rods: Mild steel, zinc coated or protected with rust-inhibitive paint.
- D. Flat Hangers: Mild steel, zinc coated or protected with rust-inhibitive paint.
- E. Angle Hangers: Angles with legs not less than 7/8 inch wide; formed with 0.04-inch-thick, galvanized-steel sheet complying with ASTM A653/A653M, G90 coating designation; with bolted connections and 5/16-inch-diameter bolts.

2.6 METAL EDGE MOLDINGS AND TRIM

- A. Metal Edge Moldings and Trim:
- 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. CertainTeed; SAINT-GOBAIN
 - b. USG Corporation
 - 2. Roll-Formed, Sheet-Metal Edge Moldings and Trim: Type and profile indicated or, if not indicated, manufacturer's standard moldings for edges and penetrations complying with seismic design requirements; formed from sheet metal of same material, finish, and color as that used for of suspension-system runners.
 - a. Edge moldings to fit acoustical panel edge details and suspension systems indicated and match width and configuration of exposed runners unless otherwise indicated.
 - b. Finish: Painted to match color indicated by manufacturer's designation.
 - 3. Extruded-Aluminum Edge Moldings and Trim: Where indicated, provide manufacturer's extruded-aluminum edge moldings and trim of profile indicated or referenced by manufacturer's designations, including splice plates, corner pieces, and attachment and other clips, complying with seismic design requirements.
 - a. Baked-Enamel or Powder-Coat Finish: Minimum dry film thickness of 1.5 mils. Comply with ASTM C635/C635M and coating manufacturer's written instructions for cleaning, conversion coating, and applying and baking finish.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

2.7 ACOUSTICAL SEALANT

- A. Acoustical Sealant: As specified in Section 079219 "Acoustical Joint Sealants."

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, including structural framing and substrates to which acoustical tile ceilings attach or abut, with Installer present, for compliance with requirements specified in this and other Sections that affect ceiling installation and anchorage and for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine acoustical tiles before installation. Reject acoustical tiles that are wet, moisture damaged, or mold damaged.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Testing Substrates: Before adhesively bonding tiles to wet-placed substrates such as cast-in-place concrete or plaster, test and verify that moisture level is below tile manufacturer's recommended limits.
- B. Measure each ceiling area and establish layout of acoustical tiles to balance border widths at opposite edges of each ceiling. Avoid using less-than-half-width tiles at borders unless otherwise indicated, and comply with layout shown on reflected ceiling plans.
- C. Layout openings for penetrations centered on the penetrating items.

3.3 INSTALLATION OF SUSPENDED ACOUSTICAL TILE CEILINGS

- A. Install suspended acoustical tile ceilings in accordance with ASTM C636/C636M and manufacturer's written instructions.
 - 1. Fire-Rated Assembly: Install fire-rated ceiling systems in accordance with tested fire-rated design.
- B. Suspend ceiling hangers from building's structural members and as follows:
 - 1. Install hangers plumb and free from contact with insulation or other objects within ceiling plenum that are not part of supporting structure or of ceiling suspension system.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

2. Splay hangers only where required to miss obstructions; offset resulting horizontal forces by bracing, countersplaying, or other equally effective means.
 3. Where width of ducts and other construction within ceiling plenum produces hanger spacings that interfere with location of hangers at spacings required to support standard suspension-system members, install supplemental suspension members and hangers in form of trapezes or equivalent devices.
 4. Secure wire hangers to ceiling suspension members and to supports above with a minimum of three tight turns. Connect hangers directly to structure or to inserts, eye screws, or other devices that are secure and appropriate for substrate and that will not deteriorate or otherwise fail due to age, corrosion, or elevated temperatures.
 5. Secure flat, angle, channel, and rod hangers to structure, including intermediate framing members, by attaching to inserts, eye screws, or other devices that are secure and appropriate for both the structure to which hangers are attached and the type of hanger involved. Install hangers in a manner that will not cause them to deteriorate or fail due to age, corrosion, or elevated temperatures.
 6. Do not attach hangers to steel roof deck. Attach hangers to structural members.
 7. Space hangers not more than 48 inches o.c. along each member supported directly from hangers unless otherwise indicated; provide hangers not more than 8 inches from ends of each member.
 8. Size supplemental suspension members and hangers to support ceiling loads within performance limits established by referenced standards.
- C. Secure bracing wires to ceiling suspension members and to supports with a minimum of four tight turns. Suspend bracing from building's structural members as required for hangers without attaching to permanent metal forms, steel deck, or steel deck tabs. Fasten bracing wires into concrete with cast-in-place or postinstalled anchors.
- D. Install edge moldings and trim of type indicated at perimeter of acoustical ceiling area and where necessary to conceal edges of acoustical tiles.
1. Apply acoustical sealant in a continuous ribbon concealed on back of vertical legs of moldings before they are installed.
 2. Screw attach moldings to substrate at intervals not more than 16 inches o.c. and not more than 3 inches from ends. Miter corners accurately and connect securely.
 3. Do not use exposed fasteners, including pop rivets, on moldings and trim.
- E. Install suspension-system runners so they are square and securely interlocked with one another. Remove and replace dented, bent, or kinked members.
- F. Arrange directionally patterned acoustical tiles as follows:
1. As indicated on reflected ceiling plans.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3.4 ERECTION TOLERANCES

- A. Suspended Ceilings: Install main and cross runners level to a tolerance of 1/8 inch in 12 feet non-cumulative.
- B. Moldings and Trim: Install moldings and trim to substrate and level with ceiling suspension system to a tolerance of 1/8 inch in 12 feet non-cumulative.

3.5 FIELD QUALITY CONTROL

- A. Acoustical tile ceiling hangers, anchors, and fasteners will be considered defective if they do not pass tests and inspections.
- B. Prepare test and inspection reports.

3.6 ADJUSTING

- A. Clean exposed surfaces of acoustical tile ceilings, including trim and edge moldings. Comply with manufacturer's written instructions for cleaning and touchup of minor finish damage.
- B. Remove and replace tiles and other ceiling components that cannot be successfully cleaned and repaired to permanently eliminate evidence of damage.

END OF SECTION 09 51 23

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 09 65 13 - RESILIENT BASE AND ACCESSORIES

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Vinyl base.
2. Rubber molding accessories.
3. Vinyl molding accessories.

B. Related Requirements:

1. Section 024119 "Selective Demolition" for removing existing floor coverings.
2. Section 096813 "Tile Carpeting" for modular carpet tile flooring.

1.2 ACTION SUBMITTALS

A. Product Data: For each type of specified product.

1. Include manufacturer's written data on physical characteristics, durability, and fade resistance.
2. Include manufacturer's written installation instructions for each type of substrate.

B. Samples: For each exposed product and for each color and texture specified, not less than 12 inches long.

C. Product Schedule: For resilient base and accessory products. Use same designations indicated on Drawings.

1.3 DELIVERY, STORAGE, AND HANDLING

A. Store resilient products and installation materials in dry spaces protected from the weather, with ambient temperatures maintained within range recommended by manufacturer, but not less than 50 deg F or more than 90 deg F.

1.4 FIELD CONDITIONS

A. Installation Temperature Requirements: Maintain ambient temperatures within range recommended by manufacturer, but not less than 70 deg F or more than 95 deg F, in spaces to receive resilient products during the following periods:

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1. 48 hours before installation.
 2. During installation.
 3. 48 hours after installation.
- B. Post-Installation Temperature Requirements: After installation and until Substantial Completion, maintain ambient temperatures within range recommended by manufacturer, but not less than 55 deg For more than 95 deg F.
- C. Install resilient products after other finishing operations, including painting, have been completed.

PART 2 - PRODUCTS

2.1 RESILIENT BASE

- A. Vinyl Base:
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Flexco Corporation
 - b. Mannington Mills, Inc
 - c. Mohawk Group
 - d. Tarkett USA
 2. Classification: ASTM F1861, Type TV (vinyl, thermoplastic), Group I (solid, homogeneous) or II (layered).
 3. Style and Location:
 - a. Style A, Straight: Provide in areas with carpet.
 - b. Style B, Cove: Provide in areas with resilient floor coverings.
 4. Minimum Thickness: 0.125 inch.
 5. Height: As indicated on Drawings.
 6. Lengths: Coils in manufacturer's standard length.
 7. Outside Corners: Preformed.
 8. Inside Corners: Job formed.
 9. Colors and Patterns: As indicated by manufacturer's designations.

2.2 RESILIENT MOLDING ACCESSORIES

- A. Rubber Molding Accessories :
1. Accessory Description: carpet edge for glue-down applications nosing for carpet nosing for resilient floor covering joiner for tile and carpet.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

2. Profile and Dimensions: As indicated on Drawings.
- B. Vinyl Molding Accessories :
1. Accessory Description: nosing for carpet, nosing for resilient floor covering.
 2. Profile and Dimensions: as indicated on Drawings.
- C. Locations: Provide resilient molding accessories in areas indicated on Drawings.
- D. Colors and Patterns: Match Architect's sample.

2.3 INSTALLATION MATERIALS

- A. Trowelable Leveling and Patching Compounds: Latex-modified, portland-cement-based or blended hydraulic-cement-based formulation provided or approved by resilient-product manufacturer for applications indicated.
- B. Adhesives: Water-resistant type recommended in writing by resilient-product manufacturer for resilient products and substrate conditions indicated.

PART 3 - EXECUTION

- A. Examine substrates, with Installer present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.
1. Installation of resilient products indicates acceptance of surfaces and conditions.

3.2 PREPARATION

- A. Prepare substrates in accordance with manufacturer's written instructions to ensure adhesion of resilient products.
- B. Fill cracks, holes, and depressions in substrates with trowelable leveling and patching compound; remove bumps and ridges to produce a uniform and smooth substrate.
- C. Do not install resilient products until materials are the same temperature as space where they are to be installed.
1. At least 48 hours in advance of installation, move resilient products and installation materials into spaces where they will be installed.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- D. Immediately before installation, sweep and vacuum clean substrates to be covered by resilient products.

3.3 INSTALLATION OF RESILIENT BASE

- A. Comply with manufacturer's written instructions for installing resilient base.
- B. Apply resilient base to walls, columns, pilasters, casework and cabinets in toe spaces, and other permanent fixtures in rooms and areas where base is required.
- C. Install resilient base in lengths as long as practical without gaps at seams and with tops of adjacent pieces aligned.
- D. Tightly adhere resilient base to substrate throughout length of each piece, with base in continuous contact with horizontal and vertical substrates.
- E. Do not stretch resilient base during installation.
- F. On masonry surfaces or other similar irregular substrates, fill voids along top edge of resilient base with manufacturer's recommended adhesive filler material.
- G. Preformed Corners: Install preformed corners before installing straight pieces.
- H. Job-Formed Corners:
 - 1. Inside Corners: Use straight pieces of maximum lengths possible and form with returns not less than 6 inches in length.
 - a. Miter or cope corners to minimize open joints.

3.4 INSTALLATION OF RESILIENT MOLDING ACCESSORIES

- A. Comply with manufacturer's written instructions for installing resilient molding accessories.
- B. Butt resilient molding accessories to adjacent materials and tightly adhere to substrates throughout length of each piece. Install reducer strips at edges of floor covering that would otherwise be exposed.

3.5 CLEANING

- A. Comply with manufacturer's written instructions for cleaning resilient products.
- B. Perform the following operations immediately after completing resilient-product installation:

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1. Remove adhesive and other blemishes from surfaces.
2. Sweep and vacuum horizontal surfaces thoroughly.
3. Damp-mop horizontal surfaces to remove marks and soil.

3.6 PROTECTION

- A. Comply with manufacturer's written instructions for protecting resilient products.
- B. After post-installation cleaning, immediately protect resilient products from marks, marks, indentations, and other damage from construction operations and placement of equipment and fixtures during remainder of construction period.
- C. Cover resilient products subject to wear and foot traffic until Substantial Completion.

END OF SECTION 09 65 13

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 09 68 13 - TILE CARPETING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Carpet tiles.
- B. Related Requirements:
 - 1. Section 024119 "Selective Demolition" for removing existing floor coverings.
 - 2. Section 096513 "Resilient Base and Accessories" for resilient wall base and accessories installed with carpet tile.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of specified product.
 - 1. Include manufacturer's written data on physical characteristics, durability, and fade resistance.
 - 2. Include manufacturer's written installation recommendations for each type of substrate.
- B. Shop Drawings: For carpet tile installation, showing the following:
 - 1. Carpet tile type, color, and dye lot.
 - 2. Type of subfloor.
 - 3. Type of installation.
 - 4. Pattern of installation.
 - 5. Pattern type, location, and direction.
 - 6. Pile direction.
 - 7. Type, color, and location of insets and borders.
 - 8. Type, color, and location of edge, transition, and other accessory strips.
 - 9. Transition details to other flooring materials.
- C. Samples for Initial Selection: Manufacturer's standard color sheets, showing full range of available colors for each type of carpet tile.
 - 1. Include Samples of exposed edge, transition, and other accessory stripping involving color or finish selection.
- D. Product Schedule: For carpet tile. Use same designations indicated on Drawings.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1.3 CLOSEOUT SUBMITTALS

- A. Maintenance Data: For carpet tiles. Include the following:
 - 1. Methods for maintaining carpet tile, including cleaning and stain-removal products and procedures and manufacturer's recommended maintenance schedule.
 - 2. Precautions for cleaning materials and methods that could be detrimental to carpet tile.

1.4 MAINTENANCE MATERIAL SUBMITTALS

- A. Extra Stock Material: Furnish extra materials, from the same production run, to Owner that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Carpet Tile: Full-size units equal to 2 percent of amount installed for each type indicated, but no fewer than 10 full-size units.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Comply with CRI 104.

1.6 FIELD CONDITIONS

- A. Comply with CRI 104 for temperature, humidity, and ventilation limitations.
- B. Environmental Limitations: Do not deliver or install carpet tiles until spaces are enclosed and weathertight, wet-work in spaces is complete and dry, and ambient temperature and humidity conditions are maintained at levels planned for building occupants during the remainder of the construction period.
- C. Do not install carpet tiles over concrete slabs until slabs have cured and are sufficiently dry to bond with adhesive and concrete slabs have pH range recommended in writing by carpet tile manufacturer.
- D. Where demountable partitions or other items are indicated for installation on top of carpet tiles, install carpet tiles before installing these items.

1.7 WARRANTY

- A. Special Warranty for Carpet Tiles: Manufacturer agrees to repair or replace components of carpet tile installation that fail in materials or workmanship within specified warranty period.
 - 1. Warranty does not include deterioration or failure of carpet tile due to

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- unusual traffic, failure of substrate, vandalism, or abuse.
2. Failures include, but are not limited to, the following:
 - a. More than 10 percent loss of face fiber, edge raveling, snags, and runs.
 - b. Loss of tuft-bind strength.
 - c. Excess static discharge.
 - d. Delamination.
 - e. Dimensional instability.
 3. Warranty Period: 2 years from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 CARPET TILES

- A. Carpet Tile:
 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Mannington Commercial; a business unit of Mannington Mills, Inc.
 - b. Mohawk Group
 - c. Tarkett USA
 2. Color: See Drawings..

2.2 ACCESSORIES

- A. Trowelable Leveling and Patching Compounds: Latex-modified, hydraulic-cement-based formulation provided or recommended in writing by carpet tile manufacturer.
- B. Adhesives: Water-resistant, mildew-resistant, nonstaining, pressure-sensitive types to suit products and subfloor conditions indicated, that comply with flammability requirements for installed carpet tile, and that are recommended in writing by carpet tile manufacturer for releasable installation.
- C. Metal Edge/Transition Strips: Extruded aluminum with [mill]<Insert finish> finish of profile and width shown, of height required to protect exposed edge of carpet, and of maximum lengths to minimize running joints.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for maximum moisture content, alkalinity range, installation tolerances, and other conditions affecting carpet tile performance.
- B. Examine carpet tile for type, color, pattern, and potential defects.
- C. Concrete Slabs: Verify that finishes comply with requirements specified in Section 033000 "Cast-in-Place Concrete" and that surfaces are free of cracks, ridges, depressions, scale, and foreign deposits.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. General: Comply with CRI 104 and with carpet tile manufacturer's written installation instructions for preparing substrates.
- B. Trowelable Leveling and Patching Compounds: Use trowelable leveling and patching compounds in accordance with manufacturer's written instructions, to fill cracks, holes, depressions, and protrusions in substrates. Fill or level cracks, holes and depressions 1/8 inch wide or wider, and protrusions more than 1/32 inch unless more stringent requirements are required by manufacturer's written instructions.
- C. Concrete Substrates: Remove coatings, including curing compounds, and other substances that are incompatible with adhesives and that contain soap, wax, oil, or silicone, without using solvents. Use mechanical methods recommended in writing by adhesive and carpet tile manufacturers.
- D. Broom and vacuum clean substrates to be covered immediately before installing carpet tile.

3.3 INSTALLATION OF CARPET TILES

- A. General: Comply with CRI 104, Section 10, "Carpet Tile," and with carpet tile manufacturer's written installation instructions.
- B. Installation Method: Glue down; install every tile with full-spread, releasable, pressure-sensitive adhesive.
- C. Maintain dye-lot integrity. Do not mix dye lots in same area.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- D. Maintain pile-direction patterns indicated on Drawings.
- E. Cut and fit carpet tile to butt tightly to vertical surfaces, permanent fixtures, and built-in furniture including cabinets, pipes, outlets, edgings, thresholds, and nosings. Bind or seal cut edges as recommended in writing by carpet tile manufacturer.
- F. Extend carpet tile into toe spaces, door reveals, closets, open-bottomed obstructions, removable flanges, alcoves, and similar openings.

3.4 CLEANING

- A. Perform cleaning operations immediately after installing carpet tile as follows:
 - 1. Remove excess adhesive and other surface blemishes using cleaner recommended in writing by carpet tile manufacturer.
 - 2. Remove yarns that protrude from carpet tile surface.
 - 3. Vacuum carpet tile using commercial machine with face-beater element.

3.5 PROTECTION

- A. Protect installed carpet tile to comply with CRI 104, Section 13.7.
- B. Protect carpet tile against damage from construction operations and placement of equipment and fixtures during the remainder of construction period. Use protection methods indicated or recommended in writing by carpet tile manufacturer.

END OF SECTION 09 68 13

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 09 91 23 - INTERIOR PAINTING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes: Surface preparation of interior substrates and application of the following:
 - 1. Primers.
 - 2. Water-based finish coatings.
 - 3. Solvent-based finish coatings.
 - 4. Floor sealers and paints.
 - 5. Dry fall coatings.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.
 - 1. Include preparation requirements and application instructions.
 - 2. Indicate VOC content.
- B. Samples: For each type of topcoat product.
- C. Samples for Initial Selection: For each type of topcoat product.
 - 1. Submit Samples on rigid backing, 8 inches square.
 - 2. Apply coats on Samples in steps to show each coat required for system.
 - 3. Label each coat of each Sample.
 - 4. Label each Sample for location and application area.
- D. Product List: Cross-reference to paint system and locations of application areas. Use same designations indicated on Drawings and in applicable interior painting schedule articles to cross-reference paint systems specified in this Section. Include color designations.

1.3 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match paint products applied and that are packaged with protective covering for storage and identified with labels describing contents.
 - 1. Paint Products: 5 percent, but not less than 1 gal. of each material and color applied.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Store materials not in use in tightly covered containers in well-ventilated areas with ambient temperatures continuously maintained at not less than 45 deg F.
 - 1. Maintain containers in clean condition, free of foreign materials and residue.
 - 2. Remove rags and waste from storage areas daily.

1.5 FIELD CONDITIONS

- A. Apply paints only when temperature of surfaces to be painted and ambient air temperatures are between 50 and 95 deg F.
- B. Do not apply paints when relative humidity exceeds 85 percent; at temperatures of less than 5 deg F above the dew point; or to damp or wet surfaces.

PART 2 - PRODUCTS

2.1 SOURCE LIMITATIONS

- A. Obtain each paint product from single source from single manufacturer.

2.2 INTERIOR PAINTS, GENERAL

- A. Interior Paints: Subject to compliance with requirements, listed in product types below and applicable interior painting schedule articles for the paint category indicated.
- B. Material Compatibility:
 - 1. Materials for use within each paint system must be compatible with one another and substrates indicated, under conditions of service and application as demonstrated by manufacturer based on testing and field experience.
 - 2. For each coat in a paint system, provide products recommended in writing by topcoat manufacturer for use in paint system and on substrate indicated.
- C. Colors: As indicated in a color schedule

2.3 PRIMERS

- A. Interior Latex Primer Sealer: Pigmented, water-based latex sealer; formulated to reduce porosity of substrate for finish coats; for use on new interior plaster, concrete, and gypsum board substrates. Not intended for use on wood or

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

previously painted surfaces.

1. Manufacturers: Subject to compliance with requirements available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Behr Paint Company (Behr Process LLC)
 - b. Benjamin Moore & Co.
 - c. Sherwin-Williams Company (The)
 - d. The Pittsburgh Paints Company

- B. Interior Alkyd Primer Sealer: Solvent-based, alkyd-type, primer/sealer for new interior wood, plaster, and porous surfaces.
 1. Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Behr Paint Company (Behr Process LLC)
 - b. Benjamin Moore & Co.
 - c. Sherwin-Williams Company (The)
 - d. The Pittsburgh Paints Company

2.4 WATER-BASED FINISH COATINGS

- A. Interior Latex Paint: Pigmented, water-based coating for use on interior primed/sealed plaster and gypsum board, and on primed wood.
 1. Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Behr Paint Company (Behr Process LLC)
 - b. Benjamin Moore & Co.
 - c. Sherwin-Williams Company (The)
 - d. The Pittsburgh Paints Company

 2. Gloss and Sheen Level: Manufacturer's standard eggshell.

2.5 SOLVENT-BASED FINISH COATINGS

- A. Interior Alkyd Paint: Pigmented, solvent-based alkyd coating for use on primed/sealed interior metal substrates primarily in moderate traffic commercial environments.
 1. Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- a. Behr Paint Company (Behr Process LLC)
 - b. Benjamin Moore & Co.
 - c. Sherwin-Williams Company (The)
 - d. The Pittsburgh Paints Company
2. Gloss and Sheen Level: Manufacturer's standard Semigloss

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions, with Applicator present, for compliance with requirements for maximum moisture content and other conditions affecting performance of the Work.
- B. Maximum Moisture Content of Substrates: When measured with an electronic moisture meter as follows:
 1. Concrete: 12 percent.
 2. Cementitious Composition Board: 12 percent.
 3. Masonry (Clay and CMU): 12 percent.
 4. Wood: 15 percent.
 5. Gypsum Board: 12 percent. Verify that finishing compound is dry and sanded smooth.
 6. Plaster: 12 percent. Verify that plaster is fully cured.
- C. Verify suitability of substrates, including surface conditions and compatibility, with finishes and primers. Proceed with coating application only after unsatisfactory conditions have been corrected.
 1. Application of coating indicates acceptance of surfaces and conditions.

3.2 PREPARATION

- A. Comply with manufacturer's written instructions applicable to substrates and paint systems indicated.
- B. Remove hardware, covers, plates, and similar items already in place that are removable and are not to be painted. If removal is impractical or impossible because of size or weight of item, provide surface-applied protection before surface preparation and painting.
 1. After completing painting operations, use workers skilled in the trades involved to reinstall items that were removed. Remove surface-applied protection if any.
- C. Clean substrates of substances that could impair bond of paints, including dust,

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

dirt, oil, grease, and incompatible paints and encapsulants.

1. Remove incompatible primers and reprime substrate with compatible primers or apply tie coat as required to produce paint systems indicated.
- D. Wood Substrates:
1. Scrape and clean knots. Before applying primer, apply coat of wood-knot sealer.
 2. Sand surfaces that will be exposed to view and remove sanding dust.
 3. Prime edges, ends, faces, undersides, and backsides of wood.
 4. After priming, fill holes and imperfections in the finish surfaces with putty or plastic wood filler. Sand smooth when dried.

3.3 APPLICATION OF INTERIOR PAINT PRODUCTS

- A. Apply paints in accordance with manufacturer's written instructions.
1. Use applicators and techniques suited for paint and substrate indicated.
 2. Paint surfaces behind movable equipment and furniture same as similar exposed surfaces. Before final installation, paint surfaces behind permanently fixed equipment or furniture with prime coat only.
 3. Paint front and backsides of access panels, removable or hinged covers, and similar hinged items to match exposed surfaces.
 4. Paint entire exposed surface of window frames and sashes.
 5. Do not paint over labels of independent testing agencies or equipment name, identification, performance rating, or nomenclature plates.
 6. Primers specified in the applicable interior painting schedule articles may be omitted on items that are factory primed or factory finished if compatible with intermediate and topcoat coatings and acceptable to intermediate and topcoat paint manufacturers.
- B. Tint each undercoat a lighter shade to facilitate identification of each coat if multiple coats of same material are to be applied. Tint undercoats to match color of topcoat but provide sufficient difference in shade of undercoats to distinguish each separate coat.
- C. If undercoats or other conditions show through topcoat, apply additional coats until cured film has a uniform paint finish, color, and appearance.
- D. Apply paints to produce surface films without cloudiness, spotting, holidays, laps, brush marks, roller tracking, runs, sags, ropiness, or other surface imperfections. Cut in sharp lines and color breaks.
- E. Painting Fire-Suppression, Plumbing, HVAC, Electrical, Communication, and Electronic Safety and Security Work:
1. Paint portions of internal surfaces of metal ducts, without liner, behind air inlets and outlets that are visible from occupied spaces.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3.4 FIELD QUALITY CONTROL

- A. Dry-Film Thickness Testing: Owner may engage the services of a qualified testing and inspecting agency to inspect and test paint for dry-film thickness.
 - 1. Touch up and restore painted surfaces damaged by testing.
 - 2. If test results show that dry-film thickness of applied paint does not comply with paint manufacturer's written recommendations, apply additional coats as needed to provide dry-film thickness that complies with paint manufacturer's written recommendations.
 - 3. Cost of retesting is Contractor's responsibility.

3.5 CLEANING

- A. At end of each workday, remove rubbish, empty cans, rags, and other discarded materials from Project site.
 - 1. Do not clean equipment with free-draining water and prevent solvents, thinners, cleaners, and other contaminants from entering into waterways, sanitary and storm drain systems, and ground.
 - 2. Dispose of contaminants in accordance with requirements of authorities having jurisdiction.
 - 3. Allow empty paint cans to dry before disposal.
 - 4. Collect waste paint by type and deliver to recycling or collection facility.
- B. After completing paint application, clean spattered surfaces. Remove spattered paints by washing, scraping, or other methods. Do not scratch or damage adjacent finished surfaces.

3.6 PROTECTION

- A. Protect work of other trades against damage from paint application. Correct damage to work of other trades by cleaning, repairing, replacing, and refinishing, as approved by Architect, and leave in an undamaged condition.
- B. At completion of construction activities of other trades, touch up and restore damaged or defaced painted surfaces.

3.7 INTERIOR PAINTING SCHEDULE, WOOD SUBSTRATES

- A. Glued-Laminated Wood Substrates:
 - 1. Latex over Latex Primer System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex paint.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- 1) Gloss and Sheen Level: Semigloss
2. Latex over Alkyd Primer System:
 - a. Prime Coat: Interior alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex paint.
 - 1) Gloss and Sheen Level: Semigloss
3. Institutional Low-Odor/VOC Latex System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, latex, institutional low-odor/VOC paint.
 - 1) Gloss and Sheen Level: Semigloss
4. High-Performance Architectural Latex System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, high-performance architectural latex.
 - 1) Gloss and Sheen Level: Semigloss
5. Antiviral/Antibacterial Latex System:
 - a. Prime Coat: Interior alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex, antiviral/antibacterial coating.
 - 1) Gloss and Sheen Level: Semigloss].
6. Alkyd System:
 - a. Prime Coat: Interior alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior alkyd paint.
 - 1) Gloss and Sheen Level: Semigloss
7. Water-Based Alkyd System:
 - a. Prime Coat: Interior alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, water-based alkyd paint.
 - 1) Gloss and Sheen Level: Semigloss

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- B. Exposed Wood Framed Substrates:
1. Latex over Latex Primer System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex paint.
 - 1) Gloss and Sheen Level: Semigloss
 2. Latex over Alkyd Primer System:
 - a. Prime Coat: Interior alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex paint.
 - 1) Gloss and Sheen Level: Semigloss.
 3. Institutional Low-Odor/VOC Latex System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, latex, institutional low-odor/VOC paint.
 - 1) Gloss and Sheen Level: Semigloss
 4. High-Performance Architectural Latex System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, high-performance architectural latex.
 - 1) Gloss and Sheen Level: Semigloss
 5. Antiviral/Antibacterial Latex System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex, antiviral/antibacterial coating.
 - 1) Gloss and Sheen Level: Semigloss.
 6. Alkyd System:
 - a. Prime Coat: Interior alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior alkyd paint.
 - 1) Gloss and Sheen Level: Semigloss.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- 7. Water-Based Alkyd System:
 - a. Prime Coat: Interior alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, water-based alkyd paint.
 - 1) Gloss and Sheen Level: Semigloss.

C. Finish Carpentry Substrates:

- 1. Latex over Latex Primer System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex paint.
 - 1) Gloss and Sheen Level: Semigloss.
- 2. Latex over Alkyd Primer System:
 - a. Prime Coat: Interior alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex paint.
 - 1) Gloss and Sheen Level: Semigloss.
- 3. Institutional Low-Odor/VOC Latex System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, latex, institutional low-odor/VOC paint.
 - 1) Gloss and Sheen Level: Semigloss.
- 4. High-Performance Architectural Latex System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, high-performance architectural latex.
 - 1) Gloss and Sheen Level: Semigloss.
- 5. Water-Based Light Industrial Coating System:
 - a. Prime Coat: Interior alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, water-based light industrial coating.
 - 1) Gloss and Sheen Level: Semigloss.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

6. Antiviral/Antibacterial Latex System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex, antiviral/antibacterial coating.
 - 1) Gloss and Sheen Level: Semigloss.

7. Alkyd System:
 - a. Prime Coat: Interior alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior alkyd paint.
 - 1) Gloss and Sheen Level: Semigloss

8. Water-Based Alkyd System:
 - a. Prime Coat: Interior, latex primer for wood.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, water-based alkyd paint.
 - 1) Gloss and Sheen Level: Semigloss.

3.8 INTERIOR PAINTING SCHEDULE, GYPSUM-BASED SUBSTRATES

- A. Gypsum Board and Plaster Substrates:
 1. Latex over Latex Sealer System:
 - a. Prime Coat: Interior latex primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex paint.
 - 1) Gloss and Sheen Level: Semigloss

 2. Latex over Alkyd Primer System (for Plaster Only):
 - a. Prime Coat: Interior alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex paint:
 - 1) Gloss and Sheen Level: Semigloss.

 3. Institutional Low-Odor/VOC Latex System:
 - a. Prime Coat: Interior, institutional low-odor/VOC primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, latex, institutional low-odor/VOC paint.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- 1) Gloss and Sheen Level: Semigloss.
4. High-Performance Architectural Latex System:
 - a. Prime Coat: Interior latex primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, high-performance architectural latex.
 - 1) Gloss and Sheen Level: Semigloss.
5. Water-Based Light Industrial Coating System:
 - a. Prime Coat: Interior latex primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, water-based light industrial coating.
 - 1) Gloss and Sheen Level: Semigloss.
6. Antiviral/Antibacterial Latex System:
 - a. Prime Coat: Interior latex primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior latex, antiviral/antibacterial coating.
 - 1) Gloss and Sheen Level: Semigloss.
7. Alkyd over Latex Sealer System:
 - a. Prime Coat: Water-based alkyd primer sealer
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior alkyd paint.
 - 1) Gloss and Sheen Level: Semigloss
8. Water-Based Alkyd System:
 - a. Prime Coat: Water-based alkyd primer sealer.
 - b. Intermediate Coat: Matching topcoat.
 - c. Topcoat: Interior, water-based alkyd paint.
 - 1) Gloss and Sheen Level: Semigloss

END OF SECTION 09 91 23

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 22 05 00 - COMMON WORK RESULTS FOR PLUMBING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. Alignment guides and anchors.
 2. Grout.
 3. Silicone sealants.
 4. Escutcheons.

1.2 DEFINITIONS

- A. Existing Piping to Remain: Existing piping that is not to be removed and that is not otherwise indicated to be removed, removed and salvaged, or removed and reinstalled.

1.3 ACTION SUBMITTALS

- A. Product Data:
1. For each type of product, excluding motors which are included in Part 1 of the plumbing equipment Sections.
 - a. Include construction details, material descriptions, and dimensions of individual components, and finishes.
 - b. Include operating characteristics and furnished accessories.
- B. Delegated Design Submittals: For each anchor and alignment guide, including analysis data, signed and sealed by the qualified professional engineer responsible for their preparation.
1. Anchor Details: Detail fabrication of each anchor indicated. Show dimensions and methods of assembly and attachment to building structure.
 2. Alignment Guide Details: Detail field assembly and attachment to building structure.

1.4 COORDINATION

- A. Coordinate features of motors, installed units, and accessory devices to be compatible with the following:

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1. Ambient and environmental conditions of installation location.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Domestic water for plumbing piping intended to convey or dispense water for human consumption are to comply with the U.S. Safe Drinking Water Act, with requirements of authorities having jurisdiction, and with NSF 61 and NSF 372, or be certified in compliance with NSF 61 and NSF 372 by an ANSI-accredited third-party certification body, in that the weighted average lead content at wetted surfaces is less than or equal to 0.25 percent.
- B. Compatibility: Provide products suitable for piping service fluids, materials, working pressures, and temperatures.
- C. Capability: Provide products and installations to accommodate maximum axial movement as scheduled or indicated on Drawings.

2.2 EXPANSION FITTINGS AND LOOPS FOR PLUMBING PIPING

- A. Performance Requirements:
 1. Compatibility: Provide products suitable for piping service fluids, materials, working pressures, and temperatures.
- B. Alignment Guides and Anchors:
 1. Anchor Materials:
 - a. Steel Shapes and Plates: ASTM A36/A36M.
 - b. Bolts and Nuts: ASME B18.10 or ASTM A183, steel hex head.
 - c. Washers: ASTM F844, steel, plain, flat washers.
 - d. Mechanical Fasteners: Insert-wedge-type stud with expansion plug anchor for use in hardened portland cement concrete, with tension and shear capacities appropriate for application.
 - 1) Stud: Threaded, zinc-coated carbon steel.
 - 2) Expansion Plug: Zinc-coated carbon steel.
 - 3) Washer and Nut: Zinc-coated carbon steel.

2.3 SLEEVES AND SLEEVE SEALS

- A. Sleeves without Waterstop:
 1. PVC Pipe Sleeves: ASTM D1785, Schedule 40.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

2. Molded-PVC Sleeves: With nailing flange.
 3. Molded-PE or -PP Sleeves: Removable, tapered-cup shaped, and smooth outer surface with nailing flange.
- B. Grout:
1. Description: Nonshrink, for interior and exterior sealing openings in non-fire-rated walls or floors.
 2. Standard: ASTM C1107/C1107M, Grade B, post-hardening and volume-adjusting, dry, hydraulic-cement grout.
 3. Packaging: Premixed and factory packaged.
- C. Silicone Sealants:

2.4 ESCUTCHEONS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
1. BrassCraft Manufacturing Co.; a Masco company
 2. Dearborn Brass
 3. Jones Stephens Corp.
 4. Keeney Manufacturing Company (The)
 5. Mid-America Fittings, LLC; A Midland Industries Company
 6. ProFlo; a Ferguson Enterprises, Inc. brand
- B. Escutcheon Types:
1. One-Piece, Steel Type: With polished, chrome-plated finish and setscrew fastener.
 2. One-Piece, Stainless Steel Type: With polished stainless steel finish.
 3. Split-Plate, Stamped-Steel Type: With polished, chrome-plated finish; concealed hinge; and spring-clip fasteners.

PART 3 - EXECUTION

3.1 INSTALLATION OF EXPANSION JOINTS, GENERAL

- A. Install expansion joints of sizes matching sizes of piping in which they are installed.

3.2 INSTALLATION OF PACKLESS EXPANSION JOINTS

- A. Install metal-bellows expansion joints in accordance with EJMA's "Standards of the Expansion Joint Manufacturers Association, Inc."

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- B. Install rubber packless expansion joints in accordance with FSA-PSJ-703.

3.3 INSTALLATION OF GROOVED-JOINT EXPANSION JOINTS

- A. Install grooved-joint expansion joints to grooved-end steel piping.

3.4 INSTALLATION OF ALIGNMENT GUIDES AND ANCHORS

- A. Install alignment guides to guide expansion and to avoid end-loading and torsional stress.
- B. Install one guide(s) on each side of pipe expansion fittings and loops. Install guides nearest to expansion joint not more than four pipe diameters from expansion joint.
- C. Attach guides to pipe, and secure guides to building structure.
- D. Install anchors at locations to prevent stresses from exceeding those permitted by ASME B31.9 and to prevent transfer of loading and stresses to connected equipment.
- E. Anchor Attachments:
 - 1. Anchor Attachment to Steel Pipe: Attach by welding. Comply with ASME B31.9.
 - 2. Anchor Attachment to Copper Tubing: Attach with pipe hangers. Use MSS SP-58, Type 24; U bolts bolted to anchor.
- F. Fabricate and install steel anchors by welding steel shapes, plates, and bars. Comply with ASME B31.9 and AWS D1.1/D1.1M.
 - 1. Anchor Attachment to Steel Structural Members: Attach by welding.
 - 2. Anchor Attachment to Concrete Structural Members: Attach by fasteners. Follow fastener manufacturer's written instructions.
 - 3. Use grout to form flat bearing surfaces for guides and anchors attached to concrete.

3.5 INSTALLATION OF PIPE LOOP AND SWING CONNECTIONS

- A. Install pipe loops cold-sprung in tension or compression as required to partly absorb tension or compression produced during anticipated change in temperature.
- B. Connect risers and branch connections to mains with at least five pipe fittings, including tee in main.
- C. Connect risers and branch connections to terminal units with at least

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

[four]<Insert number> pipe fittings, including tee in riser.

- D. Connect mains and branch connections to terminal units with at least [four]<Insert number> pipe fittings, including tee in main.

3.6 INSTALLATION OF SLEEVES - GENERAL

- A. Install sleeves for piping passing through penetrations in floors, partitions, roofs, and walls.
- B. For sleeves that will have sleeve-seal system installed, select sleeves of size large enough to provide 1-inch annular clear space between piping and concrete slabs and walls.
1. Sleeves are not required for core-drilled holes.
- C. Install sleeves in concrete floors, concrete roof slabs, and concrete walls as new slabs and walls are constructed.
1. Permanent sleeves are not required for holes in slabs formed by molded-PE or -PP sleeves.
 2. Cut sleeves to length for mounting flush with both surfaces.
 - a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches above finished floor level.
 3. Using sealant, seal the space outside of sleeves in floors/slabs/walls without sleeve-seal system. Select to maintain fire resistance of floor/slab/wall.
- D. Install sleeves for pipes passing through interior partitions.
1. Cut sleeves to length for mounting flush with both surfaces.
 2. Install sleeves that are large enough to provide 1/4-inch annular clear space between sleeve and pipe or pipe insulation.
 3. Seal annular space between sleeve and piping or piping insulation; use joint sealants that joint sealant manufacturer's literature indicates is appropriate for size, depth, and location of joint.
- E. Fire-Resistance-Rated Penetrations, Horizontal Assembly Penetrations, and Smoke Barrier Penetrations: Maintain indicated fire or smoke rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with fire- and smoke-stop materials. Comply with requirements for firestopping and fill materials specified in Section 078413 "Penetration Firestopping."

3.7 INSTALLATION OF SLEEVES WITH WATERSTOP

- A. Install sleeve with waterstop as new walls and slabs are constructed.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- B. Assemble fitting components of length to be flush with both surfaces of concrete slabs and walls. Position waterstop flange centered across width of concrete slab or wall.
- C. Secure nailing flanges to wooden concrete forms.
- D. Using sealant, seal space around outside of sleeves. Select to maintain fire resistance of floor/slab/wall.

3.8 INSTALLATION OF STACK-SLEEVE FITTINGS

- A. Install stack-sleeve fittings in new slabs as slabs are constructed.
 - 1. Install fittings that are large enough to provide 1/4-inch annular clear space between sleeve and pipe or pipe insulation.
 - 2. Secure flashing between clamping flanges for pipes penetrating floors with membrane waterproofing. Comply with requirements for flashing specified in Section 076200 "Sheet Metal Flashing and Trim."
 - 3. Install section of cast-iron soil pipe to extend sleeve to 2 inches above finished floor level.
 - 4. Extend cast-iron sleeve fittings below floor slab as required to secure clamping ring if ring is specified.
 - 5. Using silicone sealant, seal space between top hub of stack-sleeve fitting and pipe.
- B. Fire-Resistance-Rated Penetrations, Horizontal Assembly Penetrations, and Smoke Barrier Penetrations: Maintain indicated fire or smoke rating of floors at pipe penetrations. Seal pipe penetrations with fire- and smoke-stop materials. Comply with requirements for firestopping specified in Section 078413 "Penetration Firestopping."

3.9 INSTALLATION OF SLEEVE-SEAL SYSTEMS

- A. Install sleeve-seal systems in sleeves in exterior concrete walls and slabs-on-grade at service piping entries into building, and passing through exterior walls.
- B. Select type, size, and number of sealing elements required for piping material and size and for sleeve ID or hole size. Assemble sleeve-seal system components, and install in annular space between piping and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make a watertight seal.

3.10 INSTALLATION OF ESCUTCHEONS

- A. Install escutcheons for piping penetrations of walls, ceilings, and finished floors.
- B. Install escutcheons with ID to closely fit around pipe, tube, and insulation of

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

insulated piping and with OD that completely covers opening.

3.11 INSTALLATION OF METERS AND GAUGES

- A. Install thermometer with thermowell at each required thermometer location.
- B. Install thermowells in vertical position in piping tees.
- C. Install thermowells of sizes required to match thermometer connectors. Include bushings if required to match sizes.
- D. Install thermowells with extension on insulated piping.
- E. Fill thermowells with heat-transfer medium.
- F. Install direct-mounted thermometers in thermowells and adjust vertical and tilted positions.
- G. Install remote-mounted thermometer bulbs in thermowells and install cases on panels; connect cases with tubing and support tubing to prevent kinks.
- H. Install direct-mounted pressure gauges in piping tees with pressure gauge located on pipe at most readable position.
- I. Install remote-mounted pressure gauges on panel.
- J. Install valve and snubber in piping for each pressure gauge for fluids.
- K. Install test plugs in piping tees.
- L. Install thermometers in the following locations:
 - 1. Inlet and outlet of each water heater.
 - 2. Inlets and outlets of each domestic water heat exchanger.
 - 3. Inlet and outlet of each domestic hot-water storage tank.
 - 4. Inlet and outlet of each remote domestic water chiller.
 - 5. Outlet side of hot-water-balancing valve.
 - 6. Each main hot-water-recirculating line return pipe.
- M. Install pressure gauges in the following locations:
 - 1. Building water service entrance into building.
 - 2. Inlet and outlet of each pressure-reducing valve.
 - 3. Suction and discharge of each domestic water pump.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3.12 CONNECTIONS

- A. Install meters and gauges adjacent to machines and equipment to allow space for service and maintenance of meters, gauges, machines, and equipment.

3.13 ADJUSTING

- A. After installation, calibrate meters according to manufacturer's written instructions.
- B. Adjust faces of meters and gauges to proper angle for best visibility.

3.14 FIELD QUALITY CONTROL

- A. Sleeves and Sleeve Seals:
 - 1. Perform the following tests and inspections:
 - a. Leak Test: After allowing for a full cure, test sleeves and sleeve seals for leaks. Repair leaks and retest until no leaks exist.
 - b. Sleeves and sleeve seals will be considered defective if they do not pass tests and inspections.
 - 2. Prepare test and inspection reports.
- B. Escutcheons:
 - 1. Using new materials, replace broken and damaged escutcheons and floor plates.

3.15 SLEEVES APPLICATION

- A. Use sleeves and sleeve seals for the following piping-penetration applications:
 - 1. Exterior Concrete Walls above and below Grade:
 - a. Sleeves with waterstops.
 - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.
 - 2. Concrete Slabs-on-Grade:
 - a. Sleeves with waterstops.
 - 1) Select sleeve size to allow for 1-inch annular clear space between piping and sleeve for installing sleeve-seal system.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3. Interior Wall and Partitions:
 - a. Sleeves without waterstops.

3.16 ESCUTCHEONS APPLICATION

A. Escutcheons for New Piping and Relocated Existing Piping:

1. Piping with Fitting or Sleeve Protruding from Wall: One piece, deep pattern.
2. Chrome-Plated Piping: One piece, with polished, chrome-plated finish.
3. Insulated Piping:
 - a. One piece, steel with finish.
 - b. One piece, stainless steel with polished stainless steel finish.
 - c. One piece, cast brass with finish.
 - d. One piece, stamped steel with polished, chrome-plated finish.
4. Bare Piping at Wall and Floor Penetrations in Finished Spaces:
 - a. One piece, steel with finish.
 - b. One piece, stainless steel with polished stainless steel finish.
 - c. One piece, cast brass with finish.
 - d. One piece, stamped with polished, chrome-plated finish.
5. Bare Piping at Ceiling Penetrations in Finished Spaces:
 - a. One piece, steel with finish.
 - b. One piece, stainless steel with polished stainless steel finish.
 - c. One piece, cast brass with finish.
 - d. One piece, stamped steel with polished, chrome-plated finish.
6. Bare Piping in Unfinished Service Spaces:
 - a. One piece, steel with polished, chrome-plated finish.
 - b. One piece, cast brass with finish.
 - c. One piece, stamped steel with polished, chrome-plated finish.
7. Bare Piping in Equipment Rooms:
 - a. One piece, steel with polished, chrome-plated finish.
 - b. One piece, cast brass with finish.
 - c. One piece, stamped with polished, chrome-plated finish.

B. Escutcheons for Existing Piping to Remain:

1. Chrome-Plated Piping: Split casting, stamped steel with] hinge with polished, chrome-plated finish.
2. Insulated Piping: Split plate, stamped steel with hinge with polished, chrome-plated finish

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3. Bare Piping at Wall and Floor Penetrations in Finished Spaces: Split plate, stamped steel with hinge with polished, chrome-plated finish.
 4. Bare Piping at Ceiling Penetrations in Finished Spaces: Split plate, stamped steel with hinge with polished, chrome-plated finish.
 5. Bare Piping in Unfinished Service Spaces: Split plate, stamped steel with hinge with polished, chrome-plated finish.
 6. Bare Piping in Equipment Rooms: Split plate, stamped steel with hinge with polished, chrome-plated finish.
- C. Install floor plates for piping penetrations of equipment-room floors.
- D. Install floor plates with ID to closely fit around pipe, tube, and insulation of piping and with OD that completely covers opening.
1. New Piping and Relocated Existing Piping: One piece, floor plate.
 2. Existing Piping: Split floor plate.

3.17 THERMOMETER, LEAD FREE, APPLICATION

- A. Thermometers at inlet and outlet of each domestic water heater, heat exchanger, storage tank, chiller are to be the following:
1. Sealed bimetallic-actuated type.
 2. Direct-mounted, metal -case, vapor-actuated type.
 3. Metal case, industrial -style, liquid-in-glass type.
 4. Direct -mounted, light-activated type.
 5. Test plug with EPDM self-sealing rubber inserts.
- B. Thermometer stems are to be of length to match thermowell insertion length.

3.18 THERMOMETER, LEAD FREE, SCALE-RANGE APPLICATION

- A. Scale Range for Domestic Cold-Water Piping:
1. 0 to 100 deg F
- B. Scale Range for Domestic Hot-Water Piping:
1. 0 to 250 deg F
- C. Scale Range for Domestic Cooled-Water Piping:
1. 0 to 100 deg F.

3.19 PRESSURE-GAUGE APPLICATION

- A. Pressure gauges at discharge of each water service into building, domestic

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

water pump, at inlet and outlet of each water pressure-reducing valve are to be the following:

1. Liquid filled, direct mounted, metal case.
2. Sealed direct mounted, metal case.
3. Test plug with EPDM self-sealing rubber inserts.

3.20 PRESSURE-GAUGE SCALE-RANGE APPLICATION

A. Scale Range for Water Service Piping:

1. 0 to 100 psi

B. Scale Range for Domestic Water Piping:

1. 0 to 100 psi.

END OF SECTION 22 05 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 22 05 29 - HANGERS AND SUPPORTS FOR PLUMBING PIPING AND EQUIPMENT

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Pipe hangers and supports - metal.
2. Pipe hangers - FRP.
3. Thermal hanger shield inserts.
4. Fastener systems.
5. Equipment supports.

B. Related Requirements:

1. Section 220500 "Common Work Results for Plumbing" for pipe guides and anchors.

1.2 ACTION SUBMITTALS

A. Product Data: For each type of product.

PART 2 - PRODUCTS

2.1 PIPE HANGERS AND SUPPORTS - METAL

A. Pipe/Tube Hangers and Supports - Copper:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Anvil; an ASC Engineered Solution
 - b. Cooper B-line; brand of Eaton, Electrical Sector
 - c. FNW; Ferguson Enterprises, Inc.
2. Description: MSS SP-58, Types 1 through 58, copper-plated-steel, factory-fabricated components.
3. Hanger Rods: Continuous-thread rod, nuts, and washer made of copper-plated steel.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

2.2 PIPE HANGERS - METAL, TRAPEZE TYPE

- A. Description: MSS SP-58, Type 59, shop- or field-fabricated pipe-support assembly, made from structural-carbon-steel shapes, with MSS SP-58 carbon-steel hanger rods, nuts, saddles, and U-bolts.

2.3 THERMAL HANGER SHIELD INSERTS

- A. Thermal Hanger Shield Inserts:
1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. National Pipe Hanger Corporation
 - b. Pipe Shields Inc.
 2. Insulation-Insert Material for Cold Piping: ASTM C591, Type VI, Grade 1 polyisocyanurate with 125 psig minimum compressive strength and vapor barrier.
 3. Insulation-Insert Material for Hot Piping: ASTM C591, Type VI, Grade 1 polyisocyanurate with 125 psig minimum compressive strength.
 4. For Trapeze or Clamped Systems: Insert and shield are to cover entire circumference of pipe.
 5. For Clevis or Band Hangers: Insert and shield are to cover bottom 180 degrees of pipe.
 6. Insert Length: Extend 2 inches beyond sheet metal shield for piping operating below ambient air temperature.

2.4 FASTENER SYSTEMS

- A. Fastener System - Mechanical-Expansion Anchors: Insert-wedge-type anchors, for use in hardened portland cement concrete, with pull-out, tension, and shear capacities required for supported loads and building materials where used.
1. Indoor Applications: stainless steel.
 2. Outdoor Applications: Stainless steel.

2.5 MATERIALS

- A. Aluminum: ASTM B221.
- B. Carbon Steel: ASTM A1011/A1011M.
- C. Structural Steel: ASTM A36/A36M carbon-steel plates, shapes, and bars; black and galvanized.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- D. Stainless Steel: ASTM A240/A240M.
- E. Grout: ASTM C1107/C1107M, factory-mixed and -packaged, dry, hydraulic-cement, nonshrink and nonmetallic grout; suitable for interior and exterior applications.
 - 1. Properties: Nonstaining, noncorrosive, and nongaseous.
 - 2. Design Mix: 5000 psi, 28-day compressive strength.

2.6 INSULATION CLAMPS

- A. Basis-of-Design Product: Subject to compliance with requirements, provide comparable product by one of the following:
 - 1. FNW; Ferguson Enterprises, Inc.:

PART 3 - EXECUTION

3.1 APPLICATION

- A. Strength of Support Assemblies: Where not indicated, select sizes of components, so strength will be adequate to carry present and future static loads within specified loading limits. Minimum static design load used for strength determination is to include weight of supported components plus 100 lb.

3.2 INSTALLATION OF HANGERS AND SUPPORTS

- A. Install hangers and supports to allow controlled thermal and seismic movement of piping systems, to permit freedom of movement between pipe anchors, and to facilitate action of expansion joints, expansion loops, expansion bends, and similar units.
- B. Install lateral bracing with pipe hangers and supports to prevent swaying.
- C. Load Distribution: Install hangers and supports so that piping live and dead loads and stresses from movement will not be transmitted to connected equipment.
- D. Pipe Slopes: Install hangers and supports to provide indicated pipe slopes and to not exceed maximum pipe deflections allowed by ASME B31.9 for building services piping.
- E. Insulated Piping:
 - 1. Attach clamps and spacers to piping.

HANGERS AND SUPPORTS
FOR PLUMBING PIPING
AND EQUIPMENT

a. Piping Operating above Ambient Air Temperature: Clamp may project

22 05 29

3

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- through insulation.
 - b. Piping Operating below Ambient Air Temperature: Use thermal hanger shield insert with clamp sized to match OD of insert.
 - c. Do not exceed pipe stress limits allowed by ASME B31.9 for building services piping.
2. Install MSS SP-58, Type 39, protection saddles if insulation without vapor barrier is indicated. Fill interior voids with insulation that matches adjoining insulation.
 3. Install MSS SP-58, Type 40, protective shields on cold piping with vapor barrier. Shields are to span an arc of 180 degrees.
 4. Shield Dimensions for Pipe: Not less than the following:
 - a. NPS 1/4 to NPS 3-1/2 (DN 8 to DN 90): 12 inches long and 0.048 inch thick.
- F. Metal Pipe-Hanger Installation: Comply with MSS SP-58. Install hangers, supports, clamps, and attachments as required to properly support piping from building structure.
- G. Metal Trapeze Pipe-Hanger Installation: Comply with MSS SP-58. Arrange for grouping of parallel runs of horizontal piping, and support together on field-fabricated trapeze pipe hangers.
- H. Strut System Installation: Metal, rod type; arrange for grouping of parallel runs of piping, and support together on field-assembled strut systems. Install in accordance with manufacturer's written installation instructions.
- I. Thermal Hanger Shield Installation: Install in pipe hanger or shield for insulated piping.
- J. Fastener System Installation:
1. Install mechanical-expansion anchors in concrete after concrete is placed and completely cured. Install fasteners in accordance with manufacturer's written instructions.
 2. Install lag screw wood fasteners in accordance with manufacturer's written instructions.
 3. Install fasteners in accordance with manufacturer's written instructions.
- K. Install hangers and supports complete with necessary attachments, inserts, bolts, rods, nuts, washers, and other accessories.

3.3 ADJUSTING

- A. Hanger Adjustments: Adjust hangers to distribute loads equally on attachments and to achieve indicated slope of pipe.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- B. Trim excess length of continuous-thread hanger and support rods to 1-1/2 inches.

END OF SECTION 22 05 29

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 22 07 19 - PLUMBING PIPING INSULATION

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Glass-fiber pipe insulation.
- B. Related Requirements:
 - 1. Section 220716 "Plumbing Equipment Insulation" for equipment insulation.

1.2 ACTION SUBMITTALS

- A. Product Data: For each specified system and assembly, including components and accessories.
 - 1. Include thermal conductivity, water-vapor permeance thickness, and jackets (both factory and field applied if any).

1.3 QUALITY ASSURANCE

- A. Installer Qualifications: Skilled mechanics who have successfully completed an apprenticeship program or another craft training program

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Packaging: Insulation system materials are to be delivered to the Project site in unopened containers. The packaging is to include name of the manufacturer, fabricator, type, description, and size.

1.5 COORDINATION

- A. Coordinate sizes and locations of supports, hangers, and insulation shields specified in Section 220529 "Hangers and Supports for Plumbing Piping and Equipment."
- B. Coordinate clearance requirements with piping Installer for piping insulation application. Before preparing piping Shop Drawings, establish and maintain clearance requirements for installation of insulation and field-applied jackets and finishes and for space required for maintenance.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1.6 SCHEDULING

- A. Schedule insulation application after pressure testing. Insulation application may begin on segments that have satisfactory test results.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Surface-Burning Characteristics: For insulation and related materials, as determined by testing identical products in accordance with ASTM E84, by a testing agency acceptable to authorities having jurisdiction. Factory label insulation, jacket materials, adhesive, mastic, tapes, and cement material containers with appropriate markings of applicable testing agency.
 - 1. All Insulation Installed Indoors and Outdoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.

2.2 PIPING INSULATION MATERIALS, GENERAL

- A. Products are not to contain asbestos, lead, mercury, or mercury compounds.
- B. Products that come into contact with stainless steel are to have a leachable chloride content of less than 50 ppm when tested in accordance with ASTM C871.

2.3 GLASS-FIBER PIPE INSULATION

- A. Pipe Insulation - Glass-Fiber, Preformed:
 - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Johns Manville; a Berkshire Hathaway company
 - b. Knauf Insulation
 - c. Owens Corning
 - 2. Description: Glass fibers bonded with a thermosetting resin; suitable for maximum use temperature up to 850 deg F in accordance with ASTM C411. Comply with ASTM C547.
 - 3. Preformed Pipe Insulation: Type I, Grade A.
 - 4. Fabricated shapes in accordance with ASTM C450 and ASTM C585.
 - 5. Factory-Applied Insulation Facing:
 - a. ASJ-SSL: ASJ with self-sealing, pressure-sensitive, acrylic-based

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

adhesive covered by a removable protective strip; complying with
ASTM C1136, Type I.

2.4 INSULATION ADHESIVES

- A. Materials are to be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated unless otherwise indicated.

2.5 INSULATION MASTICS AND COATINGS

- A. Materials are to be compatible with insulation materials, jackets, and substrates.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions for compliance with requirements for installation tolerances and other conditions affecting performance of insulation application.
 - 1. Verify that piping to be insulated has been tested and is free of defects.
 - 2. Verify that surfaces to be insulated are clean and dry.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Clean and dry surfaces to receive insulation. Remove materials that will adversely affect insulation application.

3.3 INSTALLATION OF PIPING INSULATION, GENERAL

- A. Requirements in this article apply to all insulation materials, except where more specific requirements are specified in various pipe insulation material installation articles.
- B. Install insulation materials, accessories, and finishes with smooth, straight, and even surfaces; free of voids throughout the length of piping, including fittings, valves, and specialties.
- C. Install insulation materials, forms, vapor barriers or retarders, jackets, and of thicknesses required for each item of pipe system, as specified in insulation

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

system schedules.

- D. Install accessories compatible with insulation materials and suitable for the service. Install accessories that do not corrode, compress, or otherwise damage insulation or jacket.
- E. Install insulation with longitudinal seams at top and bottom (12 o'clock and 6 o'clock positions) of horizontal runs.
- F. Install multiple layers of insulation with longitudinal and end seams staggered.
- G. Keep insulation materials dry during storage, application, and finishing. Replace insulation materials that get wet during storage or in the installation process before being properly covered and sealed in accordance with Contract Documents.
- H. Install insulation with tight longitudinal seams and end joints. Bond seams and joints with adhesive recommended by insulation material manufacturer.
- I. Install insulation with least number of joints practical.
- J. Install insulation with factory-applied jackets as follows:
 - 1. Draw jacket tight and smooth, but not to the extent of creating wrinkles or areas of compression in the insulation.
 - 2. Cover joints and seams with tape, in accordance with insulation material manufacturer's written instructions, to maintain vapor seal.
- K. Cut insulation in a manner to avoid compressing insulation.
- L. Finish installation with systems at operating conditions. Repair joint separations and cracking due to thermal movement.
- M. Repair damaged insulation facings by applying same facing material over damaged areas. Extend patches at least 4 inches] beyond damaged areas. Adhere, staple, and seal patches in similar fashion to butt joints.
- N. For above-ambient services, do not install insulation to the following:
 - 1. Vibration-control devices.
 - 2. Testing agency labels and stamps.
 - 3. Nameplates and data plates.
 - 4. Cleanouts.
- O. Insulate instrument connections for thermometers, pressure gauges, pressure temperature taps, test connections, flow meters, sensors, switches, and transmitters on insulated pipes. Shape insulation at these connections by tapering it to and around the connection with insulating cement and finish with finishing cement, mastic, and flashing sealant.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3.4 PENETRATIONS

- A. Insulation Installation at Interior Wall and Partition Penetrations That Are Not Fire Rated: Install insulation continuously through walls and partitions.

3.5 INSTALLATION OF GLASS-FIBER PIPE INSULATION

- A. Insulation on:
1. Straight Pipes and Tubes:
 - a. For insulation with jackets on below-ambient surfaces, do not staple longitudinal tabs. Instead, secure tabs with additional adhesive, as recommended by insulation material manufacturer, and seal with vapor-barrier mastic and flashing sealant.
 2. Pipe Fittings and Elbows:
 - a. Install prefabricated sections of same material as that of straight segments of pipe insulation when available.
 - b. When prefabricated insulation elbows and fittings are not available, install mitered sections of pipe insulation, to a thickness equal to adjoining pipe insulation. Secure insulation materials with wire or bands.
 3. Valves and Pipe Specialties:
 - a. Install prefabricated sections of same material as that of straight segments of pipe insulation when available.
 - b. When prefabricated sections are not available, install fabricated sections of pipe insulation to valve body.
 - c. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
 - d. Install insulation to flanges as specified for flange insulation application.

3.6 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
- B. All insulation applications will be considered defective if they do not pass tests and inspections.

3.7 INDOOR PIPING INSULATION SCHEDULE

- A. Domestic Cold Water Piping:

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1. Insulation for pipe size NPS 1 (DN 25) and smaller is to be one of the following:
 - a. Pipe Insulation - Glass-Fiber, Preformed: 1 inch thick.
 2. Insulation for pipe size NPS 1-1/4 (DN 32) and larger is to be one of the following:
 - a. Pipe Insulation - Glass-Fiber, Preformed: 1 inch thick.
- B. Domestic Hot and Recirculated Hot Water Piping:**
1. Insulation for pipe size NPS 1-1/4 (DN32) and smaller is to be one of the following:
 - a. Pipe Insulation - Glass-Fiber, Preformed: 1 inch thick.
 2. Insulation for pipe size NPS 1-1/2 (DN 40) and larger is to be one of the following:
 - a. Pipe Insulation - Glass-Fiber, Preformed: 1 inch thick.
- C. Exposed Sanitary Drains, Domestic Water, Domestic Hot Water, and Stops for Plumbing Fixtures for People with Disabilities:**
1. Insulation for all pipe sizes is to be one of the following:
 - a. Pipe Insulation - Glass-Fiber, Preformed: 1/2 inch thick.
 - b. Pipe Insulation - Polyolefin: 1/2 inch thick.

3.8 INDOOR, FIELD-APPLIED INSULATION JACKET SCHEDULE

- A. Install jacket over insulation material. For insulation with factory-applied jacket, install the field-applied jacket over the factory-applied jacket.
- B. If more than one material is listed, selection from materials listed is Contractor's option.
- C. Piping, Concealed from View:
 1. None.
- D. Piping, Exposed to View:
 1. PVC: Standard.
 - a. Thickness: 20 mils.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

END OF SECTION 22 07 19

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 22 11 16 - DOMESTIC WATER PIPING

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Copper tube and fittings - domestic water.
2. PEX tube and fittings - domestic water.
3. Dielectric fittings - domestic water.

1.2 ACTION SUBMITTALS

A. Product Data:

1. Copper tube and fittings - domestic water.
2. PEX tube and fittings - domestic water.

1.3 QUALITY ASSURANCE

- A. Installer Qualifications: Installers of pressure-sealed joints are to be certified by pressure-seal joint manufacturer as having been trained and qualified to join piping with pressure-seal pipe couplings and fittings.

1.4 FIELD CONDITIONS

- A. Interruption of Existing Water Service: Do not interrupt water service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary water service in accordance with requirements indicated:
1. Notify Owner no fewer than two days in advance of proposed interruption of water service.
 2. Do not interrupt water service without Owner's written permission.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Domestic water piping, tubing, fittings, joints, and appurtenances intended to convey or dispense water for human consumption are to comply with the U.S.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

Safe Drinking Water Act, with requirements of authorities having jurisdiction, and with NSF 61 and NSF 372, or be certified in compliance with NSF 61 and NSF 372 by an ANSI-accredited third-party certification body, in that the weighted average lead content at wetted surfaces is less than or equal to 0.25 percent.

2.2 PIPING MATERIALS

- A. Potable-water piping and components are to comply with NSF 14, NSF 61, and NSF 372.

2.3 COPPER TUBE AND FITTINGS - DOMESTIC WATER

- A. Annealed-Temper Copper Tube: ASTM B88, Type K ASTM B88, Type L and ASTM B88, Type M.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by the following:
 - a. Cerro Flow Products, LLC
 - b. Mueller Streamline Co.; a company of Mueller Industries
- B. Cast-Copper, Solder-Joint Fittings: ASME B16.18, pressure fittings. Do not use solder joints on pipe sizes greater than NPS 2.
- C. Bronze Flanges: ASME B16.24, Class 150, with solder-joint ends. Do not use solder joints on pipe sizes greater than NPS 2.
- D. Cast Copper Unions: MSS SP-123, cast-copper-alloy, hexagonal-stock body, with ball-and-socket, metal-to-metal seating surfaces and solder-joint or threaded ends. Do not use solder joints on pipe sizes greater than NPS 2.
- E. Wrought Copper Unions: ASME B16.22. Do not use solder joints on pipe sizes greater than NPS 4.
- F. Copper-Tube, Mechanically Formed Tee Fitting - Domestic Water: For forming T-branch on copper water tube.
 - 1. Manufacturers: Subject to compliance with requirements, provide products by the following:
 - a. T-DRILL Industries Inc
 - 2. Description: Tee formed in copper tube in accordance with ASTM F2014.

2.4 PEX TUBE AND FITTINGS - DOMESTIC WATER

- A. PEX Tube - Domestic Water:

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. IPEX USA LLC
 - b. MrPex Systems Inc
 - c. NIBCO INC.
 - d. Uponor Inc.
 - e. Viega LLC
 - f. Zurn Industries, LLC
2. Source Limitations: Obtain PEX tube from single manufacturer.
3. Tube Material: PEX plastic in accordance with ASTM F876.

B. PEX Tube Fittings - Domestic Water:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. NIBCO INC.
 - b. Uponor Inc.
 - c. Zurn Industries, LLC
2. Source Limitations: Obtain PEX tube fittings from single manufacturer.
3. Fittings: ASTM F1807, metal insert and copper crimp rings ASTM F1960, cold expansion fittings and reinforcing rings.

2.5 PIPING JOINING MATERIALS - DOMESTIC WATER

- A. Solder Filler Metals: ASTM B32, lead-free alloys.
- B. Flux: ASTM B813, water flushable.
- C. Brazing Filler Metals: AWS A5.8M/A5.8, BCuP Series, copper-phosphorus alloys for general-duty brazing unless otherwise indicated.

2.6 DIELECTRIC FITTINGS - DOMESTIC WATER

- A. General Requirements: Assembly of copper alloy and ferrous materials with separating nonconductive insulating material. Include end connections compatible with pipes to be joined.
- B. Dielectric Unions - Domestic Water:
 1. Source Limitations: Obtain dielectric unions from single manufacturer.
 2. Standard: ASSE 1079.
 3. End Connections: Solder-joint copper alloy and threaded ferrous.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

PART 3 - EXECUTION

3.1 PIPING APPLICATIONS

- A. Transition and special fittings with pressure ratings at least equal to piping rating may be used in applications below unless otherwise indicated.
- B. Flanges and unions may be used for aboveground piping joints unless otherwise indicated.
- C. Fitting Option: Extruded-tee connections and brazed joints may be used on aboveground copper tubing.
- D. Aboveground domestic water piping, NPS 2 (DN 50) and smaller is to be the following:
 - 1. Drawn-temper copper tube, **Type L**, **wrought-** copper, solder-joint fittings; and **brazed or soldered** joints.
 - 2. Drawn-temper copper tube, **Type L**; copper pressure-seal-joint fittings; and pressure-sealed joints.
 - 3. PEX tube, NPS 1 and smaller.
 - a. Fittings for PEX tube:
 - 1) ASTM F1807, metal insert and copper crimp rings.
 - 2) ASTM F1960, cold expansion fittings and reinforcing rings.

3.2 JOINT CONSTRUCTION

- A. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- B. Remove scale, slag, dirt, and debris from inside and outside of pipes, tubes, and fittings before assembly.
- C. Brazed Joints for Copper Tubing: Comply with CDA's "Copper Tube Handbook," "Brazed Joints" chapter.
- D. Soldered Joints for Copper Tubing: Apply ASTM B813, water-flushable flux to end of tube. Join copper tube and fittings in accordance with ASTM B828 or CDA's "Copper Tube Handbook."
- E. Pressure-Sealed Joints for Copper Tubing: Join copper tube and pressure-seal fittings with tools and procedure recommended by pressure-seal-fitting manufacturer. Leave insertion marks on pipe after assembly.
- F. Extruded-Tee Connections: Form tee in copper tube in accordance with ASTM F2014. Use tool designed for copper tube; drill pilot hole, form collar for outlet, dimple tube to form seating stop, and braze branch tube into collar.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- G. Joints for PEX Tubing, ASTM: Join in accordance with ASTM F1807 for metal insert and copper crimp ring fittings and ASTM F1960 for cold expansion fittings and reinforcing rings.
- H. Joints for PEX Tubing, ASSE: Join in accordance with ASSE 1061 for push-fit fittings.
- I. Joints for Dissimilar-Material Piping: Make joints using adapters compatible with materials of both piping systems.

3.3 INSTALLATION OF DIELECTRIC FITTINGS

- A. Install dielectric fittings in piping at connections of dissimilar metal piping and tubing.
- B. Dielectric Fittings for NPS 2 (DN 50) and Smaller: Use dielectric unions.

3.4 INSTALLATION OF HANGERS AND SUPPORTS

- A. Comply with requirements for hangers, supports, and anchor devices in Section 220529 "Hangers and Supports for Plumbing Piping and Equipment."
- B. Install hangers for copper, with maximum horizontal spacing and minimum rod diameters, to comply with MSS SP-58, locally enforced codes, and authorities having jurisdiction requirements, whichever are most stringent.
- C. Install vinyl-coated hangers for PEX tube, with maximum horizontal spacing and minimum rod diameters, to comply with manufacturer's written instructions, locally enforced codes, and authorities having jurisdiction requirements, whichever are most stringent.
- D. Support horizontal piping within 12 inches of each fitting.
- E. Support vertical runs of copper pipe to comply with MSS SP-58, locally enforced codes, and authorities having jurisdiction requirements, whichever are most stringent.
- F. Support vertical runs of PEX tube to comply with manufacturer's written instructions, locally enforced codes, and authorities having jurisdiction requirements, whichever are most stringent.

3.5 PIPING CONNECTIONS

- A. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. When installing piping adjacent to equipment and machines, allow space for service and maintenance.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- C. Connect domestic water piping to water-service piping with shutoff valve; extend and connect to the following:
 - 1. Plumbing Fixtures: Cold- and hot-water-supply piping in sizes indicated, but not smaller than that required by plumbing code.
 - 2. Equipment: Cold- and hot-water-supply piping as indicated, but not smaller than equipment connections. Provide shutoff valve and union for each connection. Use flanges instead of unions for NPS 2-1/2 and larger.

3.6 CLEANING

- A. Clean and disinfect potable domestic water piping as follows:
 - 1. Purge new piping and parts of existing piping that have been altered, extended, or repaired before using.
 - 2. Use purging and disinfecting procedures prescribed by authorities having jurisdiction; if methods are not prescribed, use procedures described in either AWWA C651 or AWWA C652 or follow procedures described below:
 - a. Flush piping system with clean, potable water until dirty water does not appear at outlets.
 - b. Fill and isolate system in accordance with either of the following:
 - 1) Fill system or part thereof with water/chlorine solution with at least 50 ppm of chlorine. Isolate with valves and allow to stand for 24 hours.
 - 2) Fill system or part thereof with water/chlorine solution with at least 200 ppm of chlorine. Isolate and allow to stand for three hours.
 - c. Flush system with clean, potable water until no chlorine is in water coming from system after the standing time.

3.7 ADJUSTING

- A. Perform the following adjustments before operation:
 - 1. Close drain valves, hydrants, and hose bibbs.
 - 2. Open shutoff valves to fully open position.
 - 3. Remove plugs used during testing of piping and for temporary sealing of piping during installation.
 - 4. Remove and clean strainer screens. Close drain valves and replace drain plugs.
 - 5. Check plumbing specialties and verify proper settings, adjustments, and operation.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3.8 FIELD QUALITY CONTROL

A. Tests and Inspections:

1. Piping Inspections:

- a. Do not enclose, cover, or put piping into operation until it has been inspected and approved by authorities having jurisdiction.
- b. During installation, notify authorities having jurisdiction at least one day before inspection must be made. Perform tests specified below in presence of authorities having jurisdiction:
 - 1) Roughing-in Inspection: Arrange for inspection of piping before concealing or closing in after installation and before setting fixtures.
 - 2) Final Inspection: Arrange for authorities having jurisdiction to observe tests specified in "Piping Tests" Subparagraph below and to ensure compliance with requirements.
- c. Reinspection: If authorities having jurisdiction find that piping will not pass tests or inspections, make required corrections and arrange for reinspection.

2. Piping Tests:

- a. Fill domestic water piping. Check components to determine that they are not air bound and that piping is full of water.
- b. Test for leaks and defects in new piping and parts of existing piping that have been altered, extended, or repaired. If testing is performed in segments, submit a separate report for each test, complete with diagram of portion of piping tested.
- c. Leave new, altered, extended, or replaced domestic water piping uncovered and unconcealed until it has been tested and approved. Expose work that was covered or concealed before it was tested.
- d. Cap and subject piping to static water pressure of 50 psig above operating pressure, without exceeding pressure rating of piping system materials. Isolate test source and allow it to stand for four hours. Leaks and loss in test pressure constitute defects that must be repaired.
- e. Repair leaks and defects with new materials, and retest piping or portion thereof until satisfactory results are obtained.
- f. Prepare reports for tests and for corrective action required.

- B. Domestic water piping will be considered defective if it does not pass tests and inspections.

END OF SECTION 22 11 16

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 22 13 16 - SANITARY WASTE AND VENT PIPING

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. PVC sanitary waste and vent pipe and fittings.

1.2 DEFINITIONS

- A. Sanitary Waste and Vent Piping: Inclusive of sanitary soil, waste, and vent pipe and fittings.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Shop Drawings: For hubless, single-stack drainage system. Include plans, elevations, sections, and details.
- C. Interruption of Existing Sanitary Waste Service: Do not interrupt service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary service in accordance with requirements indicated:

1.4 WARRANTY

- A. Listed manufacturers to provide labeling and warranty of their respective products.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Minimum Working Pressure Ratings: Components and installation are capable of withstanding the following minimum working pressure requirements unless otherwise indicated:
 - 1. Sanitary Waste and Vent Piping: 10 ft. head of water.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

2.2 SANITARY WASTE AND VENT PIPING MATERIALS

- A. Comply with requirements in "Piping Schedule" Article for applications of pipe, tube, fitting materials, and joining methods for specific services, service locations, and pipe sizes.

2.3 PVC SANITARY WASTE AND VENT PIPE AND FITTINGS

A. Sanitary Waste and Vent Pipe, PVC:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Charlotte Pipe and Foundry Company
 - b. Cor-Tek; Atkore International
 - c. JM Eagle
2. Comply with NSF 14 for plastic piping components. Include "NSF-dwv" marking for plastic drain, waste, and vent piping and "NSF-sewer" marking for plastic sewer piping.
3. Solid Wall: ASTM D2665 drain, waste, and vent.
4. Cellular Core: ASTM F891, Schedule 40.

B. Sanitary Waste and Vent Fittings, PVC:

1. Manufacturers: Subject to compliance with requirements, provide products by the following:
 - a. Charlotte Pipe and Foundry Company
2. PVC Socket Fittings: ASTM D2665, manufactured in accordance with ASTM D3311; drain, waste, and vent patterns and to fit Schedule 40 pipe.

C. Adhesive Primer: ASTM F656.

D. Solvent Cement: ASTM D2564.

PART 3 - EXECUTION

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems.
1. Install piping as indicated unless deviations to layout are approved on coordination drawings.
- B. Install piping in concealed locations unless otherwise indicated and except in equipment rooms and service areas.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- C. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- D. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- E. Install piping to permit valve servicing.
- F. Install piping at indicated slopes.
- G. Install piping free of sags and bends.
- H. Install fittings for changes in direction and branch connections.
- I. Install piping to allow application of insulation.
- J. Make changes in direction for sanitary waste and vent piping using appropriate branches, bends, and long-sweep bends.
 - 1. Sanitary tees and short-sweep one-fourth bends may be used on vertical stacks if change in direction of flow is from horizontal to vertical.
- K. Slope: Install sanitary waste and vent piping at the following minimum slopes unless otherwise indicated on Drawings:
 - 1. Building Sanitary Waste Piping: Two percent downward in direction of flow for piping NPS 4 and smaller; 1 percent downward in direction of flow for piping NPS 5 and larger.
 - 2. Horizontal Sanitary Waste Piping: Two percent downward in direction of flow.
 - 3. Vent Piping: One percent down toward vertical fixture vent or toward vent stack.
- L. Plumbing Specialties:
 - 1. Install cleanouts at grade and extend to where building sanitary drains connect to building sanitary sewers in sanitary waste gravity-flow piping.
 - a. Comply with requirements for cleanouts specified in Section 221319 "Sanitary Waste Piping Specialties."
 - 2. Install drains in sanitary waste gravity-flow piping.
 - a. Comply with requirements for drains specified in Section 221319 "Sanitary Waste Piping Specialties."
- M. Do not enclose, cover, or put piping into operation until it is inspected and approved by authorities having jurisdiction.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- N. Install sleeves for piping penetrations of walls, ceilings, and floors.
- O. Install sleeve seals for piping penetrations of concrete walls and slabs.
 - 1. Comply with requirements for sleeve seals specified in Section 220500 "Common Work Results for Plumbing."
- P. Install escutcheons for piping penetrations of walls, ceilings, and floors.
- Q. Comply with requirements for escutcheons specified in Section 220500 "Common Work Results for Plumbing."

3.2 INSTALLATION OF PVC SANITARY WASTE AND VENT PIPE AND FITTINGS

- A. Install aboveground PVC piping in accordance with ASTM D2665.
- B. Install underground PVC piping in accordance with ASTM D2321.
- C. Plastic, Nonpressure-Piping, Solvent-Cement Joints: Clean and dry joining surfaces. Join pipe and fittings in accordance with the following:
 - 1. Comply with ASTM F402 for safe-handling practice of cleaners, primers, and solvent cements.
 - 2. Join in accordance with ASTM D2855 and ASTM D2665 appendixes.

3.3 INSTALLATION OF VALVES

- A. Shutoff Valves:
 - 1. Install full-port ball valve for piping NPS 2 and smaller.

3.4 INSTALLATION OF HANGERS AND SUPPORTS

- A. Comply with requirements for pipe hanger and support devices and installation specified in Section 220529 "Hangers and Supports for Plumbing Piping and Equipment."
 - 1. Vertical Piping: MSS Type 8 or Type 42 clamps.
 - 2. Install individual, straight, horizontal piping runs:
 - a. 100 Ft. (30 m) and Less: MSS Type 1, adjustable, steel clevis hangers.
- B. Plastic Pipe:
 - 1. Install hangers with maximum horizontal spacing and minimum rod diameters, to comply with manufacturer's written instructions, locally

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- enforced codes, and requirements of authorities having jurisdiction, whichever are most stringent.
2. Support vertical runs to comply with manufacturer's written instructions, locally enforced codes, and requirements of authorities having jurisdiction, whichever are most stringent
 - C. Support horizontal piping and tubing within 12 inches of each fitting [, **valve,**] and coupling.

3.5 PIPING CONNECTIONS

- A. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Connect sanitary waste piping to exterior sanitary sewerage piping. Use transition fitting to join dissimilar piping materials.
- C. Connect sanitary waste and vent piping to the following:
 1. Plumbing Fixtures: Connect waste piping in sizes indicated, but not smaller than required by plumbing code.
 2. Plumbing Fixtures and Equipment: Connect atmospheric vent piping in sizes indicated, but not smaller than required by authorities having jurisdiction.
 3. Install test tees (wall cleanouts) in conductors near floor and floor cleanouts with cover flush with floor.
- D. Where installing piping adjacent to equipment, allow space for service and maintenance of equipment.
- E. Make connections in accordance with the following unless otherwise indicated in Shop Drawings:
 1. Install unions, in piping NPS 2 and smaller, adjacent to each valve and at final connection to each piece of equipment.

3.6 IDENTIFICATION

- A. Identify exposed sanitary waste and vent piping.

3.7 FIELD QUALITY CONTROL

- A. During installation, notify authorities having jurisdiction at least 24 hours before inspection must be made. Perform tests specified below in presence of authorities having jurisdiction.
 1. Roughing-in Inspection: Arrange for inspection of piping before concealing or closing-in after roughing-in and before setting fixtures.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

2. Final Inspection: Arrange for final inspection by authorities having jurisdiction to observe tests specified below and to ensure compliance with requirements.
- B. Reinspection: If authorities having jurisdiction find that piping will not pass test or inspection, make required corrections and arrange for reinspection.
- C. Test sanitary waste and vent piping in accordance with procedures of authorities having jurisdiction or, in absence of published procedures, as follows:
1. Test for leaks and defects in new piping and parts of existing piping that have been altered, extended, or repaired.
 2. Leave uncovered and unconcealed new, altered, extended, or replaced waste and vent piping until it has been tested and approved.
 3. Repair leaks and defects with new materials and retest piping, or portion thereof, until satisfactory results are obtained.

3.8 CLEANING

- A. Clean interior of piping. Remove dirt and debris as work progresses.

3.9 PROTECTION

- A. Protect sanitary waste and vent piping during remainder of construction period to avoid clogging with dirt and debris and to prevent damage from traffic and construction work.
- B. Place plugs in ends of uncompleted piping at end of day and when work stops.

3.10 PIPING SCHEDULE

- A. Aboveground, sanitary waste piping NPS 4 and smaller is to be the following:
1. Solid-wall Cellular-core PVC pipe, PVC socket fittings, and solvent-cemented joints.
- B. Aboveground, vent piping NPS 4 is to be the following:
1. Solid-wall Cellular-core PVC pipe, PVC socket fittings, and solvent-cemented joints.
- C. Underground, sanitary waste and vent piping NPS 4 and smaller are to be the following:
1. Solid-wall Cellular-core PVC pipe, PVC socket fittings, and solvent-cemented joints.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

END OF SECTION 22 13 16

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 22 42 00 - COMMERCIAL PLUMBING FIXTURES

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
1. Commercial sinks.
 2. Commercial water closets.
 3. Toilet seats.

1.2 DEFINITIONS

- A. High-Efficiency Flush Volume: 1.28 gal. or less per flush.
- B. PMMA: Polymethyl methacrylate; also known as "acrylic."
- C. Standard-Efficiency Flush Volume: 1.6 gal. per flush.
- D. WaterSense Fixture: Water closet and/or flushometer valve/tank certified by the EPA to meet the WaterSense performance criteria.

1.3 ACTION SUBMITTALS

- A. Product Data:
1. Include construction details, material descriptions and thicknesses, dimensions of individual components and profiles, and finishes for plumbing fixtures.
 2. Include rated capacities, operating characteristics, electrical characteristics, and furnished specialties and accessories.
- B. Shop Drawings:
1. Plans, elevations, sections, and details.
 2. Details of equipment assemblies, including accessories. Indicate dimensions, weights, loads, required clearances, method of field assembly, components, location and size of each field connection, location and size of each cutout, and anchorage provisions and attachment methods. Indicate coordination requirements for adjacent and interfacing Work.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1.4 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data:
 - 1. For lavatories and faucets.
 - a. In addition to items specified in Section 017823 "Operation and Maintenance Data," include the following:
 - 1) Servicing and adjustments of automatic faucets.
 - 2. For flushometer valves and electronic sensors to include in operation and maintenance manuals.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Lavatory faucets, sink faucets, shower valves, and wash fountain spray heads and faucets intended to convey or dispense water for human consumption are to comply with the U.S. Safe Drinking Water Act (SDWA), with requirements of the Authority Having Jurisdiction (AHJ), and with NSF 61 and NSF 372, or be certified in compliance with NSF 61 and NSF 372 by an ANSI-accredited third-party certification body, in that the weighted average lead content at wetted surfaces is less than or equal to 0.25 percent.

2.2 COMMERCIAL LAVATORIES

- A. Lavatories, Wall Mounted:
 - 1. Lavatories, Wall Mounted - Vitreous China, Rectangular with Back:
 - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - 1) American Standard
 - 2) Kohler Co
 - 3) ProFlo; a Ferguson Enterprises, Inc. brand
 - 4) Sloan Valve Company
 - 5) Zurn Industries, LLC
 - b. Fixture:
 - 1) Standard: ASME A112.19.2/CSA B45.1.
 - 2) Type: For wall hanging.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- c. Faucet: as noted on the drawings.
- d. Lavatory Mounting Height: Standard or Accessible in accordance with ICC A117.1, as noted on drawings.

B. Lavatory Supply Fittings:

- 1. NSF Standards: Comply with NSF 61 and NSF 372 for supply-fitting materials that will be in contact with potable water.
- 2. Standard: ASME A112.18.1/CSA B125.1.
- 3. Supply Piping: Chrome-plated-brass pipe or chrome-plated copper tube matching water-supply piping size. Include chrome-plated-brass or stainless steel wall flange.
- 4. Supply Stops: Chrome-plated-brass, one-quarter-turn, ball-type or compression valve with inlet connection matching supply piping.
- 5. Operation: Wheel handle.

C. Lavatory Waste Fittings:

- 1. Standard: ASME A112.18.2/CSA B125.2.
- 2. Drain: Grid type with NPS 1-1/4 offset and straight tailpiece.
- 3. Trap:
 - a. Size: as shown on the drawings.
 - b. Material:
 - 1) PVC, and chrome plated wall flange.
 - 2) Chrome-plated, and chrome-plated, brass or steel wall flange.
 - 3) Stainless steel, two-piece trap and swivel elbow with 0.012-inch thick stainless steel tube to wall, and stainless steel wall flange.

2.3 COMMERCIAL WATER CLOSETS

A. Water Closets, Floor Mounted:

- 1. Water Closets, Floor Mounted - Bottom Outlet, Close-Coupled Flushometer Tank:
 - a. Manufacturers: Subject to compliance with requirements, but are not limited to, the following:
 - 1) American Standard
 - 2) Kohler Co
 - 3) Sloan Valve Company
 - 4) Zurn; Zurn Elkay
 - b. Source Limitations: Obtain water closets from single source from single manufacturer.
 - c. Standard: ASME A112.19.2/CSA B45.1.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- d. Bowl:
 - 1) Material: Vitreous china.
 - 2) Type: Siphon jet.
 - 3) Style: Flushometer tank, pressure assisted.
 - 4) Height: As shown in drawings, Standard or Accessible in accordance with ICC A117.1.
 - 5) Rim Contour: Elongated.
 - 6) Water Consumption: 1.6 gal. per flush.
 - 7) Color: White.
- e. Toilet Seat: Include toilet seat.

2.4 Supply Stop Valve

- A. Basis-of-Design Product: Subject to compliance with requirements, provide comparable product by one of the following:
 - 1. Accor Technology, Inc.:
 - 2. ProFlo; a Ferguson Enterprises, Inc. brand

2.5 TOILET SEATS

- A. Toilet Seats - Commercial:
 - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. American Standard
 - b. Bemis Manufacturing Company
 - c. Kohler Co
 - d. ProFlo; a Ferguson Enterprises, Inc. brand
 - 2. Source Limitations: Obtain toilet seat from single source from single manufacturer.
 - 3. Standard: IAPMO/ANSI Z124.5.
 - 4. Material: Plastic.
 - 5. Type: Commercial (heavy duty).

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine roughing-in of water-supply piping and sanitary drainage and vent piping systems to verify actual locations of piping connections before plumbing

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

fixture installation.

- B. Examine walls and floors for suitable conditions where plumbing fixtures will be installed.
- C. Examine counters for suitable conditions where lavatories and sinks will be installed.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION OF COMMERCIAL PLUMBING FIXTURES

A. Lavatory Installation:

- 1. Install lavatories level and plumb in accordance with roughing-in drawings.
- 2. Install supports, affixed to building substrate, for wall-mounted lavatories.
- 3. Install accessible, wall-mounted lavatories at mounting height in accordance with ICC A117.1.
- 4. Install water-supply piping with stop on each supply to each lavatory faucet. Install stops in locations that are accessible for ease of operation.
- 5. Install trap and waste piping on each drain outlet of each lavatory to be connected to sanitary drainage system.
- 6. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons if required to conceal protruding fittings. Comply with escutcheon requirements specified in Section 220500 "Common Work Results for Plumbing."
- 7. Seal joints between lavatories, counters, and walls using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."
- 8. Install protective shielding pipe covers and enclosures on exposed supplies and waste piping of accessible lavatories. Comply with requirements in Section 220719 "Plumbing Piping Insulation."

B. Sink Installation:

- 1. Install sinks level and plumb in accordance with roughing-in drawings.
- 2. Install supports, affixed to building substrate, for wall-mounted sinks.
- 3. Install accessible, wall-mounted sinks at mounting height in accordance with ICC A117.1.
- 4. Set floor-mounted sinks in leveling bed of cement grout.
- 5. Install water-supply piping with stop on each supply to each sink faucet.
 - a. Exception: Use ball or gate valves if supply stops are not specified with sink. Comply with valve requirements specified in Section 220523 "General Duty Valves for Plumbing Piping."
 - b. Install stops/valves in locations that are accessible for ease of operation.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

6. Install trap and waste piping on each drain outlet of each sink to be connected to sanitary drainage system.
7. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons if required to conceal protruding fittings. Comply with escutcheon requirements specified in Section 220500 "Common Work Results for Plumbing."
8. Seal joints between sinks, counters, floors, and walls using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."
9. Install protective shielding pipe covers and enclosures on exposed supplies and waste piping of accessible sinks. Comply with requirements in Section 220719 "Plumbing Piping Insulation."

C. Water Closet Installation:

1. Install water closets level and plumb in accordance with roughing-in drawings.
2. Install floor-mounted water closets on bowl-to-drain connecting fitting attachments to piping or building substrate.
3. Install accessible, wall-mounted water closets at mounting height in accordance with ICC A117.1.
4. Install supports, affixed to building substrate, for floor-mounted, back-outlet water closets.
5. Use carrier supports with waste-fitting assembly and seal.
6. Install floor-mounted, back-outlet water closets, attached to building floor substrate, onto waste-fitting seals; and attach to support.
7. Install wall-mounted, back-outlet water-closet supports with waste-fitting assembly and waste-fitting seals, and affix to building substrate.
8. Measure support height installation from finished floor, not structural floor.
9. Install flushometer-valve, water-supply fitting on each supply to each water closet.
10. Attach supply piping to supports or substrate within pipe spaces behind fixtures.
11. Install lever-handle flushometer valves for accessible water closets with handle mounted on open side of water closet.
12. Install actuators in locations easily reachable for people with disabilities.
13. Install new batteries in battery-powered, electronic-sensor mechanisms.
14. Install toilet seats on water closets.
15. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Install deep-pattern escutcheons if required to conceal protruding fittings. Comply with escutcheon requirements specified in Section 220500 "Common Work Results for Plumbing."
16. Seal joints between water closets, walls, and floors using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to water-closet color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."

D. Wash Fountain Installation:

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1. Install wash fountains level and plumb in accordance with roughing-in drawings.
2. Set freestanding wash fountains on floor.
3. Install off-floor carrier supports, affixed to building substrate, for wall-mounted wash fountains.
4. Install accessible, wall-mounted wash fountains at mounting height in accordance with ICC A117.1.
5. Install water-supply piping with shutoff valve on each supply to each wash fountain faucet. Use ball or gate valves if supply stops are not specified with wash fountain. Comply with valve requirements specified in Section 220523 "General Duty Valves for Plumbing Piping." Install stops/valves in locations that are accessible for ease of operation.
6. Install trap and waste piping on each drain outlet of each wash fountain to be connected to sanitary drainage system.
7. Install wall flanges or escutcheons at piping wall penetrations in exposed, finished locations. Use deep-pattern escutcheons if required to conceal protruding fittings. Comply with escutcheon requirements specified in Section 220500 "Common Work Results for Plumbing."
8. Seal joints between wash fountains, floors, and walls using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Comply with sealant requirements specified in Section 079200 "Joint Sealants."
9. Install protective shielding pipe covers and enclosures on exposed supplies and waste piping of accessible sinks. Comply with requirements in Section 220719 "Plumbing Piping Insulation."

3.3 INSTALLATION OF PIPING CONNECTIONS

- A. Connect plumbing fixtures with water supplies and soil, waste, and vent piping. Use size fittings required to match plumbing fixtures.
- B. Comply with water piping requirements specified in Section 221116 "Domestic Water Piping."
- C. Comply with soil, waste, and vent piping requirements specified in Section 221316 "Sanitary Waste and Vent Piping."
- D. Install protective-shielding pipe covers and enclosures on exposed supplies and waste piping of accessible plumbing fixtures. Comply with requirements in Section 220719 "Plumbing Piping Insulation."
- E. Where installing piping adjacent to water closets and urinals, allow space for service and maintenance.

3.4 INSTALLATION OF ELECTRICAL CONNECTIONS

- A. Connect wiring in accordance with Section 260519 "Low-Voltage Electrical Power Conductors and Cables."

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- B. Ground equipment in accordance with Section 260526 "Grounding and Bonding for Electrical Systems."
- C. Install electrical devices furnished by manufacturer, but not factory mounted in accordance with NFPA 70 and NECA 1.

3.5 ADJUSTING

- A. Operate and adjust plumbing fixtures and controls. Replace damaged and malfunctioning plumbing fixtures, fittings, and controls.
- B. Adjust water pressure at faucets to produce proper flow.
- C. Adjust water pressure at shower valves to produce proper flow.
- D. Adjust water pressure at flushometer valves to produce proper flow.
- E. Install new batteries in battery-powered, electronic-sensor mechanisms.

3.6 CLEANING AND PROTECTION

- A. After completing installation of plumbing fixtures, inspect and repair damage to finishes. Replace any fixtures unable to be repaired to the satisfaction of the Owner.
- B. Clean plumbing fixtures and associated faucets, valves, flushometer valves, and fittings with manufacturers' recommended cleaning methods and materials.
- C. Provide protective covering for installed plumbing fixtures and associated faucets, valves, flushometer valves, and fittings.
- D. Do not allow use of plumbing fixtures for temporary facilities unless approved in writing by Owner.

END OF SECTION 22 42 00

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 23 05 53 - IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Equipment labels.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Samples: For color, letter style, and graphic representation required for each identification material and device.
- C. Equipment-Label Schedule: Include a listing of all equipment to be labeled with the proposed content for each label.

PART 2 - PRODUCTS

2.1 EQUIPMENT LABELS

- A. Plastic Labels for Equipment:
 - 1. Manufacturers: Subject to compliance with requirements, provide products by the following:
 - a. Brady Corporation
 - b. Marking Services Inc.
 - c. Seton Identification Products; a Brady Corporation company
 - 2. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/8 inch thick, with predrilled holes for attachment hardware.
 - 3. Letter and Background Color: As indicated for specific application under Part 3.
 - 4. Maximum Temperature: Able to withstand temperatures of up to 160 deg F.
 - 5. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
 - 6. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances of up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.

IDENTIFICATION FOR
HVAC PIPING AND
EQUIPMENT

23 05 53

1

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- 7. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.

- B. Label Content: Include equipment's Drawing designation or unique equipment number, Drawing numbers where equipment is indicated (plans, details, and schedules), and the Specification Section number and title where equipment is specified.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Clean piping and equipment surfaces of incompatible primers, paints, and encapsulants, as well as dirt, oil, grease, release agents, and other substances that could impair bond of identification devices.

3.2 INSTALLATION, GENERAL REQUIREMENTS

- A. Coordinate installation of identifying devices with completion of covering and painting of surfaces where devices are to be applied.
- B. Coordinate installation of identifying devices with locations of access panels and doors.
- C. Install identifying devices before installing acoustical ceilings and similar concealment.
- D. Locate identifying devices so that they are readily visible from the point of normal approach.

3.3 INSTALLATION OF EQUIPMENT LABELS, WARNING SIGNS, AND LABELS

- A. Permanently fasten labels on each item of mechanical equipment.
- B. Sign and Label Colors:
 - 1. White letters on black background..
- C. Locate equipment labels where accessible and visible.

END OF SECTION 23 05 53

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 23 05 93 - TESTING, ADJUSTING, AND BALANCING FOR HVAC

PART 1 - GENERAL

1.1 SUMMARY

- A. The Work of this Section Includes:
 - 1. TAB of Air Systems:
 - a. Constant-volume air systems.
 - 2. TAB of existing HVAC systems and equipment.

1.2 DEFINITIONS

- A. AABC: Associated Air Balance Council.
- B. NC: Noise criteria.
- C. NEBB: National Environmental Balancing Bureau.
- D. TAB: Testing, adjusting, and balancing.

1.3 QUALITY ASSURANCE

- A. TAB Specialist Firm's Qualifications, Certified by AABC:
 - 1. TAB Field Supervisor: Employee of the TAB specialist firm and certified by AABC.
 - 2. TAB Technician: Employee of the TAB specialist firm and certified by AABC.
- B. TAB Specialist Firm's Qualifications: Certified by NEBB.
 - 1. TAB Certified Professional: Employee of the TAB specialist firm and certified by NEBB.
 - 2. TAB Technician: Employee of the TAB specialist firm and certified by NEBB.
 - 3. TAB specialist firm is to be independent, third-party, and unaffiliated with Contractor.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

1.4 FIELD CONDITIONS

- A. Partial Owner Occupancy: Owner may occupy completed areas of building before Substantial Completion. Cooperate with Owner during TAB operations to minimize conflicts with Owner's operations.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 GENERAL PROCEDURES FOR TESTING AND BALANCING

- A. Cut insulation, ducts, pipes, and equipment casings for installation of test probes to the minimum extent necessary for TAB procedures.
 - 1. Installing Contractor to Perform the Following:
 - a. After testing and balancing, patch probe holes in ducts with same material and thickness as used to construct ducts.
 - b. After testing and balancing, install test ports and duct access doors that comply with requirements in Section 233300 "Air Duct Accessories."
 - c. Where holes for probes are required in piping or hydronic equipment, install pressure and temperature test plugs to seal systems.
 - d. Install and join new insulation that matches removed materials. Restore insulation, coverings, vapor barrier, and finish in accordance with Section 230713 "Duct Insulation," Section 230716 "HVAC Equipment Insulation," and Section 230719 "HVAC Piping Insulation."
- B. Mark equipment and balancing devices, including damper-control positions, valve position indicators, fan-speed-control levers, and similar controls and devices, with paint or other suitable, permanent identification material to show final settings.
- C. Take and report testing and balancing measurements in inch-pound (IP units).
- D. Report deficiencies discovered before and during performance of TAB procedures. Observe and record system reactions to changes in conditions. Record default set points if different from indicated values.

3.2 TESTING, ADJUSTING, AND BALANCING OF HVAC EQUIPMENT

- A. Test, adjust, and balance HVAC equipment indicated on Drawings, including, but not limited to, the following:
 - 1. Air-handling units.
 - 2. Split-system air conditioners.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3. Heat pumps.

3.3 GENERAL PROCEDURES FOR BALANCING AIR SYSTEMS

- A. Prepare test reports for both fans and outlets. Obtain approved submittals and recommended testing procedures. Cross-check the summation of required outlet volumes with required fan volumes.
- B. Prepare single-line schematic diagram of systems or color-coded HVAC drawings for the purpose of identifying HVAC components, including each air terminal unit and each air diffuser, register, and grille.
- C. Determine suitable locations in main and branch ducts for accurate duct-airflow measurements.
- D. Locate start-stop and disconnect switches, electrical interlocks, and motor controllers.

3.4 PROCEDURES FOR CONSTANT-VOLUME AIR SYSTEMS

- A. Adjust fans to deliver total indicated airflows within the maximum allowable fan speed listed by fan manufacturer.
 1. Measure total airflow.
 - a. Set outside-air, return-air, and relief-air dampers for proper position that simulates minimum outdoor-air conditions.
 - b. Where duct conditions allow, measure airflow by main Pitot-tube traverse. If necessary, perform multiple Pitot-tube traverses close to the fan and prior to any outlets, to obtain total airflow.
 2. Measure fan static pressures as follows:
 - a. Measure static pressure directly at the fan outlet.
 - b. Measure static pressure directly at the fan inlet.
 - c. Measure static pressure differential across each component that makes up the air-handling system.
 - d. Apply artificial loading of filters to simulate a dirty filter pressure drop condition at the time static pressures are measured.
 3. Do not make fan-speed adjustments that result in motor overload. Consult equipment manufacturers about fan-speed safety factors. Modulate dampers and measure fan-motor amperage to ensure that no overload occurs. Measure amperage in full-cooling, full-heating, economizer, and any other operating mode to determine the maximum required brake horsepower.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- B. Adjust volume dampers for main duct, submain ducts, and major branch ducts to indicated airflows.
 - 1. Measure airflow of submain and branch ducts.
 - 2. Adjust submain and branch duct volume dampers for specified airflow.
 - 3. Re-measure each submain and branch duct after all volume dampers have been adjusted.

- C. Adjust air inlets and outlets for each space to indicated airflows.
 - 1. Set airflow patterns of adjustable outlets for proper distribution without drafts.
 - 2. Measure inlets' and outlets' airflow. Apply correction factors as applicable for each size and style of air device.
 - 3. Adjust each inlet and outlet for specified airflow.
 - 4. Re-measure each inlet and outlet after they have been adjusted.

- D. Verify final system conditions.
 - 1. Re-measure and confirm that minimum outdoor, return, and relief airflows are within design range. Readjust to within design tolerance if necessary.
 - 2. Re-measure and confirm that total airflow is within design.
 - 3. Re-measure all final fan operating data, speed, volts, amps, and static profile.
 - 4. Traverse the supply airflow in full airside economizer mode. Observe the mixed air plenum pressure as compared to normal operation: return air dampers open and minimum outside air varying to 100 percent outside air dampers fully open and return air dampers fully closed. Mixed air pressure is to remain constant plus/minus 20 percent or, otherwise, damper/fan adjustments will be required.
 - 5. Mark all final settings.
 - 6. Measure and record all operating data.
 - 7. Record final fan-performance data.

3.5 PROCEDURES FOR MOTORS

- A. Motors: 1 hp and larger; test at final balanced conditions and record the following data:
 - 1. Manufacturer's name, model number, and serial number.
 - 2. Motor horsepower rating.
 - 3. Motor rpm.
 - 4. Phase and hertz.
 - 5. Nameplate and measured voltage, each phase.
 - 6. Nameplate and measured amperage, each phase.
 - 7. Service factor and frame size.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3.6 PIPE-LEAKAGE TESTS VERIFICATION

- A. Witness the pipe pressure testing performed by Installer.
- B. Verify that proper test methods are used and that leakage rates are within specified limits.
- C. Report deficiencies observed.

3.7 HVAC-CONTROLS VERIFICATION

- A. In conjunction with system balancing, perform the following:
 - 1. Work to ensure the system is operating within the design limitations and gain a mutual understanding of intended controls performance.
 - 2. Confirm that the sequences of operation are in compliance with Contract Documents.
 - 3. Verify that controllers are calibrated and function as intended.
 - 4. Verify that controller set points are as indicated.
 - 5. Verify the operation of lockout or interlock systems.
 - 6. Verify the operation of valve and damper actuators.
 - 7. Verify that controlled devices are properly installed and connected to correct controller.
 - 8. Verify that controlled devices travel freely and are in position indicated by controller: open, closed, or modulating.
 - 9. Verify location and installation of sensors to ensure that they sense only intended temperature, humidity, or pressure.
- B. Reporting: Include a summary of verifications performed, remaining deficiencies, and variations from indicated conditions.

3.8 PROCEDURES FOR TESTING, ADJUSTING, AND BALANCING EXISTING SYSTEMS

- A. Perform a preconstruction inspection of existing equipment that is to remain and be reused.
 - 1. Measure and record the operating speed, airflow, and static pressure of each fan and equipment with fan(s).
 - 2. Measure and record flows, temperatures, and pressures of each piece of equipment in each hydronic system. Compare the values to design or nameplate information, where information is available.
 - 3. Measure motor voltage and amperage. Compare the values to motor nameplate information.
 - 4. Check the condition of filters.
 - 5. Check the condition of coils.
 - 6. Report on the operating condition of the equipment and the results of the

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

measurements taken. Report deficiencies.

- B. TAB after Construction: Before performing testing and balancing of renovated existing systems, inspect existing equipment that is to remain and be reused to verify that existing equipment has been cleaned and refurbished in accordance with renovation scope indicated by Contract Documents. Verify the following:
 - 1. New filters are installed.
 - 2. Coils are clean and fins combed.
 - 3. Drain pans are clean.
 - 4. Fans are clean.
 - 5. Deficiencies noted in the preconstruction report are corrected.
- C. Perform testing and balancing of existing systems to the extent that existing systems are affected by the renovation work.
 - 1. Compare the indicated airflow of the renovated work to the measured fan airflows and determine the new fan speed and the face velocity of filters and coils.
 - 2. Verify that the indicated airflows of the renovated work result in filter and coil face velocities and fan speeds that are within the acceptable limits defined by equipment manufacturer.
 - 3. Balance each air outlet.

3.9 TOLERANCES

- A. Set HVAC system's airflow rates and water-flow rates within the following tolerances:
 - 1. Supply, Return, and Exhaust Fans and Equipment with Fans: Plus 10 percent or minus 5 percent. If design value is less than 100 cfm, flow rate is within 10 cfm.
 - 2. Air Outlets and Inlets: Plus 10 percent or minus 5 percent. If design value is less than 100 cfm, flow rate is within 10 cfm.
- B. Maintaining pressure relationships as designed is to have priority over the tolerances specified above. If the above tolerances change the relative positive or negative airflow from/into the space, tolerances are to be adjusted so as to keep the relative positive cfm or negative cfm from/into the space a constant cfm differential.
- C. and each building floor for systems serving multiple floors.

3.10 FINAL TESTING AND BALANCING REPORT

- A. General: Prepare a certified written report; tabulate and divide the report into separate sections for tested systems and balanced systems.

TESTING, ADJUSTING,
AND BALANCING FOR
HVAC

23 05 93

6

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1. Include a certification sheet at the front of the report's binder, signed and sealed by the certified testing and balancing engineer.
 2. Include a list of instruments used for procedures, along with proof of calibration.
 3. Certify validity and accuracy of field data.
- B. Final Report Contents: In addition to certified field-report data, include the following:
1. Pump curves.
 2. Fan curves.
 3. Manufacturers' test data.
 4. Field test reports prepared by system and equipment installers.
 5. Other information relative to equipment performance; do not include Shop Drawings and product data.
- C. General Report Data: In addition to form titles and entries, include the following data:
1. Title page.
 2. Name and address of the TAB specialist firm and technician.
 3. Project name.
 4. Project location.
 5. Project Contractor's name, firm, and address.
 6. Report date.
 7. Signature of TAB supervisor who certifies the report.
 8. Table of Contents with the total number of pages defined for each section of the report. Number each page in the report.
 9. Summary of contents, including the following:
 - a. Indicated versus final performance.
 - b. Notable characteristics of systems.
 - c. Description of system operation sequence if it varies from the Contract Documents.
 10. Nomenclature sheets for each item of equipment.
 11. Data for terminal units, including manufacturer's name, type, size, and fittings.
 12. Notes to explain why certain final data in the body of reports vary from indicated values.
 13. Test conditions for fan performance forms, including the following:
 - a. Settings for outdoor-, return-, and exhaust-air dampers.
 - b. Conditions of filters.
 - c. Cooling coil, wet- and dry-bulb conditions.
 - d. Heating coil, dry-bulb conditions.
 - e. Fan drive settings, including settings and percentage of maximum pitch diameter.
 - f. Other system operating conditions that affect performance.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- D. System Diagrams: Include schematic layouts of air and hydronic distribution systems. Present each system with single-line diagram and include the following:
1. Quantities of outdoor, supply, return, and exhaust airflows.
 2. Duct, outlet, and inlet sizes.
 3. Balancing stations.
 4. Position of balancing devices.
- E. Air-Handling-Unit Test Reports: For air-handling units, include the following:
1. Unit Data:
 - a. Unit identification.
 - b. Location.
 - c. Make and type.
 - d. Model number and unit size.
 - e. Manufacturer's serial number.
 - f. Unit arrangement and class.
 - g. Discharge arrangement.
 - h. Sheave make, size in inches, and bore.
 - i. Center-to-center dimensions of sheave and amount of adjustments in inches.
 - j. Number, make, and size of belts.
 - k. Number, type, and size of filters.
 2. Motor Data:
 - a. Motor make and frame type and size.
 - b. Horsepower and speed.
 - c. Volts, phase, and hertz.
 - d. Full-load amperage and service factor.
 - e. Sheave make, size in inches, and bore.
 - f. Center-to-center dimensions of sheave and amount of adjustments in inches.
 3. Test Data (Indicated and Actual Values):
 - a. Total airflow rate in cfm.
 - b. Total system static pressure in inches wg.
 - c. Fan speed.
 - d. Inlet and discharge static pressure in inches wg.
 - e. For each filter bank, filter static-pressure differential in inches wg.
 - f. Outdoor airflow in cfm.
 - g. Return airflow in cfm.
 - h. Outdoor-air damper position.
 - i. Return-air damper position.
- F. Gas- and Oil-Fired Heat Apparatus Test Reports: In addition to manufacturer's factory startup equipment reports, include the following:

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

1. Unit Data:
 - a. System identification.
 - b. Location.
 - c. Make and type.
 - d. Model number and unit size.
 - e. Manufacturer's serial number.
 - f. Fuel type in input data.
 - g. Motor horsepower and speed.
 - h. Motor volts, phase, and hertz.
 - i. Motor full-load amperage and service factor.
 - j. Sheave make, size in inches, and bore.
 - k. Center-to-center dimensions of sheave and amount of adjustments in inches.

2. Test Data (Indicated and Actual Values):
 - a. Total airflow rate in cfm.
 - b. Entering-air temperature in deg F.
 - c. Leaving-air temperature in deg F.
 - d. Air temperature differential in deg F.
 - e. Entering-air static pressure in inches wg.
 - f. Leaving-air static pressure in inches wg.
 - g. Air static-pressure differential in inches wg.
 - h. Motor voltage at each connection.
 - i. Motor amperage for each phase.

- G. Electric-Coil Test Reports: For electric furnaces, duct coils, and electric coils installed in central-station air-handling units, include the following:

1. Unit Data:
 - a. System identification.
 - b. Location.
 - c. Coil identification.
 - d. Capacity in Btu/h.
 - e. Number of stages.
 - f. Connected volts, phase, and hertz.
 - g. Rated amperage.
 - h. Airflow rate in cfm.
 - i. Face area in sq. ft..
 - j. Minimum face velocity in fpm.

2. Test Data (Indicated and Actual Values):
 - a. Heat output in Btu/h.
 - b. Airflow rate in cfm.
 - c. Air velocity in fpm.
 - d. Entering-air temperature in deg F.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

- e. Leaving-air temperature in deg F.
 - f. Voltage at each connection.
 - g. Amperage for each phase.
- H. Fan Test Reports: For supply, return, and exhaust fans, include the following:
- 1. Fan Data:
 - a. System identification.
 - b. Location.
 - c. Make and type.
 - d. Model number and size.
 - e. Manufacturer's serial number.
 - f. Arrangement and class.
 - g. Sheave make, size in inches, and bore.
 - h. Center-to-center dimensions of sheave and amount of adjustments in inches.
 - 2. Motor Data:
 - a. Motor make and frame type and size.
 - b. Horsepower and speed.
 - c. Volts, phase, and hertz.
 - d. Full-load amperage and service factor.
 - e. Sheave make, size in inches, and bore.
 - f. Center-to-center dimensions of sheave and amount of adjustments in inches.
 - g. Number, make, and size of belts.
 - 3. Test Data (Indicated and Actual Values):
 - a. Total airflow rate in cfm.
 - b. Total system static pressure in inches wg.
 - c. Fan speed.
 - d. Discharge static pressure in inches wg.
 - e. Suction static pressure in inches wg.
- I. Round, Flat-Oval, and Rectangular Duct Traverse Reports: Include a diagram with a grid representing the duct cross-section and record the following:
- 1. Report Data:
 - a. System fan and air-handling-unit number.
 - b. Location and zone.
 - c. Traverse air temperature in deg F.
 - d. Duct static pressure in inches wg.
 - e. Duct size in inches.
 - f. Duct area in sq. ft..
 - g. Indicated airflow rate in cfm.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- h. Indicated velocity in fpm.
- i. Actual airflow rate in cfm.
- j. Actual average velocity in fpm.
- k. Barometric pressure in psig.

J. Air-Terminal-Device Reports:

1. Unit Data:

- a. System and air-handling unit identification.
- b. Location and zone.
- c. Apparatus used for test.
- d. Area served.
- e. Make.
- f. Number from system diagram.
- g. Type and model number.
- h. Size.
- i. Effective area in sq. ft..

2. Test Data (Indicated and Actual Values):

- a. Airflow rate in cfm.
- b. Air velocity in fpm.
- c. Preliminary airflow rate as needed in cfm.
- d. Preliminary velocity as needed in fpm.
- e. Final airflow rate in cfm.
- f. Final velocity in fpm.
- g. Space temperature in deg F.

K. Instrument Calibration Reports:

1. Report Data:

- a. Instrument type and make.
- b. Serial number.
- c. Application.
- d. Dates of use.
- e. Dates of calibration and interval.

3.11 VERIFICATION OF TAB REPORT

- A. TAB specialist firm technicians are to recheck all measurements and make adjustments as required to complete the balancing. Revise the report and balancing device settings to include all changes; submit final report.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3.12 ADDITIONAL TESTS

- A. Seasonal Periods: If initial TAB procedures were not performed during near-peak summer and winter conditions, perform additional TAB during near-peak summer and winter conditions.

END OF SECTION 23 05 93

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 23 07 13 - DUCT INSULATION

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Glass-fiber duct insulation.
 - 2. Insulation corner angles.

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of specified product. Include thermal conductivity, water-vapor permeance thickness, and jackets (both factory- and field-applied if any).

1.3 QUALITY ASSURANCE

- A. Installer Qualifications: Skilled mechanics who have successfully completed an apprenticeship program or craft training program.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Packaging: Insulation system materials are to be delivered to Project site in unopened containers. The packaging is to include name of the manufacturer, fabricator, type, description, and size.

1.5 COORDINATION

- A. Coordinate sizes and locations of supports, hangers, and insulation shields specified in Section 230529 "Hangers and Supports for HVAC Piping and Equipment."
- B. Coordinate clearance requirements with duct Installer for duct insulation application. Before preparing ductwork Shop Drawings, establish and maintain clearance requirements for installation of insulation and field-applied jackets and finishes, and for space required for maintenance.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Surface-Burning Characteristics: For insulation and related materials, as determined by testing identical products in accordance with ASTM E84, by a testing agency acceptable to authorities having jurisdiction. Factory label insulation, jacket materials, adhesive, mastic, tapes, and cement material containers with appropriate markings of applicable testing agency.
 - 1. All Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.

2.2 DUCT INSULATION MATERIALS, GENERAL

- A. Comply with requirements in "Duct Insulation Schedule, General," "Indoor Duct and Plenum Insulation Schedule," and "Aboveground, Outdoor Duct and Plenum Insulation Schedule" articles for where insulating materials are to be applied.
- B. Products are not to contain asbestos, lead, mercury, or mercury compounds.

2.3 GLASS-FIBER DUCT INSULATION

- A. Duct Insulation Wrap - Glass-Fiber Blanket:
 - 1. Manufacturers: Subject to compliance with requirements, provide products by the following:
 - a. Johns Manville; a Berkshire Hathaway company
 - b. Knauf Insulation
 - c. Owens Corning
 - 2. Description: Glass-fiber blanket duct insulation wrap consisting of glass fibers bonded with a thermosetting resin.
 - 3. Suitable for maximum use temperature up to 450 deg F in accordance with ASTM C411.
 - 4. Standards: ASTM C553, Type II, and ASTM C1290.
 - 5. Factory-Applied Insulation Facing:
 - a. FSK: Aluminum-foil, fiberglass-reinforced scrim with kraft-paper backing; complying with ASTM C1136, Type III.

2.4 INSULATION ADHESIVES

- A. Materials are to be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

2.5 INSULATION SECUREMENTS

- A. Insulation Staples: Outward-clinching insulation staples, nominal 3/4 inch wide, stainless steel or Monel.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and conditions for compliance with requirements for installation tolerances and other conditions affecting performance of insulation application.
 - 1. Verify that duct systems to be insulated have been tested and are free of defects.
 - 2. Verify that surfaces to be insulated are clean and dry.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. Surface Preparation: Clean and dry surfaces to receive insulation. Remove materials that will adversely affect insulation application.

3.3 GENERAL INSULATION INSTALLATION REQUIREMENTS

- A. Install insulation materials, accessories, and finishes with smooth, straight, and even surfaces; free of voids throughout the length of ducts and fittings.
- B. Install insulation materials, vapor barriers or retarders, jackets, and thicknesses required for each item of duct system as specified in insulation system schedules.
- C. Install accessories compatible with insulation materials and suitable for the service. Install accessories that do not corrode, compress, or otherwise damage insulation or jacket.
- D. Install insulation with longitudinal seams at top and bottom of horizontal runs.
- E. Install multiple layers of insulation with longitudinal and end seams staggered.
- F. Keep insulation materials dry during application and finishing. Replace insulation materials that get wet during storage or in the installation process before being properly covered and sealed in accordance with Contract Documents.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- G. Install insulation with tight longitudinal seams and end joints. Bond seams and joints with adhesive recommended by insulation material manufacturer.
- H. Install insulation with least number of joints practical.
- I. Where vapor barrier is indicated, seal joints, seams, and penetrations in insulation at hangers, supports, anchors, and other projections with vapor-barrier mastic.
 - 1. Install insulation continuously through hangers and around anchor attachments.
 - 2. Install insert materials and install insulation to tightly join the insert. Seal insulation to insulation inserts with adhesive or sealing compound recommended by insulation material manufacturer.
- J. Apply adhesives, mastics, and sealants at manufacturer's recommended coverage rate and wet and dry film thicknesses.
- K. Install insulation with factory-applied jackets as follows:
 - 1. Draw jacket tight and smooth, but not to the extent of creating wrinkles or areas of compression in the insulation.
 - 2. Cover circumferential joints with 3-inch- wide strips, of same material as insulation jacket. Secure strips with adhesive and outward clinching staples along both edges of strip, spaced 4 inches o.c.
 - 3. Overlap jacket longitudinal seams at least 1-1/2 inches. Clean and dry surface to receive self-sealing lap. Staple laps with outward clinching staples along edge at 4 inches o.c.
 - 4. For below ambient services, apply vapor-barrier mastic over staples.
 - 5. Cover joints and seams with tape, in accordance with insulation material manufacturer's written instructions, to maintain vapor seal.
- L. Cut insulation in a manner to avoid compressing insulation.
- M. Finish installation with systems at operating conditions. Repair joint separations and cracking due to thermal movement.
- N. Repair damaged insulation facings by applying same facing material over damaged areas. Extend patches at least 4 inches beyond damaged areas. Adhere, staple, and seal patches similar to butt joints.

3.4 INSTALLATION OF INSULATION AT PENETRATIONS

- A. Insulation Installation at Interior Wall and Partition Penetrations That Are Not Fire Rated: Install insulation continuously through walls and partitions.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3.5 INSTALLATION OF GLASS-FIBER DUCT INSULATION

- A. Comply with manufacturer's written installation instructions.
1. For ducts and plenums with surface temperatures below ambient, install a continuous unbroken vapor barrier. Create a facing lap for longitudinal seams and end joints with insulation by removing 2 inches from one edge and one end of insulation segment. Secure laps to adjacent insulation section with 1/2-inch outward-clinching staples, 1 inch o.c. Install vapor barrier consisting of factory- or field-applied jacket, adhesive, vapor-barrier mastic, and sealant at joints, seams, and protrusions.
 - a. Repair punctures, tears, and penetrations with tape or mastic to maintain vapor-barrier seal.
 - b. Install vapor stops for ductwork and plenums operating below 50 deg F at 18-ft. intervals. Vapor stops consist of vapor-barrier mastic applied in a Z-shaped pattern over insulation face, along butt end of insulation, and over the surface. Cover insulation face and surface to be insulated a width equal to two times the insulation thickness, but not less than 3 inches.
 2. Install insulation on rectangular duct elbows and transitions with a full insulation section for each surface. Install insulation on round and flat-oval duct elbows with individually mitered gores cut to fit the elbow.
 3. Insulate duct stiffeners, hangers, and flanges that protrude beyond insulation surface with 6-inch- wide strips of same material used to insulate duct. Secure on alternating sides of stiffener, hanger, and flange with pins spaced 6 inches o.c.

3.6 DUCT INSULATION SCHEDULE, GENERAL

- A. Plenums and Ducts Requiring Insulation:
1. Indoor, concealed supply and outdoor air.
 2. Indoor, exposed supply and outdoor air.
 3. Indoor, concealed return located in unconditioned space.
 4. Indoor, exposed return located in unconditioned space.
 5. Indoor, concealed exhaust between isolation damper and penetration of building exterior.
 6. Indoor, exposed exhaust between isolation damper and penetration of building exterior.
 7. Outdoor, concealed supply and return.
 8. Outdoor, exposed supply and return.
- B. Items Not Insulated:
1. Fibrous-glass ducts.
 2. Metal ducts with duct liner of sufficient thickness to comply with energy code and ASHRAE/IESNA 90.1.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3. Factory-insulated flexible ducts.
4. Factory-insulated plenums and casings.
5. Factory-insulated access panels and doors.

3.7 INDOOR DUCT AND PLENUM INSULATION SCHEDULE

- A. Concealed, Round and Flat-Oval, Supply-Air Duct Insulation: To be one of the following:
 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 0.75 lb/cu. ft. nominal density.
- B. Concealed, Round and Flat-Oval, Return-Air Duct Insulation: To be one of the following:
 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 1.5 lb/cu. ft. nominal density.
- C. Concealed, Round and Flat-Oval, Outdoor-Air Duct Insulation: To be one of the following:
 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 1.5 lb/cu. ft. nominal density.
- D. Concealed, Round and Flat-Oval, Exhaust-Air Duct Insulation: To be one of the following:
 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 1.5 lb/cu. ft. nominal density.
- E. Concealed, Rectangular, Supply-Air Duct Insulation: To be one of the following:
 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 1.5 lb/cu. ft. nominal density.
- F. Concealed, Rectangular, Return-Air Duct Insulation: To be one of the following:
 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 1.5 lb/cu. ft. nominal density.
- G. Concealed, Rectangular, Outdoor-Air Duct Insulation: To be one of the following:
 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 1.5 lb/cu. ft. nominal density.
- H. Concealed, Rectangular, Exhaust-Air Duct Insulation between Isolation Damper and Penetration of Building Exterior: To be one of the following:
 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 1.5 lb/cu. ft.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

nominal density.

- I. Concealed, Supply-Air Plenum Insulation: To be one of the following:
 - 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 1.5 lb/cu. ft. nominal density.

- J. Concealed, Return-Air Plenum Insulation: To be one of the following:
 - 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 1.5 lb/cu. ft. nominal density.

- K. Concealed, Outdoor-Air Plenum Insulation: To be one of the following:
 - 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 1.5 lb/cu. ft. nominal density.

- L. Concealed, Exhaust-Air Plenum Insulation: To be one of the following:
 - 1. Duct Insulation Wrap - Glass-Fiber Blanket: 2 inches thick and 1.5 lb/cu. ft. nominal density.

END OF SECTION 23 07 13

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 23 31 13 - METAL DUCTS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Rectangular ducts and fittings, shop fabricated - single wall.
2. Round ducts and fittings, factory fabricated - single wall.
3. Sheet metal materials.
4. Sealants and gaskets.

B. Related Requirements:

1. Section 230593 "Testing, Adjusting, and Balancing for HVAC" for testing, adjusting, and balancing requirements for metal ducts.

1.2 ACTION SUBMITTALS

A. Product Data: For each type of product.

B. Delegated Design Submittals:

1. Ductwork:
 - a. Sheet metal thicknesses.
 - b. Joint and seam construction and sealing.
 - c. Reinforcement details and spacing.
 - d. Materials, fabrication, assembly, and spacing of hangers and supports.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Delegated Duct Design: Duct construction, including sheet metal thicknesses, seam and joint construction, reinforcements, and hangers and supports, to comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" and with performance requirements and design criteria indicated in "Duct Application Schedule" Article.
- B. Airstream Surfaces: Surfaces in contact with airstream comply with requirements in ASHRAE 62.1.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- C. ASHRAE/IES 90.1 Compliance: Applicable requirements in ASHRAE/IES 90.1, Section 6.4.4 - "HVAC System Construction and Insulation."
- D. Duct Dimensions. The duct dimensions listed are the sheet metal dimensions. All allowances have been made for any internal liner or insulation.

2.2 RECTANGULAR DUCTS AND FITTINGS

- A. Rectangular Ducts and Fittings, Shop Fabricated - Single Wall:
 - 1. General Fabrication Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" based on static pressure indicated on Drawings.
 - a. Material, Indoor Ductwork: See Part 3 "Duct Application Schedule" Article for indoor duct material applications.
 - b. Material, Ductwork Exposed to Weather: For ducts exposed to weather, construct with joints and other details in accordance with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," suitable for outdoor use.
 - 2. Transverse Joints: Fabricate joints in accordance with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 2-1, "Rectangular Duct Transverse/Transverse Joints," for static pressure, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
 - 3. Longitudinal Seams: Select seam types and fabricate in accordance with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 2-2, "Rectangular Duct/Longitudinal Seams," for static pressure, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
 - 4. Elbows, Transitions, Offsets, Branch Connections, and Other Duct Construction: Select types and fabricate in accordance with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Ch. 4, "Fittings and Other Construction," for static pressure, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."

2.3 ROUND DUCTS AND FITTINGS

- A. Round Ducts and Fittings, Factory Fabricated - Single Wall:
 - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- a. Elgen Manufacturing
 - b. McGill AirFlow LLC
 - c. Nordfab Ducting
2. General Fabrication Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Ch. 3, "Round, Oval, and Flexible Duct," based on static pressure indicated on the Drawings.
 - a. Material, Indoor Ductwork: See Part 3 "Duct Application Schedule" Article for indoor duct material applications.
 3. Transverse Joints: Select joint types and fabricate in accordance with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-1, "Round Duct Transverse Joints," for static pressure, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
 4. Longitudinal Seams: Select seam types and fabricate in accordance with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-2, "Round Duct Longitudinal Seams," for static pressure, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
 5. Tees and Laterals: Select types and fabricate in accordance with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-5, "90 Degree Tees and Laterals," and Figure 3-6, "Conical Tees," for static pressure, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."

2.4 SHEET METAL MATERIALS

- A. General Material Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for acceptable materials, material thicknesses, and duct construction methods. Sheet metal materials are to be free of pitting, seam marks, roller marks, stains, discolorations, and other imperfections.
- B. Galvanized Sheet Steel: Comply with ASTM A653/A653M.
 1. Galvanized Coating Designation: G90.
 2. Lockforming Quality: Sheet steel and galvanized coating is to be able to be formed with back-to-back bends in seams such as the Pittsburgh lock at high speed without cracking or flaking of the coating on the outside of the bend.
- C. Carbon-Steel Sheets: Comply with ASTM A1008/A1008M, with oiled, matte finish for exposed ducts.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- D. Reinforcement Shapes and Plates: ASTM A36/A36M, steel plates, shapes, and bars; black and galvanized.
 - 1. Where black- and galvanized-steel shapes and plates are used to reinforce aluminum ducts, isolate the different metals with butyl rubber, neoprene, or EPDM gasket materials.
- E. Tie Rods: Galvanized steel, 1/4-inch- minimum diameter for lengths 36 inches or less; 3/8-inch- minimum diameter for lengths longer than 36 inches.

2.5 SEALANTS AND GASKETS

- A. General Sealant and Gasket Requirements: Surface-burning characteristics for sealants and gaskets: Maximum flame-spread index of 25 and a maximum smoke-developed index of 50 when tested in accordance with UL 723 and certified by an NRTL.
- B. Water-Based Joint and Seam Sealant:
 - 1. Application Method: Brush on.
 - 2. Solids Content: Minimum 65 percent.
 - 3. Shore A Hardness: Minimum 20.
 - 4. Water resistant.
 - 5. Mold and mildew resistant.
 - 6. VOC: Maximum 75 g/L (less water).
 - 7. Maximum Static Pressure: 10-inch wg, positive and negative.
 - 8. Service: Indoor or outdoor.
 - 9. Substrate: Compatible with galvanized sheet steel (both PVC coated and bare), stainless steel, or aluminum sheets.
- C. Flanged Joint Sealant: Comply with ASTM C920.
 - 1. General: Single component, acid curing, silicone, elastomeric.
 - 2. Type: S.
 - 3. Grade: NS.
 - 4. Class: 25.
 - 5. Use: O.
- D. Flange Gaskets: Butyl rubber, neoprene, or EPDM polymer with polyisobutylene plasticizer.

2.6 HANGERS AND SUPPORTS

- A. Hanger Rods for Noncorrosive Environments: Galvanized-steel rods and nuts.
- B. Strap and Rod Sizes: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Table 5-1, "Rectangular Duct Hangers Minimum Size," and Table 5-2, "Minimum Hanger Sizes for Round Duct."

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- C. Duct Attachments: Sheet metal screws, blind rivets, or self-tapping metal screws; compatible with duct materials.
- D. Trapeze and Riser Supports: Steel shapes complying with ASTM A36/A36M.
 - 1. Supports for Galvanized-Steel Ducts: Galvanized-steel shapes and plates.

PART 3 - EXECUTION

3.1 INSTALLATION OF DUCTS

- A. Install duct systems as indicated unless deviations to layout are approved on Shop Drawings and coordination drawings.
- B. Install ducts in accordance with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
- C. Install ducts in maximum practical lengths with fewest possible joints.
- D. Install factory- or shop-fabricated fittings for changes in direction, size, and shape and for branch connections.
- E. Unless otherwise indicated, install ducts vertically and horizontally, and parallel and perpendicular to building lines.
- F. Install ducts close to walls, overhead construction, columns, and other structural and permanent enclosure elements of building.
- G. Install ducts with a minimum clearance of 1 inch, plus allowance for insulation thickness.
- H. Don't route ducts through transformer vaults and electrical equipment rooms and enclosures.
- I. Where ducts pass through non-fire-rated interior partitions and exterior walls and are exposed to view, cover the opening between the partition and duct or duct insulation with sheet metal flanges of same metal thickness as the duct. Overlap openings on four sides by at least 1-1/2 inches.
- J. Install and smoke dampers where indicated on Drawings and as required by code, and by local authorities having jurisdiction. Comply with requirements in Section 233300 "Air Duct Accessories" for fire and smoke dampers and specific installation requirements of the damper UL listing.
- K. Install duct access panel assemblies at each fire and smoke damper to permit damper inspection and testing.
- L. Install heating coils, cooling coils, air filters, dampers, and all other duct-mounted

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

accessories in air ducts where indicated on Drawings.

- M. Protect duct interiors from moisture, construction debris and dust, and other foreign materials both before and after installation
- N. Elbows: Use long-radius elbows wherever they fit.
 - 1. Fabricate 90-degree rectangular mitered elbows to include turning vanes.
 - 2. Fabricate 90-degree round elbows with a minimum of three segments for 12 inches and smaller and a minimum of five segments for 14 inches and larger.
- O. Branch Connections: Use lateral or conical branch connections.

3.2 DUCT SEALING

- A. Seal ducts for duct static-pressure, seal classes, and leakage classes specified in "Duct Application Schedule" Article in accordance with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
- B. Minimum Seal Class: Seal ducts at a minimum to the following seal classes in accordance with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible":
 - 1. Unconditioned Space, Supply-Air Ducts in Pressure Rating of 2-Inch wg (500 Pa) and Lower: Seal Class B.
 - 2. Unconditioned Space, Supply-Air Ducts in Pressure Rating Higher than 2-Inch wg (500 Pa): Seal Class A.
 - 3. Unconditioned Space, Exhaust Ducts: Seal Class B.
 - 4. Unconditioned Space, Return-Air Ducts: Seal Class B.
 - 5. Conditioned Space, Supply-Air Ducts in Pressure Ratings of 2-Inch wg (500 Pa) and Lower: Seal Class B.
 - 6. Conditioned Space, Supply-Air Ducts in Pressure Rating Higher than 2-Inch wg (500 Pa): Seal Class A.
 - 7. Conditioned Space, Exhaust Ducts: Seal Class B.
 - 8. Conditioned Space, Return-Air Ducts: Seal Class B.

3.3 DUCTWORK CONNECTIONS

- A. Make connections to equipment with flexible connectors.
- B. Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for branch, outlet and inlet, and terminal unit connections.
- C. Perform tests and inspections with qualified tradesmen to verify all sheet metal installations meet the requirements for SMACNA 2" pressure classification. Verify all insulated surfaces meet SMACNA standards for coverage, compression, anchorage, vapor barrier, etc. Verify any surface conveying fluids

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

below room ambient temperature are adequately insulated to prevent any condensation. This includes all hangers, straps, quadrants, handles, rods, balancing dampers, etc. Verify insulation R value meets the minimum requirement per ASHRAE 90.1

3.4 DUCT CLEANING

- A. Clean new duct system(s) before testing, adjusting, and balancing.
- B. Use duct cleaning methodology as indicated in NADCA ACR.
- C. Use service openings for entry and inspection.
 - 1. Provide openings with access panels appropriate for duct static-pressure and leakage class at dampers, coils, and any other locations where required for inspection and cleaning access. Provide insulated panels for insulated or lined duct. Patch insulation and liner as recommended by duct liner manufacturer. Comply with Section 233300 "Air Duct Accessories" for access panels and doors.
 - 2. Disconnect and reconnect flexible ducts as needed for cleaning and inspection.
 - 3. Remove and reinstall ceiling to gain access during the cleaning process.
- D. Particulate Collection and Odor Control:
 - 1. When venting vacuuming system inside the building, use HEPA filtration with 99.97 percent collection efficiency for 0.3-micron-size (or larger) particles.
 - 2. When venting vacuuming system to outdoors, use filter to collect debris removed from HVAC system, and locate exhaust downwind and away from air intakes and other points of entry into building.
- E. Cleaning: Clean the following components by removing surface contaminants and deposits:
 - 1. Air outlets and inlets (registers, grilles, and diffusers).
 - 2. Supply, return, and exhaust fans including fan housings, plenums (except ceiling supply and return plenums), scrolls, blades or vanes, shafts, baffles, dampers, and drive assemblies.
 - 3. Air-handling unit internal surfaces and components including mixing box, coil section, air wash systems, spray eliminators, condensate drain pans, humidifiers and dehumidifiers, filters and filter sections, and condensate collectors and drains.
 - 4. Coils and related components.
 - 5. Return-air ducts, dampers, actuators, and turning vanes except in ceiling plenums and mechanical equipment rooms.
 - 6. Supply-air ducts, dampers, actuators, and turning vanes.
 - 7. Dedicated exhaust and ventilation components and makeup air systems.

ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL

- F. Mechanical Cleaning Methodology:
1. Clean metal duct systems using mechanical cleaning methods that extract contaminants from within duct systems and remove contaminants from building.
 2. Use vacuum-collection devices that are operated continuously during cleaning. Connect vacuum device to downstream end of duct sections so areas being cleaned are under negative pressure.
 3. Use mechanical agitation to dislodge debris adhered to interior duct surfaces without damaging integrity of metal ducts, duct liner, or duct accessories.
 4. Clean fibrous-glass duct liner with HEPA vacuuming equipment; do not permit duct liner to get wet. Replace fibrous-glass duct liner that is damaged, deteriorated, or delaminated or that has friable material, mold, or fungus growth.
 5. Clean coils and coil drain pans in accordance with NADCA ACR. Keep drain pan operational. Rinse coils with clean water to remove latent residues and cleaning materials; comb and straighten fins.
 6. Provide drainage and cleanup for wash-down procedures.
 7. Antimicrobial Agents and Coatings: Apply EPA-registered antimicrobial agents if fungus is present. Apply antimicrobial agents in accordance with manufacturer's written instructions after removal of surface deposits and debris.

3.5 DUCT APPLICATION SCHEDULE

- A. Fabricate all ducts to achieve SMACNA pressure rating, seal class, and leakage class as indicated below.
- B. Supply Ducts:
1. Ducts Connected to Fan Coil Units, Furnaces, Heat Pumps, and Terminal Units:
 - a. Pressure Rating: Positive 2-inch wg.
 - b. Minimum SMACNA Seal Class: B.
 - c. Material: Type G90 galvanized steel.
 2. Ducts Connected to Constant-Volume Air-Handling Units:
 - a. Pressure Rating: Positive 2-inch wg.
 - b. Minimum SMACNA Seal Class: B.
 - c. Material: Type G90 galvanized steel.
 3. Ducts Connected to Equipment Not Listed Above: exhaust fans
 - a. Pressure Rating: Positive 1 inch w.g..
 - b. Minimum SMACNA Seal Class: B.
 - c. Material: Type G90 galvanized steel.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

C. Elbow Configuration:

1. Rectangular Duct - Requirements for Different Velocities: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 4-2, "Rectangular Elbows."
 - a. Velocity 1000 fpm (5 m/s) or Lower:
 - 1) Mitered Type RE 4 without vanes.
 - b. Velocity 1000 to 1500 fpm (5 to 7.6 m/s):
 - 1) Radius Type RE 1 with minimum 1.0 radius-to-diameter ratio.
 - 2) Mitered Type RE 2 with vanes complying with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 4-3, "Vanes and Vane Runners," and Figure 4-4, "Vane Support in Elbows."
 - c. Velocity 1500 fpm (7.6 m/s) or Higher:
 - 1) Radius Type RE 1 with minimum 1.5 radius-to-diameter ratio.
 - 2) Mitered Type RE 2 with vanes complying with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 4-3, "Vanes and Vane Runners," and Figure 4-4, "Vane Support in Elbows."
2. Round Duct and Flat Oval: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-4, "Round Duct Elbows."
 - a. Minimum Radius-to-Diameter Ratio and Elbow Segments: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Table 3-1, "Mitered Elbows." Elbows with less than 90-degree change of direction have proportionately fewer segments.
 - 1) Radius-to-Diameter Ratio: 1.5.

D. Branch Configuration:

1. Rectangular Duct: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 4-6, "Branch Connection."
 - a. Rectangular Main to Rectangular Branch: 45-degree entry.
 - b. Round Branch from Rectangular Main: Conical tap with sealed collar, 2" stand off bracket, nylon bearings, locking quadrant handle.

END OF SECTION 23 31 13

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 23 37 13.13 - AIR DIFFUSERS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Diffusers - louver face.

B. Related Requirements:

1. Section 233713.23 "Registers and Grilles" for adjustable-bar register and grilles, fixed-face registers and grilles, and linear bar grilles.

1.2 ACTION SUBMITTALS

A. Product Data: For each type of specified product.

1. Data Sheet: Indicate materials of construction, finish, and mounting details; and performance data including throw and drop, static-pressure drop, and noise ratings.
2. Diffuser Schedule: Indicate drawing designation, room location, quantity, model number, size, and accessories furnished.

PART 2 - PRODUCTS

2.1 DIFFUSERS - LOUVER FACE

A. Diffuser - Louver Face:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Krueger-HVAC; brand of Johnson Controls International plc, Global Products
 - b. METALAIRE, Inc
 - c. Titus; brand of Johnson Controls International plc, Global Products
2. Description: Square diffuser with outer border, duct collar, and curved face louvers to direct air discharge in one, two, three, or four directions, parallel to ceiling surface.
3. Source Limitations: Obtain from single source from single manufacturer.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

4. Material: Aluminum.
5. Finish: Baked enamel, white.
6. Face Size: 24 x24.
7. Mounting: T-bar.
8. Pattern: Four-way core style.
9. Dampers: Radial opposed blade.

2.2 SOURCE QUALITY CONTROL

- A. Verification of Performance: Rate diffusers in accordance with ASHRAE 70.

PART 3 - EXECUTION

3.1 INSTALLATION OF AIR DIFFUSERS

- A. Install diffusers level and plumb.
- B. Ceiling-Mounted Outlets and Inlets: For units installed in lay-in ceiling panels, locate units in the center of panel. Where architectural features or other items conflict with installation, notify Architect for a determination of final location.
- C. Install diffusers with airtight connections to ducts and to allow service and maintenance of dampers, air extractors, and fire dampers.

3.2 ADJUSTING

- A. After installation, adjust diffusers to air patterns indicated, or as directed, before starting air balancing.

END OF SECTION 23 37 13.13

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

SECTION 23 37 13.23 - REGISTERS AND GRILLES

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Grilles - fixed-blade face.

B. Related Requirements:

1. Section 233300 "Air Duct Accessories" for fire and smoke dampers and volume-control dampers not integral to registers and grilles.
2. Section 233713.13 "Air Diffusers" for various types of air diffusers.

1.2 ACTION SUBMITTALS

A. Product Data:

1. For each type of product.
 - a. Data Sheet: Indicate materials of construction, finish, and mounting details; and performance data including throw and drop, static-pressure drop, and noise ratings.
 - b. Register and Grille Schedule: Indicate drawing designation, room location, quantity, model number, size, and accessories furnished.

PART 2 - PRODUCTS

2.1 GRILLES

A. Grilles - Fixed-Blade Face:

1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
 - a. Krueger-HVAC; brand of Johnson Controls International plc, Global Products
 - b. METALAIRE, Inc
 - c. Titus; brand of Johnson Controls International plc, Global Products
2. Material: Aluminum.

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

3. Finish: Baked enamel, white.
4. Face-Blade Arrangement: Fixed-face blade position, horizontally spaced 1/2 inch apart.
5. Core Construction: Integral.
6. Frame: 1-1/4 inches wide.
7. Mounting: Countersunk screw.
8. Accessory: Filter.

2.2 SOURCE QUALITY CONTROL

- A. Verification of Performance: Rate registers and grilles in accordance with ASHRAE 70.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas where registers and grilles are installed for compliance with requirements for installation tolerances and other conditions affecting performance of equipment.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION OF REGISTERS AND GRILLES

- A. Install registers and grilles level and plumb.

3.3 ADJUSTING

- A. After installation, adjust registers and grilles to air patterns indicated, or as directed, before starting air balancing.

END OF SECTION 23 37 13.23

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

APPENDIX A

February 24, 2026

Mr. Mina Awadalla
Facilities Management Engineer
Arkansas Department of Transportation
PO Box 2261
Little Rock, AR 72203

RE: Fire Protection Requirements
ARDOT Central Campus Tower
10324 I-30
Little Rock, AR 72209

Mr. Awadalla,

We have reviewed the existing conditions of the ARDOT Central Campus Tower and offer the following analysis of the fire proofing requirements from the 2021 Arkansas Fire Prevention Code:

EXISTING BUILDING CODE INFORMATION

2021 Arkansas Fire Prevention Code (AFPC) Vol. I. 1103.1 requires that any changes in the fire-resistance ratings of a building must comply with the *International Existing Building Code (IEBC)*.

The prescriptive compliance method, outlined in Chapter 5 of the 2021 IEBC, must be utilized to ensure the alterations included in the scope of work for the renovation of the ARDOT Central Office meet code requirements.

According to 2021 IEBC 503.1, "Alterations to any building or structure shall comply with the requirements of the *International Building Code** for new construction."

The ARDOT Central Office is **10 stories** above the grade plane. 2021 AFPC Vol II. 504.4 requires a minimum construction type of IB to allow this number of stories for a business occupancy, regardless of if the building is sprinklered or non-sprinklered. IB construction type allows for a building height of 160 feet for a non-sprinklered building and unlimited area, from 2021 AFPC Vol II. 504.3 and 506.2, respectively.



ARKANSAS FIRE PREVENTION CODE REQUIREMENTS

The fire-resistance rating requirements for building elements for type IB construction, as outlined in 2021 AFPC Vol II, Table 602, are as follows:

| BUILDING ELEMENT | FIRE-RESISTANCE RATING (HOURS) |
|------------------------------------------------------------------|--------------------------------|
| Primary structural frame** | 2 |
| Bearing walls, exterior | 2 |
| Bearing walls, interior | 2 |
| Nonbearing walls and partitions, exterior | 0 |
| Nonbearing walls and partitions, interior | 0 |
| Floor construction and associated secondary structural members** | 2 |
| Roof construction and associated secondary structural members** | 1 |

*2021 AFPC Code Rules – Definitions: International Building Code shall mean the *Arkansas Fire Prevention Code*, Volume II.

**See 2021 AFPC Vol II. Section 202 for definition of term.

For this building, steel framing supporting floors and roof are classified as part of the primary structural frame or secondary structural members per the definitions in the Arkansas Fire Prevention Code and shall have a fire resistance rating per Table 602.

Per the original building drawings, floor and roof assemblies are typically composite slabs and shall have a fire resistance rating per Table 602.

Per the original building drawings, typical columns are reinforced concrete with dimensions greater than 8” and at least 2” of concrete cover over the vertical reinforcement. Columns meeting these standards exceed the 2 hour fire rating and do not require additional spray applied fire proofing.

Based on a review of the original construction drawings and field observations, to the best of my knowledge this information is accurate and reflects the current conditions of the building.

Sincerely,

John Worsham, PE
Fire Protection Engineer
Cromwell Architects Engineers



Cc: Bob Keltner

**ARKANSAS DEPARTMENT OF TRANSPORTATION
JOB NO. 42-170
ARDOT CENTRAL OFFICE 5TH AND 6TH FLOOR RENOVATIONS
PROJECT MANUAL**

APPENDIX B

ATOKA, Inc.

Professional Environmental
Consulting Services

April 2, 2019

Arkansas Department of Transportation
P.O. Box 2261
Little Rock, AR. 72203
ATTN: Brian Bynum

RE: Additional asbestos bulk and dust sampling at ARDOT, 10324 I-30, Room 203, Little Rock, AR.
ATOKA, Inc., reference # 19-055-1

Dear Mr. Bynum,

Per your request, ATOKA, Inc. collected and performed Asbestos Polarized Light Microscopy (PLM) bulk and dust sampling at the above referenced building on March 27, 2019. The purpose of the sampling was to determine if there was asbestos in the dust and debris that was on top of the ceiling tiles in an area that was being renovated. This report should be added to the Pre-Renovation/Demolition USEPA NESHAP Limited Asbestos Inspection Report ATOKA # 19-055 Inspection date February 20, 2019.

This assessment found friable Asbestos Containing Materials (ACM) in the debris and the dust on top of the ceiling tile in Room 203. The debris and dust comes from the sprayed on structural fireproofing above the ceiling tile on each floor. An ACM is a material that contains greater than 1% asbestos by weight or volume as determined via Polarized Light Microscopy (PLM) methods.

Crisp Analytical, L.L.C., a NVLAP accredited laboratory performed the analysis. Laboratory results are attached.

Suspect Asbestos Materials Sampled, Laboratory Analysis Results and Condition

| Sample # | F/NF | Homogeneous Material Description | Sample Location | Asbestos | Quantity Condition |
|-----------|------|----------------------------------|---------------------------------|------------------|--------------------|
| 19-055-20 | F | Fireproofing | On Top of Ceiling Tile Room 203 | 6% Chrysotile | unk poor |
| 19-055-21 | F | Fireproofing | On Top of Ceiling Tile Room 203 | 6% Chrysotile | unk poor |
| 19-055-22 | F | Dust Sample | On top of Ceiling Tile Room 203 | 2% Chrysotile | unk poor |


NF = non-friable F- friable L1=Layer 1 L2=Layer 2 L3=Layer 3 L4=Layer 4 NAD = No asbestos detected unk = unknown sf = square feet All quantities of ACM are estimated and should be verified

DISCUSSION

The structural fireproofing material is sprayed on the decking of each floor above the lay-in ceiling tile. This space is also the return air plenum for each floor's air handling unit which means there is almost constant air movement across the ACM fireproofing material. Although the ACM fireproofing material is generally in good condition, the fifty plus years of wear and tear, on-going maintenance, and new technology has caused a dusting and in some areas fireproofing debris to be deposited on top of the ceiling tile causing potential asbestos exposure every time a ceiling tile is removed. There are Occupational Safety and Health Administration (OSHA) and EPA regulations for building owners that require notification, labeling, air testing, and training of maintenance personnel who have the potential to come into contact with the ACM.

Mr. Vick Loomis, of our Little Rock office performed the sampling. Mr. Loomis is EPA accredited and Arkansas licensed Asbestos Air Inspector (ADEQ # 008695) who has been trained to survey, sample, and assess risk associated with asbestos.

Respectfully submitted,


A handwritten signature in cursive script that reads "Vick Loomis".

Vick Loomis, Asbestos Consultant
ATOKA, Inc.

CA Labs
Dedicated to
Quality

Crisp Analytical, L.L.C.

1929 Old Denton Road
Carrollton, TX 75006
Phone 972-242-2754
Fax 972-242-2798



CA Labs, L.L.C.

12232 Industriplex, Suite 32
Baton Rouge, LA 70809
Phone 225-751-5632
Fax 225-751-5634

Materials Characterization - Bulk Asbestos Analysis

Laboratory Analysis Report - Polarized Light

Atoka, Inc.

2695 Airport Road
Hot Springs, AR 71913

Customer Project: 19-055, ARDOT
Reference #: CAL19031984AF

Date: 4/1/2019

Analysis and Method

Summary of polarized light microscopy (PLM / Stereomicroscopy bulk asbestos analysis) using the methods described in 40CFR Part 763 Appendix E to Subpart E (Interim and EPA 600 / R-93 / 116 (Improved)). The sample is first viewed with the aid of a stereomicroscope. Numerous liquid slide preparations are created for analysis under the polarized microscope where identifications and quantifications are performed. Calibrated liquid refractive oils are used as liquid mounting medium. These oils are used for identification (dispersion staining). A calibrated visual estimation is reported, should any asbestiform mineral be present. Other techniques such as acid washing are used in conjunction with refractive oils for detection of smaller quantities of asbestos. All asbestos percentages are based on calibrated visual estimation traceable to NIST standards for regulated asbestos. Traceability to measurement and calibration is achieved by using known amounts and types of asbestos from standards where analyst and laboratory accuracy are measured. As little as 0.001% asbestos can be detected in favorable samples, while detection in unfavorable samples may approach the detection limit of 0.50% (well above the laboratory definition of trace).

Discussion

Vermiculite containing samples may contain trace amounts of actinolite/tremolite. When not detected by PLM, these samples should be analyzed using TEM methods and / or water separation techniques. Suspected actinolite/vermiculite presence will be indicated through the sample comment section of this report.

Fibrous talc containing samples may contain a regulated asbestos fiber known as anthophyllite. Under certain conditions the same fiber may actually contain both talc and anthophyllite (a phenomenon called intergrowth). Again, TEM detection methods are recommended. CA Labs PLM report comments will denote suspected amounts of asbestiform anthophyllite with talc, where further analysis is recommended.

Some samples (floor tiles, surfacings, etc.) may contain fibers too small to be detectable by PLM analysis and should be analyzed by TEM bulk protocols.

A "trace asbestos" will be reported if the analyst observes far less than 1% asbestos. CA Labs defines "trace asbestos" as a few fibers detected by the analyst in several preparations and will indicate as such under these circumstances.

Since allowable variation in quantification of samples close to 1% is high, <1% may be reported. Such results are ideal for point counting, and the technique is mandatory for friable samples (NESHAP, Nov. 1990 and clarification letter 8 May 1991) under 1% percent asbestos or "trace asbestos". **In order to make all initial PLM reports issued from CA Labs NESHAP compliant, all <1% asbestos results (except floor tiles) will be point counted at no additional charge.**


Qualifications

CA Labs is accredited by the National Voluntary Accreditation Program (NVLAP) for selected test methods for airborne fiber analysis (TEM), and for bulk asbestos fiber analysis (PLM). CA Labs is also accredited by AIHA LAP, LLC. in the PLM asbestos field of testing for Industrial Hygiene. All analysts have completed college courses or hold a degree in a natural science (geology, biology, or environmental science). Recognition by a state professional board in one these disciplines is preferred, but not required. Extensive in-house training programs are used to augment the educational background of the analyst. The Laboratory Director and Quality Manager have received supplemental McCrone Research training for asbestos identification. Analysis performed at Crisp Analytical Labs, LLC 1929 Old Denton Road Carrollton, TX 75006

Dallas NVLAP Lab Code 200349-0 TEM/PLM TCEQ# T104704513-15-3 TDH 30-0235
AIHA LAP, LLC Laboratory #102929

CA Labs
Dedicated to
Quality

Crisp Analytical, L.L.C.
1929 Old Denton Road
Carrollton, TX 75006
Phone 972-242-2754
Fax 972-242-2798



CA Labs, L.L.C.
12232 Industriplex, Suite 32
Baton Rouge, LA 70809
Phone 225-751-5632
Fax 225-751-5634

Polarized Light Asbestiform Materials Characterization

| | | | |
|-----------------------|--------------|--------------------------|------------------------------------------|
| Customer Info: | Attn: | Customer Project: | CA Labs Project #: |
| Atoka, Inc. | | | CAL19031984AF |
| 2695 Airport Road | | | |
| Hot Springs, AR 71913 | | 19-055, ARDOT | Date: 4/1/2019 |
| | | Turnaround Time: | Samples Received: 3/28/19 10:30am |
| Phone # 501-623-1121 | | 3 Days | Date Of Sampling: 3/27/2019 |
| Fax # 501-623-2769 | | | Purchase Order #: |

| Sample # | Com ment | Layer # | Analysts Subsample | Physical Description of | Homo- geneo us (Y/N) | Asbestos type / calibrated visual estimate percent | Non-asbestos fiber type / percent | Non-fibrous type / percent |
|-----------|-------------|------------|-----------------------|-------------------------|-------------------------------|----------------------------------------------------------|--------------------------------------|-------------------------------|
| 19-055-20 | | 20-1 | Fireproofing/ | tan fireproofing | y | 6% Chrysotile | | 94% qu,ve,ma |
| 19-055-21 | | 21-1 | Fireproofing/ | tan fireproofing | y | 6% Chrysotile | | 94% qu,ve,ma |
| 19-055-22 | | 22-1 | Dust/ | tan debris | y | 2% Chrysotile | 4% fg 6% ce | 88% qu,ve,ma |

Dallas NVLAP Lab Code 200349-0 TEM/PLM TCEQ# T104704513-15-3 TDH 30-0235

AIHA LAP, LLC Laboratory #102929

Analysis Method: Interim (40CFR Part 763 Appendix E to Subpart E) / Improved (EPA-600 / R-93/116). All samples received in good condition unless noted.

Preparation Method: HCL acid washing for carbonate based samples, chemical reduction for organically bound components, oil immersion for

identification of asbestos types by dispersion attaining / becke line method.

| | | | |
|----------------|------------------|-------------------|--------------------------|
| ca - carbonate | mi - mica | fg - fiberglass | ce - cellulose |
| gy - gypsum | ve - vermiculite | mw - mineral wool | br - brucite |
| bi - binder | ot - other | wo - wollastonite | ka - kaolin (clay) |
| or - organic | pe - perlite | ta - talc | pa - palygorskite (clay) |
| ma - matrix | qu - quartz | sy - synthetic | |

Approved Signatories:

Stanley Massett
Analyst

Tanner Rasmussen
Technical Manager

Julio Robles
Senior Analyst

1. Fire Damage significant fiber damage - reported percentages reflect unaltered fibers
2. Fire Damage no significant fiber damages effecting fibrous percentages
3. Actinolite in association with Vermiculite
4. Layer not analyzed - attached to previous positive layer and contamination is suspected
5. Not enough sample to analyze

6. Anthophyllite in association with Fibrous Talc
7. Contamination suspected from other building materials
8. Favorable scenario for water separation on vermiculite for possible analysis by another method
9. < 1% Result point counted positive
10. TEM analysis suggested

CA Labs
Dedicated to
Quality

Crisp Analytical, L.L.C.
 1929 Old Denton Road
 Carrollton, TX 75006
 Phone 972-242-2754
 Fax 972-242-2798

CA Labs, L.L.C.
 12232 Industriplex, Suite 32
 Baton Rouge, LA 70809
 Phone 225-751-5632
 Fax 225-751-5634

Overview of Project Sample Material Containing Asbestos

| Customer Project: | | 19-055, ARDOT | | CA Labs Project #: CAL19031984AF | |
|--------------------------|---------|----------------------|-------------------------|----------------------------------------------------|----------------------------------------------|
| Sample # | Layer # | Analysts Subsample | Physical Description of | Asbestos type / calibrated visual estimate percent | List of Affected Building Material Types |
| 19-055-20 | 20-1 | Fireproofing/ | tan fireproofing | 6% Chrysotile | tan fireproofing tan debris |
| 19-055-21 | 21-1 | Fireproofing/ | tan fireproofing | 6% Chrysotile | |
| 19-055-22 | 22-1 | Dust/ | tan debris | 2% Chrysotile | |

Dallas NVLAP Lab Code 200349-0 TEM/PLM TCEQ# T104704513-15-3 TDH 30-0235
AIHA LAP, LLC Laboratory #102929

Glossary of abbreviations (non-asbestos fibers and non-fibrous minerals):

| | | | |
|------------------|--------------|--------------------|--------------------------|
| ca - carbonate | pe - perlite | fg - fiberglass | pa - palygorskite (clay) |
| gypsum - gypsum | qu - quartz | mw - mineral wool | |
| bi - binder | | wo - wollastinite | |
| or - organic | | ta - talc | |
| ma - matrix | | sy - synthetic | |
| mi - mica | | ce - cellulose | |
| ve - vermiculite | | br - brucite | |
| ot - other | | ka - kaolin (clay) | |

This report relates to the items tested. This report is not to be used by the customer to claim product certification, approval or endorsement by NVLAP, NIST, AIHA LAP, LLC, or any other agency of the federal government. This report may not be reproduced except in full without written permission from CA Labs. These results are submitted pursuant to CA Labs' current terms and sale, condition of sale, including the company's standard warranty and limitations of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping or handling fee may be assessed for the return of any samples.

Arkansas Department of Environmental Quality

ATOKA, INC.

is a licensed

Asbestos Abatement Consultant

having qualified as required by law in accordance with the regulations adopted by the Arkansas Pollution Control and Ecology Commission's Regulation 21 pursuant to Arkansas Code Annotated §20-27-1001 et seq., relative to abatement of asbestos-containing material within the state of Arkansas.



License Number: 000242

Issue Date: 12/13/2018

Expire Date: 12/13/2019

A handwritten signature in blue ink that reads "Becky W. Keogh".

Becky W. Keogh
ADEQ Director

Arkansas Department of Environmental Quality

VICK LOOMIS

having satisfied the requirements necessary to meet the provisions of AHERA/ASHARA under TSCA Title II and the Arkansas Pollution Control and Ecology Commission's Regulation 21 and is hereby certified in the State of Arkansas in the discipline(s) of Asbestos

| Discipline | Issue Date | Effective Date | Expiration Date |
|------------------|------------|----------------|-----------------|
| Air Monitor | 01/08/2019 | 01/23/2019 | 01/31/2020 |
| Inspector | 01/09/2019 | 01/23/2019 | 01/31/2020 |
| Project Designer | 11/28/2018 | 12/13/2018 | 11/30/2019 |



Certification Number: 008695

Becky W. Keogh

Becky W. Keogh
ADEQ Director

**Pre-Renovation/Pre-Demolition
United States EPA NESHAP
Limited Asbestos Inspection**

Of

**Arkansas Department of Transportation
10324 I-30
Little Rock, AR. 72209**

For

**Arkansas Department of Transportation
P.O. Box 2261
Little Rock, AR. 72203**

By

ATOKA INC.

ATOKA, Inc. - Project Reference Number 19-055

Inspection Date: February 20, 2019

Report Date: February 26, 2019

Table of Contents

| <u>Heading</u> | <u>Page</u> |
|----------------------------------------------|-------------|
| <u>Summary</u> | 3 |
| <u>Purpose of Survey</u> | 3 |
| <u>Sampling & Analysis</u> | 4 |
| <u>Report Findings</u> | 4 |
| <u>Discussion</u> | 5 |
| <u>Recommendations</u> | 6 |
| <u>Regulatory</u> | 6 |
| <u>Limitations</u> | 7 |
| <u>Appendix A - Laboratory Reports</u> | 8 |
| <u>Appendix B - Qualifications</u> | 9 |
| <u>Photos</u> | 10 |

ASBESTOS SURVEY REPORT

Limited Inspection

ARDOT

10324 I-30

Little Rock, AR.

SUMMARY

ATOKA, Inc.'s approach to this assessment was to physically and visually inspect the building materials likely to be disturbed by future renovations, to identify Suspect Asbestos Containing Materials (SACM) and collect bulk samples of those suspect materials to determine if those materials contain more than 1% asbestos. The floors to be affected by future renovations are floors 2, 3, and 10. Suspect materials sampled included structural fireproofing, 2 X 4 ceiling tiles, 9 X 9 floor tile and mastic, vinyl floor covering, cove base and mastic, and sheet rock partitions.

This assessment found friable Asbestos Containing Materials (ACM) in the sprayed on structural fireproofing above the ceiling tile on each floor and ACM 9 X 9 floor tile and black mastic, which is located through-out the building. An ACM is a material that contains greater than 1% asbestos by weight or volume as determined via Polarized Light Microscopy (PLM) methods.

The information in this assessment should be incorporated into the asbestos abatement design document but should not take the place of an abatement design specification. A written asbestos abatement design document should be developed before soliciting competitive bids from licensed Arkansas Asbestos Abatement Contractors to remove the ACM. The Arkansas Department of Environmental Quality (ADEQ) Asbestos Abatement Regulation 21 requires that in the event greater than three (3) square feet of RACM will be abated from a regulated structure(s) then it is necessary to retain an Arkansas Asbestos Designer.

PURPOSE OF SURVEY

ATOKA, Inc. was retained by ARDOT to inspect the affected floors for the presence of asbestos containing flooring materials prior to renovations. ATOKA, Inc. visited the structure on February 20, 2019, for the purpose of inspecting, sampling and quantifying ACM. ATOKA, Inc. inspected these areas to identify suspect asbestos containing material (SACM), which is classified into two categories. Those materials which can be reduced to powder or crumbled under light hand pressure are referred to as "friable" ACM (e.g., fireproofing, ceiling textures and ceiling tiles, thermal system insulation, etc.). Those materials that cannot be easily crumbled are referred to as "non-friable" ACM (e.g., floor tile, resilient flooring, roofing, mastics, etc.).

The inspection was conducted by Vick Loomis of ATOKA, Inc. Mr. Loomis is an Environmental Protection Agency (EPA) accredited and licensed Arkansas Asbestos Inspector (License #008695) who has been trained to survey, sample, and assess the conditions of SACM. Multiple samples of suspect friable and non-friable ACM were collected during the inspection.

ATOKA, Inc. is an ADEQ licensed Asbestos Consultant in good standing (License #000242).

SAMPLING AND ANALYSIS

ATOKA, Inc. conducted an asbestos assessment in general accordance with EPA NESHAP protocol requiring that a sufficient number of bulk samples be collected that represent each homogeneous SACM.

ATOKA, Inc. identified suspect asbestos containing materials (SACM) and characterized these materials into distinct homogeneous areas during the site visit inspection. This information was then used to establish a sampling plan during the course of the inspection.

The samples of SACM collected from the building were obtained by physically removing a small portion (approximately one square inch) of the material using a sharp instrument. All layers of the material samples were penetrated and registered as separate samples. Disturbance of adjacent material was kept to a minimum during the sampling program.

Each sample was placed into a separate labeled container, which was then sealed. The sampling instrument was cleaned to remove materials that could cross-contaminate the next sample. Each sample was labeled with the sample number and location and logged onto the floor plan. All samples collected during the site investigation are listed in Appendix A.

Seven (7) different SACMs were identified of which thirteen (13) samples were collected and analyzed for asbestos using the EPA "Interim Method for Determination of Asbestos in Bulk Insulation Samples" [40 CFR Part 763, Appendix E, Subpart E, improved (EPA-600/R-93/116)], by Crisp Analytical, L.L.C. a NVLAP Polarized Light Microscopy (PLM) accredited laboratory. The ACM as determined by PLM examination are those materials which contain greater than 1% asbestos by weight or volume.

The asbestos content determined for a bulk sample represents only the amount of asbestos at the point where the sample was taken. The amount of asbestos found in a material may vary depending on the sample location. Consequently, confidence limits are calculated for the same data to allow a more conservative estimate of the asbestos content of the suspect material or area. The upper confidence limit is taken as the most probable value which represents the maximum asbestos content that would be observed from a sample taken from the suspect material or area.

REPORT OF FINDINGS

Asbestos containing materials identified in the survey are summarized in the table below.

The laboratory report for bulk sample PLM analysis is found in Appendix "A" of this document.

Suspect Asbestos Materials Sampled, Laboratory Analysis Results and Condition

| Sample # | F/NF | Homogeneous Material Description | Sample Location | Asbestos | Quantity Condition |
|----------------|------|-----------------------------------------------|-----------------------------------------------------|-------------------|--------------------|
| 19-055-1 | NF | Fireproofing | Above the ceiling 10 th Floor Hallway | 15% Chrysotile | unk good |
| 19-055-2 | NF | Fireproofing | Above the ceiling 10 th Floor Hallway | 16% Chrysotile | unk good |
| 19-055-3 | F | 2X4 Ceiling Tile | 10 th Floor Hallway | NAD All Layers | unk good |
| 19-055-4 | F | 2X4 Ceiling Tile | 10 th Floor Hallway | NAD All Layers | unk good |
| 19-055-5 L1 | NF | 9X9 Floor Tile & Mastic (white floor tile) | East Stairwell | 4% Chrysotile | unk good |
| 19-055-5 L2 | NF | black mastic | East Stairwell | 3% Chrysotile | unk good |
| 19-055-6 | F | 2X4 Ceiling Tile | Commission Board Room | NAD All Layers | unk good |
| 19-055-7 | F | 2X4 Ceiling Tile | Commission Board Room | NAD All Layers | unk good |
| 19-055-8 | NF | Vinyl Floor Covering | Room 1011 | NAD | unk good |
| 19-055-9 | NF | Cove Base | 3 rd Floor Hallway | NAD All Layers | unk good |
| 19-055-10 | NF | Cove Base | 3 rd Floor Hallway | NAD All Layers | unk good |
| 19-055-11 | F | Sheetrock Partition Wall | 3 rd Floor Hallway | NAD All Layers | unk good |
| 19-055-12 | F | Sheetrock Partition | 2 nd Floor Room 205 | NAD All Layers | unk good |
| 19-055-13 | NF | Fireproofing | 2 nd Floor | 16% Chrysotile | unk good |

NF = non-friable F- friable L1=Layer 1 L2=Layer 2 L3=Layer 3 L4=Layer 4 NAD = No asbestos detected unk = unknown sf = square feet All quantities of ACM are estimated and should be verified

DISCUSSION

The structural fireproofing material is sprayed on the decking of each floor above the lay-in ceiling tile. This space is also the return air plenum for each floor's air handling unit which means there is almost constant air movement across the ACM fireproofing material. Although the ACM fireproofing material is generally in good condition, the fifty plus years of wear and tear, on-going

maintenance, and new technology has caused a dusting and in some areas fireproofing debris to be deposited on top of the ceiling tile causing potential asbestos exposure every time a ceiling tile is removed. There are Occupational Safety and Health Administration (OSHA) and EPA regulations for building owners that require notification, labeling, air testing, and training of maintenance personnel who have the potential to come into contact with the ACM.

RECOMMENDATIONS

ATOKA, Inc. recommends that this report and all records should be kept by the building owner as long as the building is in existence. All information concerning this property should be forwarded to all future property owners and made available to outside contractors that may disturb the materials identified to contain asbestos.

ATOKA, Inc., recommends that the asbestos containing materials identified in this assessment be properly removed and disposed of by a licensed Arkansas Asbestos Abatement Contractor and according to all Federal and State asbestos removal and disposal requirements prior to any renovation or demolition that would disturb the ACM.

ATOKA, Inc. recommends that any other suspect materials encountered during the renovation or demolition process that were not found and identified during this assessment be tested for asbestos prior to disturbance, handling and disposal.

ATOKA, Inc. recommends that the mandatory ten (10) day Notice of Intent (NOI) to remove regulated quantities of asbestos containing materials from a structure(s) be filed with the Arkansas Department of Environmental Quality (ADEQ) as required by EPA NESHAP regulations and Arkansas Asbestos Abatement Regulation # 21 effective 1997.

REGULATORY REQUIREMENTS

Under the Federal (EPA) NESHAP and Arkansas law, before any renovation and or demolition activities occur in commercial properties it is mandatory to ascertain the presence of asbestos containing materials (ACM), 40 CFR, Part 61, Subpart M, Section 61.145, Paragraph (a). This includes all Category I and Category II non-friable materials. The inspection by ATOKA, Inc. and this report meet the requirements of this regulation.

ACM that is friable or Category I and II ACM that is in poor condition or Category I & II ACM that becomes friable during renovation or demolition activities and found in quantities greater than 160 square feet, 260 linear feet or 35 cubic feet are considered to be regulated asbestos containing materials (RACM) and all Federal, State and Local regulations are applicable to their removal, containerization and disposal.

Be advised in the event of renovation and/or demolition activities in which ACM materials will be disturbed and are rendered friable, those materials are considered to be regulated asbestos containing materials (RACM). Arkansas Department of Environmental Quality (ADEQ) and United States EPA NESHAP require that RACM be removed prior to any such renovation or demolition activity.

LIMITATIONS

This report was prepared for the exclusive use of Arkansas Department of Transportation and/or its assignees to aid in the identification and management of ACM located at 10324 I-30, Little Rock, Arkansas.

Report prepared by




Vick Loomis, Asbestos Inspector
ATOKA, Inc.

APPENDIX "A"

LABORATORY REPORTS

CA Labs
Dedicated to
Quality

Crisp Analytical, L.L.C.
1929 Old Denton Road
Carrollton, TX 75006
Phone 972-242-2754
Fax 972-242-2798



CA Labs, L.L.C.
12232 Industriplex, Suite 32
Baton Rouge, LA 70809
Phone 225-751-5632
Fax 225-751-5634

Materials Characterization - Bulk Asbestos Analysis

Laboratory Analysis Report - Polarized Light

Atoka, Inc.

2695 Airport Road
Hot Springs, AR 71913

Customer Project: 19-055, ARDOT
Reference #: CAL19021138AG

Date: 2/22/2019

Analysis and Method

Summary of polarized light microscopy (PLM / Stereomicroscopy bulk asbestos analysis) using the methods described in 40CFR Part 763 Appendix E to Subpart E (Interim and EPA 600 / R-93 / 116 (Improved)). The sample is first viewed with the aid of a stereomicroscope. Numerous liquid slide preparations are created for analysis under the polarized microscope where identifications and quantifications are preformed. Calibrated liquid refractive oils are used as liquid mounting medium. These oils are used for identification (dispersion staining). A calibrated visual estimation is reported, should any asbestiform mineral be present. Other techniques such as acid washing are used in conjunction with refractive oils for detection of smaller quantities of asbestos. All asbestos percentages are based on calibrated visual estimation traceable to NIST standards for regulated asbestos. Traceability to measurement and calibration is achieved by using known amounts and types of asbestos from standards where analyst and laboratory accuracy are measured. As little as 0.001% asbestos can be detected in favorable samples, while detection in unfavorable samples may approach the detection limit of 0.50% (well above the laboratory definition of trace).

Discussion

Vermiculite containing samples may contain trace amounts of actinolite/tremolite. When not detected by PLM, these samples should be analyzed using TEM methods and / or water separation techniques. Suspected actinolite/vermiculite presence will be indicated through the sample comment section of this report.

Fibrous talc containing samples may contain a regulated asbestos fiber known as anthophyllite. Under certain conditions the same fiber may actually contain both talc and anthophyllite (a phenomenon called intergrowth). Again, TEM detection methods are recommended. CA Labs PLM report comments will denote suspected amounts of asbestiform anthophyllite with talc, where further analysis is recommended.

Some samples (floor tiles, surfacings, etc.) may contain fibers too small to be detectable by PLM analysis and should be analyzed by TEM bulk protocols.

A "trace asbestos" will be reported if the analyst observes far less than 1% asbestos. CA Labs defines "trace asbestos" as a few fibers detected by the analyst in several preparations and will indicate as such under these circumstances.

Since allowable variation in quantification of samples close to 1% is high, <1% may be reported. Such results are ideal for point counting, and the technique is mandatory for friable samples (NESHAP, Nov. 1990 and clarification letter 8 May 1991) under 1% percent asbestos or "trace asbestos". **In order to make all initial PLM reports issued from CA Labs NESHAP compliant, all <1% asbestos results (except floor tiles) will be point counted at no additional charge.**

Qualifications

CA Labs is accredited by the National Voluntary Accreditation Program (NVLAP) for selected test methods for airborne fiber analysis (TEM), and for bulk asbestos fiber analysis (PLM). CA Labs is also accredited by AIHA LAP, LLC. in the PLM asbestos field of testing for Industrial Hygiene. All analysts have completed college courses or hold a degree in a natural science (geology, biology, or environmental science). Recognition by a state professional board in one these disciplines is preferred, but not required. Extensive in-house training programs are used to augment the educational background of the analyst. The Laboratory Director and Quality Manager have received supplemental McCrone Research training for asbestos identification. Analysis performed at Crisp Analytical Labs, LLC 1929 Old Denton Road Carrollton, TX 75006

Dallas NVLAP Lab Code 200349-0 TEM/PLM TCEQ# T104704513-15-3 TDH 30-0235
AIHA LAP, LLC Laboratory #102929

CA Labs
Dedicated to
Quality

Crisp Analytical, L.L.C.
1929 Old Denton Road
Carrollton, TX 75006
Phone 972-242-2754
Fax 972-242-2798

CA Labs, L.L.C.
12232 Industriplex, Suite 32
Baton Rouge, LA 70809
Phone 225-751-5632
Fax 225-751-5634

Overview of Project Sample Material Containing Asbestos

| Customer Project: | | 19-055, ARDOT | | | CA Labs Project #: | CAL19021138AG |
|-------------------|---------|---------------|------------------------------------------------|----------------------------------------------------|----------------------------------------------------------------------------|---------------|
| Sample # | Layer # | Analysts | Physical Description of Subsample | Asbestos type / calibrated visual estimate percent | List of Affected Building Material Types | |
| A-055-1 | 1-1 | | Fireproofing/ gray fireproofing | 15% Chrysotile | gray fireproofing white floor tile black mastic | |
| A-055-2 | 2-1 | | Fireproofing/ gray fireproofing | 16% Chrysotile | | |
| A-055-5 | 5-1 | | Floor Tile and Mastic/ white floor tile | 4% Chrysotile | | |
| | 5-2 | | black mastic | 3% Chrysotile | | |
| A-055-13 | 13-1 | | Fireproofing/ gray fireproofing | 16% Chrysotile | | |

Dallas NVLAP Lab Code 200349-0 TEM/PLM TCEQ# T104704513-15-3 TDH 30-0235
AIHA LAP, LLC Laboratory #102929

Glossary of abbreviations (non-asbestos fibers and non-fibrous minerals):

| | | | |
|------------------|--------------|--------------------|--------------------------|
| ca - carbonate | pe - perlite | fg - fiberglass | pa - palygorskite (clay) |
| gypsum - gypsum | qu - quartz | mw - mineral wool | |
| bi - binder | | wo - wollastinite | |
| or - organic | | ta - talc | |
| ma - matrix | | sy - synthetic | |
| mi - mica | | ce - cellulose | |
| ve - vermiculite | | br - brucite | |
| ot - other | | ka - kaolin (clay) | |

This report relates to the items tested. This report is not to be used by the customer to claim product certification, approval or endorsement by NVLAP, NIST, AIHA LAP, LLC, or any other agency of the federal government. This report may not be reproduced except in full without written permission from CA Labs. These results are submitted pursuant to CA Labs' current terms and sale, condition of sale, including the company's standard warranty and limitations of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping or handling fee may be assessed for the return of any samples.

CA Labs
Dedicated to
Quality

Crisp Analytical, L.L.C.
1929 Old Denton Road
Carrollton, TX 75006
Phone 972-242-2754
Fax 972-242-2798

CA Labs, L.L.C.
12232 Industriplex, Suite 32
Baton Rouge, LA 70809
Phone 225-751-5632
Fax 225-751-5634

Polarized Light Asbestiform Materials Characterization

Customer Info: Attn:
Atoka, Inc.
2695 Airport Road
Hot Springs, AR 71913

Customer Project:
19-055, ARDOT
Turnaround Time:
24 hours

CA Labs Project #:
CAL19021138AG

Date: 2/22/2019
Samples Received: 2/21/19 10:30AM
Date Of Sampling: 2/20/2019
Purchase Order #:

Phone # 501-623-1121
Fax # 501-623-2769

| Sample # | Com ment | Layer # | Analysts Physical Description of Subsample | Homo-geneous (Y/N) | Asbestos type / calibrated visual estimate percent | Non-asbestos fiber type / percent | Non-fibrous type / percent |
|----------|----------|---------|------------------------------------------------|--------------------|----------------------------------------------------|-----------------------------------|----------------------------|
| A-055-1 | | 1-1 | Fireproofing/ gray fireproofing | y | 15% Chrysotile | 10% ce | 75% qu,ve,ca,ma |
| A-055-2 | | 2-1 | Fireproofing/ gray fireproofing | y | 16% Chrysotile | 10% ce | 74% qu,ve,ca,ma |
| A-055-3 | | 3-1 | Ceiling Tile/ white surfacing | y | None Detected | | 100% qu,bi |
| | | 3-2 | tan fibrous ceiling tile | y | None Detected | 100% fg | |
| A-055-4 | | 4-1 | Ceiling Tile/ white surfacing | y | None Detected | | 100% qu,bi |
| | | 4-2 | tan fibrous ceiling tile | y | None Detected | 100% fg | |
| A-055-5 | | 5-1 | Floor Tile and Mastic/ white floor tile | y | 4% Chrysotile | | 96% qu,ca |

Dallas NVLAP Lab Code 200349-0 TEM/PLM TCEQ# T104704513-15-3 TDH 30-0235


AIHA LAP, LLC Laboratory #102929

Analysis Method: Interim (40CFR Part 763 Appendix E to Subpart E) / Improved (EPA-600 / R-93/116). All samples received in good condition unless noted.

Preparation Method: HCL acid washing for carbonate based samples, chemical reduction for organically bound components, oil immersion for identification of asbestos types by dispersion attaining / becke line method.

| | | | |
|----------------|------------------|-------------------|--------------------------|
| ca - carbonate | mi - mica | fg - fiberglass | ce - cellulose |
| gy - gypsum | ve - vermiculite | mw - mineral wool | br - brucite |
| bi - binder | ot - other | wo - wollastonite | ka - kaolin (clay) |
| or - organic | pe - perlite | ta - talc | pa - palygorskite (clay) |
| ma - matrix | qu - quartz | sy - synthetic | |

Approved Signatories:



Tanner Rasmussen
Analyst



Technical Manager
Tanner Rasmussen

Senior Analyst
Julio Robles

1. Fire Damage significant fiber damage - reported percentages reflect unaltered fibers
2. Fire Damage no significant fiber damages affecting fibrous percentages
3. Actinolite in association with Vermiculite
4. Layer not analyzed - attached to previous positive layer and contamination is suspected
5. Not enough sample to analyze

6. Anthophyllite in association with Fibrous Talc
7. Contamination suspected from other building materials
8. Favorable scenario for water separation on vermiculite for possible analysis by another method
9. < 1% Result point counted positive
10. TEM analysis suggested

CA Labs
Dedicated to
Quality

Crisp Analytical, L.L.C.
1929 Old Denton Road
Carrollton, TX 75006
Phone 972-242-2754
Fax 972-242-2798

CA Labs, L.L.C.
12232 Industriplex, Suite 32
Baton Rouge, LA 70809
Phone 225-751-5632
Fax 225-751-5634

Polarized Light Asbestiform Materials Characterization

| | | |
|--------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Customer Info: Attn: Atoka, Inc. 2695 Airport Road Hot Springs, AR 71913 | Customer Project: 19-055, ARDOT Turnaround Time: 24 hours | CA Labs Project #: CAL19021138AG Date: 2/22/2019 Samples Received: 2/21/19 10:30AM Date Of Sampling: 2/20/2019 Purchase Order #: |
| Phone # 501-623-1121 Fax # 501-623-2769 | | |

| Sample # | Com ment | Layer # | Analysts Physical Description of Subsample | Homo-geneo us (Y/N) | Asbestos type / calibrated visual estimate percent | Non-asbestos fiber type / percent | Non-fibrous type / percent |
|----------|----------|---------|-------------------------------------------------|---------------------|----------------------------------------------------|-----------------------------------|----------------------------|
| | | 5-2 | black mastic | y | 3% Chrysotile | | 97% gy,bi |
| A-055-6 | | 6-1 | Ceiling Tile/ white surfacing | y | None Detected | | 100% qu,bi |
| | | 6-2 | tan ceiling tile | y | None Detected | 41% ce 41% fg | 18% qu,pe,ca |
| A-055-7 | | 7-1 | Ceiling Tile/ white surfacing | y | None Detected | | 100% qu,bi |
| | | 7-2 | tan ceiling tile | y | None Detected | 41% ce 41% fg | 18% qu,pe,ca |
| A-055-8 | | 8-1 | Covering/ white self-adhesive floor tile | y | None Detected | | 100% qu,ma |
| A-055-9 | | 9-1 | Cove Base/ black baseboard | y | None Detected | | 100% gy,ma |

Dallas NVLAP Lab Code 200349-0 TEM/PLM TCEQ# T104704513-15-3 TDH 30-0235


AIHA LAP, LLC Laboratory #102929

Analysis Method: Interim (40CFR Part 763 Appendix E to Subpart E) / Improved (EPA-600 / R-93/116). All samples received in good condition unless noted.

Preparation Method: HCL acid washing for carbonate based samples, chemical reduction for organically bound components, oil immersion for identification of asbestos types by dispersion attaining / becke line method.

| | | | |
|----------------|------------------|-------------------|--------------------------|
| ca - carbonate | mi - mica | fg - fiberglass | ce - cellulose |
| gy - gypsum | ve - vermiculite | mw - mineral wool | br - brucite |
| bi - binder | ot - other | wo - wollastonite | ka - kaolin (clay) |
| or - organic | pe - perlite | ta - talc | pa - palygorskite (clay) |
| ma - matrix | qu - quartz | sy - synthetic | |

Approved Signatories:



Tanner Rasmussen
Analyst



Technical Manager Senior Analyst
Tanner Rasmussen Julio Robles

1. Fire Damage significant fiber damage - reported percentages reflect unaltered fibers
2. Fire Damage no significant fiber damages effecting fibrous percentages
3. Actinolite in association with Vermiculite
4. Layer not analyzed - attached to previous positive layer and contamination is suspected
5. Not enough sample to analyze

6. Anthophyllite in association with Fibrous Talc
7. Contamination suspected from other building materials
8. Favorable scenario for water separation on vermiculite for possible analysis by another method
9. < 1% Result point counted positive
10. TEM analysis suggested

CA Labs
Dedicated to
Quality

Crisp Analytical, L.L.C.
1929 Old Denton Road
Carrollton, TX 75006
Phone 972-242-2754
Fax 972-242-2798

CA Labs, L.L.C.
12232 Industriplex, Suite 32
Baton Rouge, LA 70809
Phone 225-751-5632
Fax 225-751-5634

Polarized Light Asbestiform Materials Characterization

| | | |
|--------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Customer Info: Attn: Atoka, Inc. 2695 Airport Road Hot Springs, AR 71913 | Customer Project: 19-055, ARDOT Turnaround Time: 24 hours | CA Labs Project #: CAL19021138AG Date: 2/22/2019 Samples Received: 2/21/19 10:30AM Date Of Sampling: 2/20/2019 Purchase Order #: |
| Phone # 501-623-1121 | | |
| Fax # 501-623-2769 | | |

| Sample # | Com ment | Layer # | Analysts Physical Description of Subsample | Homo-geneo us (Y/N) | Asbestos type / calibrated visual estimate percent | Non-asbestos fiber type / percent | Non-fibrous type / percent |
|----------|----------|---------|--------------------------------------------|---------------------|----------------------------------------------------|-----------------------------------|----------------------------|
| | | 9-2 | tan mastic | y | None Detected | | 100% gy,bi |
| A-055-10 | | 10-1 | Cove Base/ black baseboard | y | None Detected | | 100% gy,ma |
| | | 10-2 | tan mastic | y | None Detected | | 100% gy,bi |
| A-055-11 | | 11-1 | Sheetrock Partition/ white surfacing | y | None Detected | | 100% qu,bi |
| | | 11-2 | white drywall with brown paper | n | None Detected | 20% ce | 80% qu,gy |
| A-055-12 | | 12-1 | Sheetrock Partition/ white surfacing | y | None Detected | | 100% qu,bi |
| | | 12-2 | white drywall with brown paper | n | None Detected | 22% ce | 78% qu,gy |

Dallas NVLAP Lab Code 200349-0 TEM/PLM TCEQ# T104704513-15-3 TDH 30-0235

AIHA LAP, LLC Laboratory #102929

Analysis Method: Interim (40CFR Part 763 Appendix E to Subpart E) / Improved (EPA-600 / R-93/116). All samples received in good condition unless noted.
Preparation Method: HCL acid washing for carbonate based samples, chemical reduction for organically bound components, oil immersion for identification of asbestos types by dispersion attaining / becke line method.

- | | | | |
|----------------|------------------|-------------------|--------------------------|
| ca - carbonate | mi - mica | fg - fiberglass | ce - cellulose |
| gy - gypsum | ve - vermiculite | mw - mineral wool | br - brucite |
| bi - binder | ot - other | wo - wollastonite | ka - kaolin (clay) |
| or - organic | pe - perillite | ta - talc | pa - palygorskite (clay) |
| ma - matrix | qu - quartz | sy - synthetic | |

Approved Signatories:

C.T. Rasmussen

Tanner Rasmussen
Analyst

Julio Robles

Technical Manager
Tanner Rasmussen

Senior Analyst
Julio Robles

1. Fire Damage significant fiber damage - reported percentages reflect unaltered fibers
2. Fire Damage no significant fiber damages effecting fibrous percentages
3. Actinolite in association with Vermiculite
4. Layer not analyzed - attached to previous positive layer and contamination is suspected
5. Not enough sample to analyze

6. Anthophyllite in association with Fibrous Talc
7. Contamination suspected from other building materials
8. Favorable scenario for water separation on vermiculite for possible analysis by another method
9. < 1% Result point counted positive
10. TEM analysis suggested

CA Labs
Dedicated to
Quality

Crisp Analytical, L.L.C.
1929 Old Denton Road
Carrollton, TX 75006
Phone 972-242-2754
Fax 972-242-2798

CA Labs, L.L.C.
12232 Industriplex, Suite 32
Baton Rouge, LA 70809
Phone 225-751-5632
Fax 225-751-5634

Polarized Light Asbestiform Materials Characterization

Customer Info: Attn:
Atoka, Inc.
2695 Airport Road
Hot Springs, AR 71913

Customer Project:
19-055, ARDOT
Turnaround Time:
24 hours

CA Labs Project #:
CAL19021138AG

Date: 2/22/2019
Samples Received: 2/21/19 10:30AM
Date Of Sampling: 2/20/2019
Purchase Order #:

Phone # 501-623-1121
Fax # 501-623-2769

| Sample # | Com ment | Layer # | Analysts Physical Description of Subsample | Homo- geneo us (Y/N) | Asbestos type / calibrated visual estimate percent | Non-asbestos fiber type / percent | Non-fibrous type / percent |
|----------|-------------|------------|-----------------------------------------------|-------------------------------|----------------------------------------------------------|--------------------------------------|-------------------------------|
| A-055-13 | | 13-1 | Fireproofing/ gray fireproofing | y | 16% Chrysotile | 5% fg | 79% qu,ve,ca,ma |


Dallas NVLAP Lab Code 200349-0 TEM/PLM TCEQ# T104704513-15-3 TDH 30-0235

AIHA LAP, LLC Laboratory #102929

Analysis Method: Interim (40CFR Part 763 Appendix E to Subpart E) / Improved (EPA-600 / R-93/116). All samples received in good condition unless noted.
Preparation Method: HCL acid washing for carbonate based samples, chemical reduction for organically bound components, oil immersion for identification of asbestos types by dispersion attaining / becke line method.

| | | | |
|----------------|------------------|-------------------|--------------------------|
| ca - carbonate | mi - mica | fg - fiberglass | ce - cellulose |
| gy - gypsum | ve - vermiculite | mw - mineral wool | br - brucite |
| bi - binder | ot - other | wo - wollastonite | ka - kaolin (clay) |
| or - organic | pe - perlite | ta - talc | pa - palygorskite (clay) |
| ma - matrix | qu - quartz | sy - synthetic | |

Approved Signatories:



Tanner Rasmussen
Analyst



Technical Manager
Tanner Rasmussen

Senior Analyst
Julio Robles

1. Fire Damage significant fiber damage - reported percentages reflect unaltered fibers
2. Fire Damage no significant fiber damages effecting fibrous percentages
3. Actinolite in association with Vermiculite
4. Layer not analyzed - attached to previous positive layer and contamination is suspected
5. Not enough sample to analyze

6. Anthophyllite in association with Fibrous Talc
7. Contamination suspected from other building materials
8. Favorable scenario for water separation on vermiculite for possible analysis by another method
9. < 1% Result point counted positive
10. TEM analysis suggested

11701 I-30, Bldg. 1, Ste. 119
Little Rock, AR. 72209

Office: 501-455-1700

Fax: 501-455-1864

ATOKA, INC.
CHAIN OF CUSTODY/ANALYSIS REQUEST FORM

CALL 902 1138

| | | | |
|-------------------------------------------|--|-------------------------------------------|--|
| ATOKA PROJECT NO. 19-055 | | CLIENT/OWNER AR DOT | |
| Name AA DOT | | Name AA DOT | |
| Address PO Box 2261 | | Address 10324 I-30 | |
| City, State, ZIP Little Rock AR | | City, State, ZIP Little Rock AR | |
| Phone # | | E-mail : | |
| Fax # | | Temp °C. | |

| | | | | | |
|------------------------------------------|--|-------------------------------------------------------------------------------------------------------------------------------------------------|--|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| SAMPLERS SIGNATURE <i>Vick Loomis</i> | | SAMPLE CONDITION: | | TURN AROUND TIME | |
| Printed Vick Loomis | | <input checked="" type="checkbox"/> Satisfactory <input type="checkbox"/> Unsatisfactory <input type="checkbox"/> Rejected - Reason _____ | | <input checked="" type="checkbox"/> 24 hours <input type="checkbox"/> 2 days <input type="checkbox"/> Standard (3-5 days) <input type="checkbox"/> Std Protocol | |

| FIELD SAMPLE # | DATE COLLECTED | TIME | SAMPLE LOCATION/DESCRIPTION: | Volume of Air Liters | TEST REQUESTED | ATOKA LAB ID # |
|----------------|----------------|------|------------------------------------------|----------------------|----------------|----------------|
| A-055-1 | 2/20/19 | | 10th Floor Fire proofing - Hallway | | Asbestos | |
| -2 | | | 10th Floor Fire proofing - Hallway | | | |
| -3 | | | 2X4 Ceiling Tile - Hallway | | | |
| -4 | | | 2X4 Ceiling Tile - Hallway | | | |
| -5 | | | 9X9 Floor Tile + Mastix - EAST STAIRWELL | | | |
| -6 | | | 2X4 Ceiling Tile - Commission Board Room | | | |
| -7 | | | 2X4 Ceiling Tile " | | | |
| -8 | | | Vinyl Floor Covering - AM 1011 | | | |
| -9 | | | 3rd Floor Cove base - Hallway | | | |
| -10 | | | 3rd Floor Cove base + Hallway | | | |

| | | | |
|---------------------------------------|----------------------|-----------------------------------|----------------------|
| RELINQUISHED BY <i>Vick Loomis</i> | DATE/TIME 2/20/19 | RECEIVED BY <i>[Signature]</i> | DATE/TIME 2/21/19 |
| PRINTED Vick Loomis | | PRINTED | |

| | | | | |
|-------------|-----------|------------------------|-----------------|----------------------|
| RECEIVED BY | DATE/TIME | RECEIVED BY LABORATORY | DATE/TIME | SPECIAL INSTRUCTIONS |
| PRINTED | | PRINTED | 2/21/19 10:30am | |

APPENDIX "B"
QUALIFICATIONS

Arkansas Department of Environmental Quality

ATOKA, INC.

is a licensed

Asbestos Abatement Consultant

having qualified as required by law in accordance with the regulations adopted by the Arkansas Pollution Control and Ecology Commission's Regulation 21 pursuant to Arkansas Code Annotated §20-27-1001 et seq., relative to abatement of asbestos-containing material within the state of Arkansas.



License Number: 000242

Issue Date: 12/13/2018

Expire Date: 12/13/2019

A handwritten signature in blue ink that reads "Becky W. Keogh".

Becky W. Keogh
ADEQ Director

Arkansas Department of Environmental Quality

VICK LOOMIS

having satisfied the requirements necessary to meet the provisions of AHERA/ASHARA under TSCA Title II and the Arkansas Pollution Control and Ecology Commission's Regulation 21 and is hereby certified in the State of Arkansas in the discipline(s) of Asbestos


| Discipline | Issue Date | Effective Date | Expiration Date |
|------------------|------------|----------------|-----------------|
| Air Monitor | 01/08/2019 | 01/23/2019 | 01/31/2020 |
| Inspector | 01/09/2019 | 01/23/2019 | 01/31/2020 |
| Project Designer | 11/28/2018 | 12/13/2018 | 11/30/2019 |



Certification Number: 008695

Becky W. Keogh
Becky W. Keogh
ADEQ Director

PHOTOS



ACM fireproofing material applied to structural decking and beams



ACM 9 X 9 floor tile and mastic prevalent through out building



ACM fireproofing debris on top of ceiling tile on 10th floor. This space is also the return air plenum.



ACM debris on top of ceiling tile on 10th floor. This space is also the return air plenum.



ACM fireproofing debris on ceiling tile in the return air plenum of the 2nd floor



ACM fireproofing debris on ceiling tile in the return air plenum of the 2nd floor

ATOKA, Inc.

Professional Environmental Consulting
Services

May 16, 2019

Brian Bynum
Arkansas Department of Transportation
P.O. Box 2261
Little Rock, AR 72203

RE: Ambient air sampling and Transmission Electron Microscopy (TEM) analysis for the presence of asbestos at the ARDOT main building, 10324 I-30, Little Rock, AR 72209, ATOKA project reference # 19-055.

Dear Mr. Bynum,

Per your request ATOKA, Inc., performed ambient air sampling for airborne asbestos at the above referenced location. The sampling was conducted over the course of two weeks on Friday evenings and Saturdays starting on April 26, 2019. The purpose of the air sampling was to determine if there was an airborne asbestos exposure risk in the building due to asbestos containing structural fireproofing material that was sprayed on the decking of each floor. The asbestos containing material (ACM) is in the air plenum above the drop ceiling tile and had shown some signs of deterioration and damage due to age and new technology. A minimum of five (5) samples were collected on each floor with floors 5, 6, 7, and 9 getting six (6) samples because of the different lay-out of each floor for a total of 60 samples.

No asbestos was detected in any of the air samples collected and analyzed for asbestos. There was no indication that an asbestos fiber release has occurred at the time of the assessment. ATOKA, Inc. does recommend that great caution be taken when accessing above the ceiling tile as there is visible ACM material on much of the ceiling tile on the floors that have been inspected. As was discussed in the inspection report letter dated February 26, 2019, there are training requirements for custodial and maintenance personnel who have the potential to come into contact with the ACM.


Air sampling was conducted by Vick Loomis and Carrie Roberts of ATOKA, Inc. Mr. Loomis and Mrs. Roberts are E.P.A. accredited and an Arkansas licensed Asbestos Air Monitors (ADEQ license #'s 009695 and 017397) who has been trained to survey, sample, and assess risk associated with airborne asbestos.

Crisp Analytical, L.L.C., a NVLAP Transmission Electron Microscopy (TEM) accredited laboratory performed the analysis. Laboratory results are attached.

Respectfully submitted,



Vick Loomis, Asbestos Consultant
ATOKA, Inc.



Transmission Electron Microscopy Report

Analysis Method EPA Level II / 68-02-3266.

Preparation Method: Filters are carbon coated, plasma ashed to ten percent weight loss, and dissolved with acetone in both jaffe wick and condensate washer (coldfinger). All preps must be verified by another analyst.

Client Information:
Atoka, Inc.
2695 Airport Road
Hot Springs, AR 71913

Client Project:
AR DOT

CA Labs Project #:
CAL19042718AF

Date of Sampling: 4/26/19
Report Date: 5/2/19
Samples Received: 4/30/19 10:30am
Purchase Order #:

Phone: 501-623-1121
Fax: 501-623-2769

Turnaround Time: 3 Days
Attn:

| Sample# | Location – provided by client | Sample Volume L | # GO Analyzed | Asbestos Structures Detected <5um | Asbestos Structures Detected >5um | Non - Asbestos Structures / Identification | On-filter Concentration s/mm ² | Asbestos Concentration s/cc |
|---------|----------------------------------|-----------------------|------------------|-----------------------------------------|-----------------------------------------|--------------------------------------------------|-------------------------------------------------|-----------------------------------|
| T1 | Auditorium | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T2 | Rm 103 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T3 | Rm 102 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T4 | Lobby | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T5 | Mech Rm 1 st Floor | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T6 | Hall by Elevator | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T7 | Mech Rm Basement | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T8 | Vending Area | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T9 | Break Room | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |

All samples received in good condition unless noted.

| | | |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|
| Grid Opening Area: 0.0120 mm ² | Area Analyzed: 0.1200 mm ² | Analytical Sensitivity: 0.0026 s/cc |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|

NSD = No Structures Detected

NVLAP # 200349-0
TCEQ # T104704513-15-3
TDH # 30-0235

Approved Signatories:


Robert Olivarez
Analyst


Tanner Rasmussen
Technical Manager


Julio Robles
Senior Analyst

Page 1 of 1

Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates traceable to NIST standards for regulated asbestos types. Analysts' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. CA Labs is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for selected test methods for bulk asbestos fiber analysis (PLM) and airborne fiber analysis (TEM). CA Labs is accredited by the American Industrial Hygiene Association (AIHA LAP, LLC.) in the TEM asbestos field of testing for Industrial Hygiene. This test report relates only to the items tested. Neither NVLAP-AIHA, nor TCEQ accreditation implies endorsement by any US Government agency. This report may not be reproduced except in full without written permission from CA Labs. This method is not covered by the AIHA Industrial Hygiene scope of accreditation. The laboratory is not responsible for data collected by personnel who are not part of the laboratory. Results reported in both structures/mm² and structures/cc are dependent on the volume of air sampled and measured by non-laboratory personnel.

These results are submitted pursuant to CA Labs' current terms and condition of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee may be assessed for the return of any samples.



Transmission Electron Microscopy Report

Analysis Method EPA Level II / 68-02-3266.

Preparation Method: Filters are carbon coated, plasma ashed to ten percent weight loss, and dissolved with acetone in both jaffe wick and condensate washer (coldfinger). All preps must be verified by another analyst.

Client Information:
Atoka, Inc.
2695 Airport Road
Hot Springs, AR 71913

Client Project:
19-055, ARDOT

CA Labs Project #:
CAL19042719AG

Date of Sampling: 4/26/2019
Report Date: 5/2/2019

Phone: 501-623-1121
Fax: 501-623-2769

Turnaround Time: 3 days
Attn:

Samples Received: 4/30/19 10:30AM
Purchase Order #:

| Sample# | Location – provided by client | Sample Volume L | # GO Analyzed | Asbestos Structures Detected <5um | Asbestos Structures Detected >5um | Non - Asbestos Structures / Identification | On-filter Concentration s/mm ² | Asbestos Concentration s/cc |
|---------|----------------------------------|-----------------------|------------------|-----------------------------------------|-----------------------------------------|--------------------------------------------------|-------------------------------------------------|-----------------------------------|
| T-10 | East Hall | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-11 | Field Blank | 0 | 10 | NSD | NSD | NSD | ---- | ---- |
| T-12 | Mechanical Rm | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-13 | Hallway by Foundation | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-14 | Rm 203 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-15 | Rm 206 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-16 | Rm 207 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |

All samples received in good condition unless noted.

| | | |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|
| Grid Opening Area: 0.0120 mm ² | Area Analyzed: 0.1200 mm ² | Analytical Sensitivity: 0.0026 s/cc |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|

NSD = No Structures Detected

NVLAP # 200349-0
TCEQ # T104704513-15-3
TDH # 30-0235

Approved Signatories:

Robert Olivarez
Analyst

Page 1 of 1

Tanner Rasmussen
Technical Manager

Julio Robles
Senior Analyst

Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates (traceable to NIST standards for regulated asbestos types). Analysis' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. CA Labs is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for selected test methods for bulk asbestos fiber analysis (PLM) and airborne fiber analysis (TEM). CA Labs is accredited by the American Industrial Hygiene Association (AIHA L.A.P. LLC.) in the TEM asbestos field of testing for Industrial Hygiene. This test report relates only to the items tested. Neither NVLAP AIHA, nor TCEQ accreditation implies endorsement by any US Government agency. This report may not be reproduced except in full without written permission from CA Labs. This method is not covered by the AIHA Industrial Hygiene scope of accreditation. The laboratory is not responsible for data collected by personnel who are not part of the laboratory. Results reported in both structures/mm² and structures/cc are dependent on the volume of air sampled and measured by non-laboratory personnel.

These results are submitted pursuant to CA Labs' current terms and condition of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee may be assessed for the return of any samples.



Transmission Electron Microscopy Report

Analysis Method EPA Level II / 68-02-3266.

Preparation Method: Filters are carbon coated, plasma ashed to ten percent weight loss, and dissolved with acetone in both jaffe wick and condensate washer (coldfinger). All preps must be verified by another analyst.

Client Information:
Atoka, Inc.
2695 Airport Road
Hot Springs, AR 71913

Client Project:
19-055, ARDOT

CA Labs Project #:
CAL19042720AF

Date of Sampling: 4/27/19

Report Date: 5/2/19

Samples Received: 4/30/19 10:30am

Purchase Order #:

Phone: 501-623-1121
Fax: 501-623-2769

Turnaround Time: 3 Days
Attn:

| Sample# | Location – provided by client | Sample Volume L | # GO Analyzed | Asbestos Structures Detected <5um | Asbestos Structures Detected >5um | Non - Asbestos Structures / Identification | On-filter Concentration s/mm ² | Asbestos Concentration s/cc |
|---------|----------------------------------|-----------------------|------------------|-----------------------------------------|-----------------------------------------|--------------------------------------------------|-------------------------------------------------|-----------------------------------|
| T17 | Rm 301 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T18 | Rm 304 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T19 | Rm 308 West | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T20 | Rm 308 East | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T21 | Mech Rm | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T22 | Mechanical Rm | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T23 | Rm 402 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T24 | Rm 401 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |


All samples received in good condition unless noted.

| | | |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|
| Grid Opening Area: 0.0120 mm ² | Area Analyzed: 0.1200 mm ² | Analytical Sensitivity: 0.0026 s/cc |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|


NSD = No Structures Detected


NVLAP # 200349-0
TCEQ # T104704513-15-3
TDH # 30-0235

Approved Signatories:


Robert Olivarez
Analyst

Page 1 of 1


Tanner Rasmussen
Technical Manager


Julio Robles
Senior Analyst

Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates traceable to NIST standards for regulated asbestos types. Analysts' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. CA Labs is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for selected test methods for bulk asbestos fiber analysis (PLM) and airborne fiber analysis (TEM). CA Labs is accredited by the American Industrial Hygiene Association (AIHA LAP, LLC.) in the TEM asbestos field of testing for Industrial Hygiene. This test report relates only to the items tested. Neither NVLAP AIHA, nor TCEQ accreditation implies endorsement by any US Government agency. This report may not be reproduced except in full without written permission from CA Labs. This method is not covered by the AIHA Industrial Hygiene scope of accreditation. The laboratory is not responsible for data collected by personnel who are not part of the laboratory. Results reported in both structures/mm² and structures/cc are dependent on the volume of air sampled and measured by non-laboratory personnel.

These results are submitted pursuant to CA Labs' current terms and condition of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee may be assessed for the return of any samples.



Transmission Electron Microscopy Report

Analysis Method EPA Level II / 68-02-3266.

Preparation Method: Filters are carbon coated, plasma ashed to ten percent weight loss, and dissolved with acetone in both jaffe wick and condensate washer (coldfinger). All preps must be verified by another analyst.

Client Information:
Atoka, Inc.
2695 Airport Road
Hot Springs, AR 71913

Client Project:
19-055, ARDOT

CA Labs Project #:
CAL19042722AG

Date of Sampling: 4/27/2019

Report Date: 5/2/2019

Samples Received: 4/30/19 10:30AM

Purchase Order #:

Phone: 501-623-1121
Fax: 501-623-2769

Turnaround Time: 3 days
Attn:

| Sample# | Location – provided by client | Sample Volume L | # GO Analyzed | Asbestos Structures Detected <5um | Asbestos Structures Detected >5um | Non - Asbestos Structures / Identification | On-filter Concentration s/mm ² | Asbestos Concentration s/cc |
|---------|----------------------------------|-----------------------|------------------|-----------------------------------------|-----------------------------------------|--------------------------------------------------|-------------------------------------------------|-----------------------------------|
| T-25 | Rm 403 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-26 | Rm 406 SE Office | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-27 | Mechanical Rm | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-28 | 501 Center | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-29 | Rm 505 E Corner Office | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-30 | Rm 507 by Fridge | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-31 | Rm 510 Corner Office | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-32 | Hallway by Copier | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |

All samples received in good condition unless noted.

| | | |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|
| Grid Opening Area: 0.0120 mm ² | Area Analyzed: 0.1200 mm ² | Analytical Sensitivity: 0.0026 s/cc |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|

NSD = No Structures Detected

NVLAP # 200349-0
TCEQ # T104704513-15-3
TDH # 30-0235

Approved Signatories:

Robert Olivarez
Analyst

Page 1 of 1

Tanner Rasmussen
Technical Manager

Julio Robles
Senior Analyst

Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates traceable to NIST standards for regulated asbestos types. Analysts' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. CA Labs is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for selected test methods for bulk asbestos fiber analysis (PLM) and airborne fiber analysis (TEM). CA Labs is accredited by the American Industrial Hygiene Association (AIHA LAP, LLC.) in the TEM asbestos field of testing for Industrial Hygiene. This test report relates only to the items tested. Neither NVLAP AIHA, nor TCEQ accreditation implies endorsement by any US Government agency. This report may not be reproduced except in full without written permission from CA Labs. This method is not covered by the AIHA Industrial Hygiene scope of accreditation. The laboratory is not responsible for data collected by personnel who are not part of the laboratory. Results reported in both structures/mm² and structures/cc are dependent on the volume of air sampled and measured by non-laboratory personnel.

These results are submitted pursuant to CA Labs' current terms and condition of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee may be assessed for the return of any samples.



Transmission Electron Microscopy Report

Analysis Method EPA Level II / 68-02-3266.

Preparation Method: Filters are carbon coated, plasma ashed to ten percent weight loss, and dissolved with acetone in both jaffe wick and condensate washer (coldfinger). All preps must be verified by another analyst.

Client Information:
Atoka, Inc.
2695 Airport Road
Hot Springs, AR 71913

Client Project:
19-055, ARDOT

CA Labs Project #:
CAL19042721AG

Date of Sampling: 4/27/2019

Report Date: 5/2/2019

Samples Received: 4/30/19 10:30AM

Purchase Order #:

Phone: 501-623-1121
Fax: 501-623-2769

Turnaround Time: 3 days
Attn:

| Sample# | Location – provided by client | Sample Volume L | # GO Analyzed | Asbestos Structures Detected <5um | Asbestos Structures Detected >5um | Non - Asbestos Structures / Identification | On-filter Concentration s/mm ² | Asbestos Concentration s/cc |
|---------|----------------------------------|-----------------------|------------------|-----------------------------------------|-----------------------------------------|--------------------------------------------------|-------------------------------------------------|-----------------------------------|
| T-33 | Mechanical Rm | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-34 | Rm 602 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-35 | Rm 601 Break Room | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-36 | Rm 606 Center | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-37 | Rm 605 Center | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-38 | Rm 607 Entry | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-39 | Mechanical Rm | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |

All samples received in good condition unless noted.

| | | | | | |
|---------------------------|------------------------|-----------------------|------------------------|--------------------------------|-------------|
| Grid Opening Area: | 0.0120 mm ² | Area Analyzed: | 0.1200 mm ² | Analytical Sensitivity: | 0.0026 s/cc |
|---------------------------|------------------------|-----------------------|------------------------|--------------------------------|-------------|

NSD = No Structures Detected

NVLAP # 200349-0
TCEQ # T104704513-15-3
TDH # 30-0235

Approved Signatories:

Robert Olivarez
Analyst

Page 1 of 1

Tanner Rasmussen
Technical Manager

Julio Robles
Senior Analyst

Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates (traceable to NIST standards for regulated asbestos types). Analysis' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. CA Labs is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for selected test methods for bulk asbestos fiber analysis (PLM) and airborne fiber analysis (TEM). CA Labs is accredited by the American Industrial Hygiene Association (AIHA L.A.P., L.L.C.) in the TEM asbestos field of testing for Industrial Hygiene. This test report relates only to the items tested. Neither NVLAP AIHA, nor TCEQ accreditation implies endorsement by any US Government agency. This report may not be reproduced except in full without written permission from CA Labs. This method is not covered by the AIHA Industrial Hygiene scope of accreditation. The laboratory is not responsible for data collected by personnel who are not part of the laboratory. Results reported in both structures/mm² and structures/cc are dependent on the volume of air sampled and measured by non-laboratory personnel.

These results are submitted pursuant to CA Labs' current terms and condition of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee may be assessed for the return of any samples.

Analysis performed at Crisp Analytical Labs, LLC 1929 Old Denton Road Carrollton, TX 75006; phone (972) 242-2754, fax (972) 242-2798.



Transmission Electron Microscopy Report

Analysis Method EPA Level II / 68-02-3266.

Preparation Method: Filters are carbon coated, plasma ashed to ten percent weight loss, and dissolved with acetone in both jaffe wick and condensate washer (coldfinger). All preps must be verified by another analyst.

Client Information:
Atoka, Inc.
2695 Airport Road
Hot Springs, AR 71913

Client Project:
19-055, ARDOT

CA Labs Project #:
CAL19042723AG

Date of Sampling: 4/27/2019

Report Date: 5/3/2019

Samples Received: 4/30/19 10:30AM

Purchase Order #:

Phone: 501-623-1121
Fax: 501-623-2769

Turnaround Time: 3 days
Attn:

| Sample# | Location -- provided by client | Sample Volume L | # GO Analyzed | Asbestos Structures Detected <5um | Asbestos Structures Detected >5um | Non - Asbestos Structures / Identification | On-filter Concentration s/mm ² | Asbestos Concentration s/cc |
|---------|-----------------------------------|-----------------------|------------------|-----------------------------------------|-----------------------------------------|--------------------------------------------------|-------------------------------------------------|-----------------------------------|
| T-40 | Rm 701 Center | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-41 | 702/704 Center Hallway | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-42 | 705 W Wall | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-43 | Rm 708 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |
| T-44 | Rm 709 | 1232 | 10 | NSD | NSD | NSD | <8.33 | <0.0026 |

All samples received in good condition unless noted.

| | | | | | |
|---------------------------|------------------------|-----------------------|------------------------|--------------------------------|-------------|
| Grid Opening Area: | 0.0120 mm ² | Area Analyzed: | 0.1200 mm ² | Analytical Sensitivity: | 0.0026 s/cc |
|---------------------------|------------------------|-----------------------|------------------------|--------------------------------|-------------|

NSD = No Structures Detected

NVLAP # 200349-0
TCEQ # T104704513-15-3
TDH # 30-0235

Approved Signatories:


Robert Olivarez
Analyst


Tanner Rasmussen
Technical Manager


Julio Robles
Senior Analyst

Page 1 of 1

Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates traceable to NIST standards for regulated asbestos types. Analysts' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. CA Labs is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for selected test methods for bulk asbestos fiber analysis (PLM) and airborne fiber analysis (TEM). CA Labs is accredited by the American Industrial Hygiene Association (AIHA LAP, LLC.) in the TEM asbestos field of testing for Industrial Hygiene. This test report relates only to the items tested. Neither NVLAP AIHA, nor TCEQ accreditation implies endorsement by any US Government agency. This report may not be reproduced except in full without written permission from CA Labs. This method is not covered by the AIHA Industrial Hygiene scope of accreditation. The laboratory is not responsible for data collected by personnel who are not part of the laboratory. Results reported in both structures/mm² and structures/cc are dependent on the volume of air sampled and measured by non-laboratory personnel.

These results are submitted pursuant to CA Labs' current terms and condition of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee may be assessed for the return of any samples.



Transmission Electron Microscopy Report

Analysis Method EPA Level II / 68-02-3266.

Preparation Method: Filters are carbon coated, plasma ashed to ten percent weight loss, and dissolved with acetone in both jaffe wick and condensate washer (coldfinger). All preps must be verified by another analyst.

Client Information:
Atoka, Inc.
2695 Airport Road
Hot Springs, AR 71913

Client Project:
19-055, ARDOT

CA Labs Project #:
CAL19052882AG

Date of Sampling: 5/3/2019

Report Date: 5/9/2019

Samples Received: 5/7/19 10:30AM

Purchase Order #:

Phone: 501-623-1121
Fax: 501-623-2769

Turnaround Time: 3 days
Attn:

| Sample# | Location – provided by client | Sample Volume L | # GO Analyzed | Asbestos Structures Detected <5um | Asbestos Structures Detected >5um | Non - Asbestos Structures / Identification | On-filter Concentration s/mm ² | Asbestos Concentration s/cc |
|---------|----------------------------------|-----------------------|------------------|-----------------------------------------|-----------------------------------------|--------------------------------------------------|-------------------------------------------------|-----------------------------------|
| T-45 | Room 807 | 1262.8 | 10 | NSD | NSD | NSD | <8.33 | <0.0025 |
| T-46 | Hallway | 1262.8 | 10 | NSD | NSD | NSD | <8.33 | <0.0025 |
| T-47 | Room 802 | 1262.8 | 10 | NSD | NSD | NSD | <8.33 | <0.0025 |
| T-48 | Room 801 | 1262.8 | 10 | NSD | NSD | NSD | <8.33 | <0.0025 |
| T-49 | Mech Rm | 1262.8 | 10 | NSD | NSD | NSD | <8.33 | <0.0025 |


All samples received in good condition unless noted.

| | | |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|
| Grid Opening Area: 0.0120 mm ² | Area Analyzed: 0.1200 mm ² | Analytical Sensitivity: 0.0025 s/cc |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|

NSD = No Structures Detected


NVLAP # 200349-0
TCEQ # T104704513-15-3
TDH # 30-0235

Approved Signatories:


Robert Olivarez
Analyst

Page 1 of 1

Tanner Rasmussen
Technical Manager


Julio Robles
Senior Analyst

Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates traceable to NIST standards for regulated asbestos types. Analysts' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. CA Labs is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for selected test methods for bulk asbestos fiber analysis (PLM) and airborne fiber analysis (TEM). CA Labs is accredited by the American Industrial Hygiene Association (AIHA LAP, LLC.) in the TEM asbestos field of testing for Industrial Hygiene. This test report relates only to the items tested. Neither NVLAP AIHA, nor TCEQ accreditation implies endorsement by any US Government agency. This report may not be reproduced except in full without written permission from CA Labs. This method is not covered by the AIHA Industrial Hygiene scope of accreditation. The laboratory is not responsible for data collected by personnel who are not part of the laboratory. Results reported in both structures/mm² and structures/cc are dependent on the volume of air sampled and measured by non-laboratory personnel.

These results are submitted pursuant to CA Labs' current terms and condition of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee may be assessed for the return of any samples.



Transmission Electron Microscopy Report

Analysis Method EPA Level II / 68-02-3266.

Preparation Method: Filters are carbon coated, plasma ashed to ten percent weight loss, and dissolved with acetone in both jaffe wick and condensate washer (coldfinger). All preps must be verified by another analyst.

Client Information:
Atoka, Inc.
2695 Airport Road
Hot Springs, AR 71913

Client Project:
19-055, ARDOT

CA Labs Project #:
CAL19052880AG

Date of Sampling: 5/3/2019

Report Date: 5/9/2019

Samples Received: 5/7/19 10:30AM

Purchase Order #:

Phone: 501-623-1121
Fax: 501-623-2769

Turnaround Time: 3 days
Attn:

| Sample# | Location – provided by client | Sample Volume L | # GO Analyzed | Asbestos Structures Detected <5um | Asbestos Structures Detected >5um | Non - Asbestos Structures / Identification | On-filter Concentration s/mm ² | Asbestos Concentration s/cc |
|---------|----------------------------------|-----------------------|------------------|-----------------------------------------|-----------------------------------------|--------------------------------------------------|-------------------------------------------------|-----------------------------------|
| T-50 | Mech Rm | 1293.6 | 10 | NSD | NSD | NSD | <8.33 | <0.0025 |
| T-51 | Room 902 | 1293.6 | 10 | NSD | NSD | NSD | <8.33 | <0.0025 |
| T-52 | Room 904 | 1293.6 | 10 | NSD | NSD | NSD | <8.33 | <0.0025 |
| T-53 | Hallway | 1293.6 | 10 | NSD | NSD | NSD | <8.33 | <0.0025 |
| T-54 | Rm 907 | 1293.6 | 10 | NSD | NSD | NSD | <8.33 | <0.0025 |
| T-55 | Rm 908 | 1293.6 | 10 | NSD | NSD | NSD | <8.33 | <0.0025 |

All samples received in good condition unless noted.

| | | |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|
| Grid Opening Area: 0.0120 mm ² | Area Analyzed: 0.1200 mm ² | Analytical Sensitivity: 0.0025 s/cc |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|


NSD = No Structures Detected


NVLAP # 200349-0
TCEQ # T104704513-15-3
TDH # 30-0235

Approved Signatories:


Robert Olivarez
Analyst

Page 1 of 1



Tanner Rasmussen
Technical Manager


Julio Robles
Senior Analyst

Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates traceable to NIST standards for regulated asbestos types. Analysts' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. CA Labs is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for selected test methods for bulk asbestos fiber analysis (PLM) and airborne fiber analysis (TEM). CA Labs is accredited by the American Industrial Hygiene Association (AIHA LAP, LLC.) in the TEM asbestos field of testing for Industrial Hygiene. This test report relates only to the items tested. Neither NVLAP AIHA, nor TCEQ accreditation implies endorsement by any US Government agency. This report may not be reproduced except in full without written permission from CA Labs. This method is not covered by the AIHA Industrial Hygiene scope of accreditation. The laboratory is not responsible for data collected by personnel who are not part of the laboratory. Results reported in both structures/mm² and structures/cc are dependent on the volume of air sampled and measured by non-laboratory personnel.

These results are submitted pursuant to CA Labs' current terms and condition of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee may be assessed for the return of any samples.



Transmission Electron Microscopy Report

Analysis Method EPA Level II / 68-02-3266.

Preparation Method: Filters are carbon coated, plasma ashed to ten percent weight loss, and dissolved with acetone in both jaffe wick and condensate washer (coldfinger). All preps must be verified by another analyst.

Client Information:
Atoka, Inc.
2695 Airport Road
Hot Springs, AR 71913

Phone: 501-623-1121
Fax: 501-623-2769

Client Project:
19-055, ARDOT

Turnaround Time: 3 days
Attn:

CA Labs Project #:
CAL19052881AG

Date of Sampling: 5/3/2019
Report Date: 5/9/2019
Samples Received: 5/7/19 10:30AM
Purchase Order #:

| Sample# | Location – provided by client | Sample Volume L | # GO Analyzed | Asbestos Structures Detected <5um | Asbestos Structures Detected >5um | Non - Asbestos Structures / Identification | On-filter Concentration s/mm ² | Asbestos Concentration s/cc |
|---------|-----------------------------------|-----------------------|------------------|-----------------------------------------|-----------------------------------------|--------------------------------------------------|-------------------------------------------------|-----------------------------------|
| T-56 | Rm 1011 | 1155 | 10 | NSD | NSD | NSD | <8.33 | <0.0028 |
| T-57 | Rm 1008 | 1155 | 10 | NSD | NSD | NSD | <8.33 | <0.0028 |
| T-58 | Rm 1007 | 1155 | 10 | NSD | NSD | NSD | <8.33 | <0.0028 |
| T-59 | Rm 1002 | 1155 | 10 | NSD | NSD | NSD | <8.33 | <0.0028 |
| T-60 | Mech Rm 10 th Floor | 1155 | 10 | NSD | NSD | NSD | <8.33 | <0.0028 |

All samples received in good condition unless noted.

| | | |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|
| Grid Opening Area: 0.0120 mm ² | Area Analyzed: 0.1200 mm ² | Analytical Sensitivity: 0.0028 s/cc |
|--------------------------------------------------|----------------------------------------------|--------------------------------------------|

NSD = No Structures Detected


NVLAP # 200349-0
TCEQ # T104704513-15-3
TDH # 30-0235

Approved Signatories:


Robert Olivarez
Analyst

Page 1 of 1

Tanner Rasmussen
Technical Manager


Julio Robles
Senior Analyst

Notes:

Some samples (floor tiles, surfacing, etc.) may contain fibers too small to be detectable by PLM. TEM Chatfield analysis of bulk material is recommended in this case. All asbestos percentages are based on calibrated visual estimates traceable to NIST standards for regulated asbestos types. Analysts' percentages fall within a range of acceptable percentages, depending on the actual concentration of asbestos. CA Labs is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for selected test methods for bulk asbestos fiber analysis (PLM) and airborne fiber analysis (TEM). CA Labs is accredited by the American Industrial Hygiene Association (AIHA LAP, LLC.) in the TEM asbestos field of testing for Industrial Hygiene. This test report relates only to the items tested. Neither NVLAP AIHA, nor TCEQ accreditation implies endorsement by any US Government agency. This report may not be reproduced except in full without written permission from CA Labs. This method is not covered by the AIHA Industrial Hygiene scope of accreditation. The laboratory is not responsible for data collected by personnel who are not part of the laboratory. Results reported in both structures/mm² and structures/cc are dependent on the volume of air sampled and measured by non-laboratory personnel.

These results are submitted pursuant to CA Labs' current terms and condition of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee may be assessed for the return of any samples.

ATOKA, I

11701 I-30, Bldg. 1, Ste. 119
Little Rock, AR. 72209

ATOKA PROJECT: **19-055**

AIR DATA

Rotameter Calibration Date: **7/18**

Phone: (501) 455-1700
Fax: (501) 455-1864

Client/Company Name: **AR DOT**
 Address: **PO Box 2261**
LITTLE ROCK AR 72203

Contact Person: **Brian Byrum**

Phone/Fax: ph/fx

Project: **AR DOT** **CAU19042718**

Location: **10324 I-30**
LITTLE ROCK AR.

Calibrated & Collected by: **Vick hoomis**

Date: **4/26/19**

Purpose: **TEM Sampling**

Analyzed by:

Turnaround Requested:
 Immediate 3 days Rush 24 Hour
 48 Hour 3-5 Day Other

Sample Media
 Cassette: 25mm 37mm Tube

Soil: Grab Composite Water

Resp Protection 1/2 Face PAPR

Type C Full Face Other

PPG: Head Gloves Boots

Coverall Hood Other

Method: NIOSH 7400 - "A" Rules
 Other

Eff. Fiber Area 385 W/B Area 00785

| Sample # | Sample Type (See below) | Description | Start | Stop | Total Min | Flow | | | Volume Liters | Fibers Field | Coefficient of Variation | Fiber Conc. f/cc |
|------------|-------------------------|--------------------------|-------------|-------------|------------|------------|------------|------------|---------------|--------------|--------------------------|------------------|
| | | | | | | start | stop | ave | | | | |
| T-1 | | Audi: Tecium | 5:20 | 8:00 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |
| T-2 | | Am 103 | 5:20 | 8:00 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |
| T-3 | | Am 102 | 5:20 | 8:00 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |
| T-4 | | Lobby | 5:20 | 8:00 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |
| T-5 | | Mech Am 1st Floor | 5:20 | 8:00 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |
| T-6 | | Hall by Elevator | 5:52 | 8:32 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |
| T-7 | | Mech Am Basement | 5:52 | 8:32 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |
| T-8 | | Vending Area | 5:52 | 8:32 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |
| T-9 | | Beck Area | 5:52 | 8:32 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |

Relinquished by: **Caply Good** date/time: **4/26/19** Received by: **26** date/time: **10:30AM 4-30-19**

B = Ambient Background, NAB = Negative pressure filtration unit exhaust, NAI = Negative pressure filtration unit intake, DCI = Inside regulated work area at decontamination unit entrance, DCO = Outside regulated work area at decontamination unit entrance, OD = Outside regulated work area during abatement, FC = Final Clearance, AH = High volume area, AL = Low volume area, P = Personnel

ATOKA, J

11701 I-30, Bldg. 1, Ste. 119
Little Rock, AR. 72209

AIR SAMPLING DATA

ATOKA PROJECT: 19-055 Rotameter Calibration Date: 7/19

Phone: (501) 455-1700
Fax: (501) 455-1864

Client/Company Name: **ARDOT** Project: **ARDOT**

Address: **PO Box 2261**
Little Rock AR 72203

Location: **10324 I-30**
Little Rock AR

Contact Person: **Brian Bynum** Calibrated & Collected by: **Vick Loomis**

Phone/Fax: **ph/fx** Date: **4/26/19**

Purpose: **TEM Sampling**

Analyzed by:

Turnaround Requested:
Immediate Rush 24 Hour
48 Hour 3-5 Day Other

Sample Media
Cassette: 25mm 37mm 1tube

Soil: Grab Composite Water

Resp Protection 1/2 Face PAPR

Type C Full Face Other

PPB: Head Gloves Boots

Coverall Hood Other

Method: NIOSH 7400 - "A" Rules
Other

Eff. Fiber Area **385** W/B Area **00785**

| Sample # | Sample Type (See below) | Description | Start | Stop | Total Min | Flow | | | Volume Liters | Fibers Field | Coefficient of Variation | Fiber Conc. f/cc |
|-----------|----------------------------|---------------------|-------|------|-----------|-------|------|-----|---------------|--------------|--------------------------|------------------|
| | | | | | | start | stop | ave | | | | |
| T-10 | | East Hall | 5:52 | | | 7.7 | 7.7 | 7.7 | | | | |
| T-11 | | Field Blank | | | | | | | | | | |
| 2nd Floor | | | | | | | | | | | | |
| T-12 | | Mechanical Rm | 0800 | 1040 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |
| T-13 | | Hallway by fountain | 0800 | 1040 | 160 | 7.7 | 7.7 | 7.7 | | | | |
| T-14 | | Rm 203 | 0802 | 1042 | 160 | 7.7 | 7.7 | 7.7 | | | | |
| T-15 | | Rm 206 | 0803 | 1043 | 160 | 7.7 | 7.7 | 7.7 | | | | |
| T-16 | | Rm 207 | 0803 | 1043 | 160 | 7.7 | 7.7 | 7.7 | | | | |
| 3rd Floor | | | | | | | | | | | | |

Relinquished by: *[Signature]* date/time **4:29 PM** Received by: *[Signature]* date/time **10:30 AM 4-30-19**

B = Ambient Background, NAE = Negative pressure filtration unit exhaust, NAI = Negative pressure filtration unit intake, DCO = Inside regulated work area at decontamination unit entrance, DCO = Outside regulated work area at decontamination unit entrance, ID = Inside regulated work area during abatement, OD = Outside regulated work area during abatement, FC = Final Clearance, AH = High volume area, AL = Low volume area, P = Personnel

ATOKA, I

11701 I-30, Bldg. 1, Ste. 119
Little Rock, AR. 72209

AIR SAMPLING DATA

ATOKA PROJECT: 19-055 Rotameter Calibration Date:

Phone: (501) 455-1700
Fax: (501) 455-1864

Client/Company Name: **ARDDOT**

Address: **R.D. Box 22601
Little Rock AR. 72203**

Contact Person: **Brigyn Bynum**

Phone/Fax: ph/fx

Project: **ARDDOT**

Location: **.10324 1-30
Little Rock AR**

Calibrated & Collected by: **C. Roberts**

Date: **4.27.19**

Purpose: **TEM Sampling**

Analyzed by:

Turnaround Requested:
Immediate Rush 24 Hour
48 Hour 3-5 day Other

Sample Media
Cassette: 25mm 37mm Tube
Soil: Grab Composite Water

Resp Protection 1/2 Face PAPER
Type C Full Face Other
PPE: Head Gloves Boots
Overall Hood Other

Method: NIOSH 7400 - "A" Rules
Other

Eff. Fiber Area 385 W/B Area 00785

Test Requested/Special Lab Instructions: **PCM Fiber TEM**

| Sample # | Sample Type (See below) | Description | Start | Stop | Total Min | Flow | | Volume Liters | Fibers Field | Coefficient of Variation | Fiber Conc. f/cc |
|-----------|-------------------------|-------------|-------|------|-----------|-------|------|---------------|--------------|--------------------------|------------------|
| | | | | | | start | stop | | | | |
| T-17 | Rm 301 | | 0811 | 1051 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | |
| T-18 | Rm 304 | | 0811 | 1051 | 160 | 7.7 | 7.7 | 7.7 | | | |
| T-19 | Rm 308 - West | | 0813 | 1053 | 160 | 7.7 | 7.7 | 7.7 | | | |
| T-20 | Rm 308 - East | | 0813 | 1053 | 160 | 7.7 | 7.7 | 7.7 | | | |
| T-21 | | | 0815 | 1055 | 160 | 7.7 | 7.7 | 7.7 | | | |
| 4th Floor | | | | | | | | | | | |
| T-22 | mechanical Rm | | 1110 | 1350 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | |
| T-23 | Rm 402 | | 1110 | 1350 | 160 | 7.7 | 7.7 | 7.7 | | | |
| T-24 | Rm 401 | | 1113 | 1353 | 160 | 7.7 | 7.7 | 7.7 | | | |

Relinquished by: *Andy Scott* date/time **4-27-19** Received by: *[Signature]* date/time **4-30-19**

B = Ambient Background, NAE = Negative pressure filtration unit exhaust, NAI = Negative pressure filtration unit intake, DCI = Inside regulated work area at decontamination unit entrance, DCO = Outside regulated work area at decontamination unit entrance, ID = Inside regulated work area during abatement, OD = Outside regulated work area during abatement, FC = Final Clearance, AH = High volume area, AL = Low volume area, P = Personnel

ATOKA, J

11701 I-30, Bldg. 1, Ste. 119
Little Rock, AR. 72209

ATOKA PROJECT:

Client/Company Name: **AROOT**

Address: **P.O. Box 22461
Little Rock AR 72203**

Contact Person: **Brian Bynum**

Phone/Fax: **pb/fx**

Test Requested/Special Lab Instructions: **PCM Fiber TEM**

AIR SAMPLING DATA

19-055 Rotameter Calibration Date:

Project: **ARDOT CAU9040122**

Location: **10324 I-30
Little Rock AR**

Calibrated & Collected by: **C. Roberts**

Date: **4 27 19**

Purpose: **TEM sampling**

Analyzed by:

| Sample # | Sample Type (See below) | Description | Start | Stop | Total Min | Flow | | | Volume Liters | Fibers Field | Coefficient of Variation | Fiber Conc. f/cc |
|-----------|----------------------------|----------------------|-------|------|-----------|-------|------|-----|---------------|--------------|--------------------------|------------------|
| | | | | | | start | stop | ave | | | | |
| T-25 | | Rm 403 | 1113 | 1353 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |
| T-26 | | Rm 406 G.E. Office | 1116 | 1356 | 160 | 7.7 | 7.7 | 7.7 | 1 | | | |
| 5th floor | | | | | | | | | | | | |
| T-27 | | mechanical Rm | 1125 | 1405 | 160 | 7.7 | 7.7 | 7.7 | 1232 | | | |
| T-28 | | 501 Center | 1127 | 1407 | 160 | 7.7 | 7.7 | 7.7 | | | | |
| T-29 | | Rm 505 E Connector | 1130 | 1410 | 160 | 7.7 | 7.7 | 7.7 | | | | |
| T-30 | | Rm 507 by fridge | 1132 | 1412 | 160 | 7.7 | 7.7 | 7.7 | | | | |
| T-31 | | Rm 510 Carter Office | 1136 | 1416 | 160 | 7.7 | 7.7 | 7.7 | | | | |
| T-32 | | Hallway by copier | 1136 | 1416 | 160 | 7.7 | 7.7 | 7.7 | | | | |

Relinquished by: **J. Lab** date/time **7-29-19** Received by: **J. Lab** date/time **6:30 AM 4-30-19**

B = Ambient Background, NAE = Negative pressure filtration unit exhaust, DCI = Inside regulated work area at decontamination unit entrance, DCO = Outside regulated work area at decontamination unit entrance, ID = Inside regulated work area during abatement, OD = Outside regulated work area during abatement, FC = Final Clearance, AH = High volume area, AL = Low volume area, P = Personnel

Turnaround Requested:
Immediate 30 day Rush 24 Hour
48 Hour 3-5 Day Other _____
Sample Media
Cassette: 25mm 37mm Tube _____
Soil: Grab _____ Composite _____ Water _____
Resp Protection 1/2 Face _____ PAPR _____
Type C _____ Full Face _____ Other _____
PPE: Head _____ Gloves _____ Boots _____
Coverall _____ Hood _____ Other _____
Method: NIOSH 7400 - "A" Rules
Other _____
Eff. Fiber Area 385 W/B Area 00785

Phone: (501) 455-1700
Fax: (501) 455-1864

ATOKA, I

11701 I-30, Bldg. 1, Ste. 119
Little Rock, AR. 72209

AIR SAMPLING DATA

Phone: (501) 455-1700
Fax: (501) 455-1864

ATOKA PROJECT: 19-055 Rotameter Calibration Date:

| | |
|-----------------------------------------------------------------|---------------------------------------------------|
| Client/Company Name: <u>ARDOT</u> | Project: <u>ARDOT</u> |
| Address: <u>P.O. Box 22461</u> <u>Little Rock AR. 72203</u> | <u>CAL 19042721</u> |
| Contact Person: <u>Brian Bynum</u> | Location: <u>10324 I-30</u> <u>Little Rock</u> |
| Phone/Fax: <u>ph/tx</u> | Calibrated & Collected by: <u>C. Roberts</u> |
| Test Requested/Special Lab Instructions: <u>PCM-Fiber (TEM)</u> | Date: <u>4.27.19</u> |
| | Purpose: <u>TEM Sampling</u> |
| | Analyzed by: |

| Sample # | Sample Type (See below) | Description | Start | Stop | Total Min | Flow | | | Volume Liters | Fibers Field | Coefficient of Variation | Fiber Conc. f/cc |
|-------------------|----------------------------|--------------------------|-------------|-------------|------------|------------|------------|------------|---------------|--------------|--------------------------|------------------|
| | | | | | | start | stop | ave | | | | |
| <u>14th floor</u> | | | | | | | | | | | | |
| <u>T-33</u> | | <u>Mechanical Rm</u> | <u>1430</u> | <u>1710</u> | <u>160</u> | <u>7.7</u> | <u>7.7</u> | <u>7.7</u> | <u>1832</u> | | | |
| <u>T-34</u> | | <u>Rm 6002</u> | <u>1432</u> | <u>1712</u> | <u>160</u> | <u>7.7</u> | <u>7.7</u> | <u>7.7</u> | | | | |
| <u>T-35</u> | | <u>Rm 601 Break Room</u> | <u>1433</u> | <u>1713</u> | <u>140</u> | <u>7.7</u> | <u>7.7</u> | <u>7.7</u> | | | | |
| <u>T-36</u> | | <u>Rm 606 Center</u> | <u>1436</u> | <u>1716</u> | <u>160</u> | <u>7.7</u> | <u>7.7</u> | <u>7.7</u> | | | | |
| <u>T-37</u> | | <u>Rm 605 Center</u> | <u>1440</u> | <u>1720</u> | <u>160</u> | <u>7.7</u> | <u>7.7</u> | <u>7.7</u> | | | | |
| <u>T-38</u> | | <u>Rm 607 Entry</u> | <u>1443</u> | <u>1723</u> | <u>160</u> | <u>7.7</u> | <u>7.7</u> | <u>7.7</u> | | | | |
| <u>7th floor</u> | | | | | | | | | | | | |
| <u>T-39</u> | | <u>Mechanical Rm</u> | <u>1450</u> | <u>1730</u> | <u>160</u> | <u>7.7</u> | <u>7.7</u> | <u>7.7</u> | <u>1832</u> | | | |

Relinquished by: Andy Leach date/time: 7-29-19 Received by: [Signature] 10:30AM 4-30-19 date/time:

B = Ambient Background, NAE = Negative pressure filtration unit exhaust, NAI = Negative pressure filtration unit intake, DCI = Inside regulated work area at decontamination unit entrance, DCO = Outside regulated work area at decontamination unit entrance, IDI = Inside regulated work area during abatement, ODI = Outside regulated work area during abatement, FC = Final Clearance, AH = High volume area, AL = Low volume area, P = Personnel

AIR SAMPLING DATA

ATOKA, I

11701 I-30, Bldg. 1, Ste. 119
Little Rock, AR. 72209

ATOKA PROJECT: 19-055

Rotameter Calibration Date:

Phone: (501) 455-1700
Fax: (501) 455-1864

| Client/Company Name: ARDOT | | Project: ARDOT | | CAL 19042723 | | | | | | | |
|--------------------------------------------------------|----------------------------|---------------------------------------|-------|--------------|-----------|-------|----------|---------------|--------------|--------------------------|------------------|
| Address: P.O. Box 2261 Little Rock AR. 72203 | | Location: 10324 I-30 Little Rock | | | | | | | | | |
| Contact Person: Brian Bynum | | Calibrated & Collected by: C. Roberts | | | | | | | | | |
| Phone/Fax: ph/fix | | Date: 4.27.19 | | | | | | | | | |
| Test Requested/Special Lab Instructions: PCM Fiber TEM | | Purpose: TEM Sampling | | | | | | | | | |
| Analyzed by: | | | | | | | | | | | |
| Sample # | Sample Type (See below) | Description | Start | Stop | Total Min | Flow | | Volume Liters | Fibers Field | Coefficient of Variation | Fiber Conc. f/cc |
| | | | | | | start | stop ave | | | | |
| T-40 | | Rm 701 Center | 1452 | 1732 | 160 | 7.7 | 7.7 | 1232 | | | |
| T-41 | | 702/709 Center Highway | 1454 | 1734 | 160 | 7.7 | 7.7 | | | | |
| T-42 | | 705 W. Wall | 1457 | 1737 | 160 | 7.7 | 7.7 | | | | |
| T-43 | | Rm 708 | 1457 | 1737 | 160 | 7.7 | 7.7 | | | | |
| T-44 | | Rm 709 | 1500 | 1740 | 160 | 7.7 | 7.7 | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |

Turnaround Requested:
Immediate _____
Rush _____ 24 Hour _____
48 Hour 3-5 Day _____ Other _____

Sample Media
Cassette: 25mm _____ 37mm _____ Tube _____

Soil: Grab _____ Composite _____ Water _____

Resp Protection 1/2 Face _____ PAPP _____

Type C _____ Full Face _____ Other _____

PPF: Head _____ Gloves _____ Boots _____

Coverall _____ Hood _____ Other _____

Method: NIOSH 7400 "A" Rules
Other _____

Eff. Fiber Area 385 W/B Area .00785

Relinquished by: *[Signature]* date/time: 4-29-19 Received by: *[Signature]* date/time: 10:30AM 4-30-19

B = Ambient Background, NAE = Negative pressure filtration unit exhaust, NAI = Negative pressure filtration unit intake, DCI = Inside regulated work area at decontamination unit entrance, DCO = Outside regulated work area at decontamination unit entrance, OD = Outside regulated work area during abatement, ID = Inside regulated work area during abatement, FC = Final Clearance, AH = High volume area, AL = Low volume area, P = Personnel

AIR SAMPLING DATA

ATOKA, I
11701 I-30, Bldg 1, Ste. 119
Little Rock, AR. 72209

ATOKA PROJECT:

Phone: (501) 455-1700
Fax: (501) 455-1864

Rotameter Calibration Date: 7/18

| Client/Company Name: AR DOT | | Project: AR DOT | | Turnaround Requested: Immediate <input type="checkbox"/> Rush <input checked="" type="checkbox"/> 24 Hour <input type="checkbox"/> 48 Hour <input type="checkbox"/> 3-5 Day <input type="checkbox"/> Other <input type="checkbox"/> | | | | | | | | |
|---------------------------------------------------------------|----------------------------|---------------------------------------------------|-------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------|-------|------|-----|---------------|--------------|--------------------------|------------------|
| Address: PO Box 2261 Little Rock AR. 72203 | | Location: 10324 I-30 Little Rock AR | | Sample Media Cassette: 25mm <input type="checkbox"/> 37mm <input type="checkbox"/> Tube <input type="checkbox"/> Soil: Grab <input type="checkbox"/> Composite <input type="checkbox"/> Water <input type="checkbox"/> | | | | | | | | |
| Contact Person: Brian Bynum | | Calibrated & Collected by: Vick Loomis | | Resp Protection 1/2 Face <input type="checkbox"/> PAPR <input type="checkbox"/> Type C <input type="checkbox"/> Full Face <input type="checkbox"/> Other <input type="checkbox"/> | | | | | | | | |
| Phone/Fax: ph/fx | | Date: 5/3/19 | | PPE: Head <input type="checkbox"/> Gloves <input type="checkbox"/> Boots <input type="checkbox"/> Coverall <input type="checkbox"/> Hood <input type="checkbox"/> Other <input type="checkbox"/> | | | | | | | | |
| Test Requested/Special Lab Instructions: PCM Fiber TEM | | Purpose: TEM Sampling | | Method: NIOSH 7400 - "A" Rules Other <input type="checkbox"/> | | | | | | | | |
| Analyzed by: | | Eff. Fiber Area 385 W/B Area .00785 | | | | | | | | | | |
| Sample # | Sample Type (See below) | Description | Start | Stop | Total Min | Flow | | | Volume Liters | Fibers Field | Coefficient of Variation | Fiber Conc. f/cc |
| | | | | | | start | stop | ave | | | | |
| T-50 | TEM | Mech Am | 5:51 | 8:39 | 168 | 7.7 | 7.7 | 7.7 | 1293.6 | | | |
| T-51 | TEM | Room 902 | 5:51 | 8:39 | 168 | 7.7 | 7.7 | 7.7 | 1293.6 | | | |
| T-52 | TEM | Room 904 | 5:51 | 8:39 | 168 | 7.7 | 7.7 | 7.7 | 1293.6 | | | |
| T-53 | TEM | Hallway | 5:51 | 8:39 | 168 | 7.7 | 7.7 | 7.7 | 1293.6 | | | |
| T-54 | TEM | Room 907 | 5:51 | 8:39 | 168 | 7.7 | 7.7 | 7.7 | 1293.6 | | | |
| T-55 | TEM | Room 908 | 5:51 | 8:39 | 168 | 7.7 | 7.7 | 7.7 | 1293.6 | | | |

Relinquished by: **Vick Loomis** date/time: _____ Received by: _____ date/time: _____

Legend:
 Ambient Background, NAE=Negative pressure filtration unit exhaust, NAI=Negative pressure filtration unit intake, DCI=Inside regulated work area at decontamination unit entrance, DCO=Outside regulated work area at decontamination unit entrance, ID=Inside regulated work area during abatement, OD=Outside regulated work area during abatement, FC=Final Clearance, AH=High volume area, AL=Low volume area, P=Personnel

AIR SAMPLING DATA

ATOKA, J
11701 I-30, Box 1, Ste. 119
Little Rock, AR. 72209

Phone: (501) 455-1700
Fax: (501) 455-1864

Rotameter Calibration Date: 7/18

ATOKA PROJECT:

Project: **AR DOT**

Location: **10324 I-30
Little Rock AR**

Calibrated & Collected by: **Vick Loomis**

Date: **5/3/19**

Purpose: **TEM Sampling**

Analyzed by:

Client/Company Name: **AR DOT**

Address: **PO Box 2261
Little Rock AR. 72203**

Contact Person: **Brian Bynum**

Phone/Fax: ph/fx

Test Requested/Special Lab Instructions: **PCM Fiber TEM**

Turnaround Requested:
Immediate _____ Rush _____ 24 Hour _____
48 Hour 3-5 Day _____ Other _____

Sample Media
Cassette: 25mm _____ 37mm _____ Tube _____

Soil: Grab _____ Composite _____ Water _____

Resp Protection 1/2 Face _____ PAPER _____
Type C _____ Full Face _____ Other _____

PPE: Head _____ Gloves _____ Boots _____
Coverall _____ Hood _____ Other _____

Method: NIOSH 7400 - "A" Rules
Other _____

Eff. Fiber Area 385 _____ W/B Area 00785 _____

| Sample # | Sample Type (See below) | Description | Start | Stop | Total Min | Flow | | | Volume Liters | Fibers Field | Coefficient of Variation | Fiber Conc. f/cc |
|----------|----------------------------|--------------------------------|-------|-------|-----------|-------|------|-----|---------------|--------------|--------------------------|------------------|
| | | | | | | start | stop | ave | | | | |
| T-56 | TEM | Am 1011 | 8:30 | 11:00 | 150 | 7.7 | 7.7 | 7.7 | 1155 | | | |
| T-57 | | Am 1008 | 8:30 | 11:00 | 150 | 7.7 | 7.7 | 7.7 | 1155 | | | |
| T-58 | | Am 1007 | 8:30 | 11:00 | 150 | 7.7 | 7.7 | 7.7 | 1155 | | | |
| T-59 | | Am 1002 | 8:30 | 11:00 | 150 | 7.7 | 7.7 | 7.7 | 1155 | | | |
| T-60 | | Mech RA 10 th Floor | 8:30 | 11:00 | 150 | 7.7 | 7.7 | 7.7 | 1155 | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |

Relinquished by: **Vick Loomis** date/time: _____ Received by: _____ date/time: _____

Legend:
 = Ambient Background, NAE=Negative pressure filtration unit exhaust, DCI=Inside regulated work area at decontamination unit entrance, DCO=Outside regulated work area at decontamination unit entrance, ID=Inside regulated work area during abatement, OD= Outside regulated work area during abatement, FC=Final Clearance, AH=High volume area, AL=Low volume area, P=Personnel

Arkansas Department of Environmental Quality

ATOKA, INC.

is a licensed

Asbestos Abatement Consultant

having qualified as required by law in accordance with the regulations adopted by the Arkansas Pollution Control and Ecology Commission's Regulation 21 pursuant to Arkansas Code Annotated §20-27-1001 et seq., relative to abatement of asbestos-containing material within the state of Arkansas.



License Number: 000242

Issue Date: 12/13/2018

Expire Date: 12/13/2019

A handwritten signature in cursive script, reading "Becky W. Keogh".

Becky W. Keogh
ADEQ Director

Arkansas Department of Environmental Quality

VICK LOOMIS

having satisfied the requirements necessary to meet the provisions of AHERA/ASHARA under TSCA Title II and the Arkansas Pollution Control and Ecology Commission's Regulation 21 and is hereby certified in the State of Arkansas in the discipline(s) of Asbestos

| Discipline | Issue Date | Effective Date | Expiration Date |
|------------------|------------|----------------|-----------------|
| Air Monitor | 01/08/2019 | 01/23/2019 | 01/31/2020 |
| Inspector | 01/09/2019 | 01/23/2019 | 01/31/2020 |
| Project Designer | 11/28/2018 | 12/13/2018 | 11/30/2019 |



Certification Number: **008695**

Becky W. Keogh
Becky W. Keogh
ADEQ Director

Arkansas Department of Environmental Quality

CARRIE L. ROBERTS

having satisfied the requirements necessary to meet the provisions of AHERA/ASHARA under TSCA Title II and the Arkansas Pollution Control and Ecology Commission's Regulation 21 and is hereby certified in the State of Arkansas in the discipline(s) of Asbestos

| Discipline | Issue Date | Effective Date | Expiration Date |
|-----------------------|------------|----------------|-----------------|
| Contractor Supervisor | 03/25/2019 | 04/11/2019 | 03/31/2020 |
| Inspector | 03/27/2019 | 04/11/2019 | 03/31/2020 |



Certification Number: **017397**

Becky W. Keogh

Becky W. Keogh
ADEQ Director



#9 Remington Cove
Little Rock, Arkansas 72204
Phone: 501-562-3818
Fax: 501-562-5701
Toll Free: 1-800-530-7706

Asbestos Sampling

To: Phillip Watkins
ARDOT
10324 Interstate I-30
Little Rock, AR

From: Gary Nooner

Email: phillip.watkins@ardot.gov

Fax:

Date: March 9, 2026

Phone: 501-569-4950

Cell: 501-351-0488

Pages: 17 Including cover sheet

Re: Elevator Lobby Sampling
ARDOT

cc:

Comments



#9 Remington Cove
Little Rock, Arkansas 72204
501-562-3818
Fax 501-562-5701

March 9, 2026

ARDOT
10324 Interstate I-30
Little Rock, AR

RE: Asbestos Sampling

Elevator Lobby Sampling
ARDOT
10324 Interstate I-30
Little Rock, AR

Mr. Phillip Watkins

On March 4, 2026 at your request I collected samples from the above referenced location to determine if asbestos was present.
One (1) samples were collected for laboratory analysis.

Laboratory analysis of these samples have determined the following:

Asbestos Detected in the following Materials

| | Description | Location | |
|--------------------|--------------------|---------------------------------------|------------------|
| Sample # 01 | Fire Proofing | 10 th Floor Elevator Lobby | Approx. 200 Sft. |

Our site visit involved accessing the area above the lay in ceiling tile in the elevator lobbies: Basement, 1st, 2nd, 3rd, 4th, 5th, 6th, 7th, 8th, 9th, 10th Floors
It was determined that the Fire Proofing is only located on the 10th floor (approximately 1/3 of the Area) see pictures and drawing.

Federal and state regulations with the exception of OSHA, determine a material to be asbestos containing if it contains 1% or more asbestos.
OSHA states that any amount is an asbestos material.

Therefore the following materials must be removed by a licensed asbestos contractor if disturbed by renovation or demolition.



Fire Proofing - 10th Floor Elevator Lobby

For further clarification of the Arkansas asbestos regulation 21. You may contact the Arkansas Department of Environmental Quality (ADEQ)
Phone - 501-682-0718 or visit their website at - www.adeg.state.ar.us

I have attached my chain of custody and laboratory findings. Please contact me with any Questions you may have.

Sincerely,

Gary Nooner
Inspector
License No. 005065




ARDOT

 *Asbestos Containing Fire Proofing*

CA Labs
Dedicated to Quality

Crisp Analytical, L.L.C.
1929 Old Denton Road
Carrollton, TX 75006
Phone 972-242-2754
Fax 972-242-2798



CA Labs, L.L.C.
12232 Industriplex, Suite 32
Baton Rouge, LA 70809
Phone 225-751-5632
Fax 225-751-5634

Materials Characterization - Bulk Asbestos Analysis

Laboratory Analysis Report - Polarized Light

Environmental Protection Associates

#9 Remington Cove
Little Rock, AR 72204

Attn: Gary Nooner

Customer Project: Elevator Lobby Sampling

Reference #: CAL26031776AG **Date:** 03/09/26

Analysis and Method

Summary of polarized light microscopy (PLM / Stereomicroscopy bulk asbestos analysis) using the methods described in 40CFR Part 763 Appendix E to Subpart E (Interim and EPA 600 / R-93 / 116 (Improved). The sample is first viewed with the aid of a stereomicroscope. Numerous liquid slide preparations are created for analysis under the polarized microscope where identifications and quantifications are performed. Calibrated liquid refractive oils are used as liquid mounting medium. These oils are used for identification (dispersion staining). A calibrated visual estimation is reported, should any asbestiform mineral be present. Other techniques such as acid washing are used in conjunction with refractive oils for detection of smaller quantities of asbestos. All asbestos percentages are based on calibrated visual estimation traceable to NIST standards for regulated asbestos. Traceability to measurement and calibration is achieved by using known amounts and types of asbestos from standards where analyst and laboratory accuracy are measured. As little as 0.001% asbestos can be detected in favorable samples, while detection in unfavorable samples may approach the detection limit of 0.50% (well above the laboratory definition of trace).

Discussion

Vermiculite containing samples may contain trace amounts of actinolite/tremolite. When not detected by PLM, these samples should be analyzed using TEM methods and / or water separation techniques. Suspected actinolite/vermiculite presence will be indicated through the sample comment section of this report.

Fibrous talc containing samples may contain a regulated asbestos fiber known as anthophyllite. Under certain conditions the same fiber may actually contain both talc and anthophyllite (a phenomenon called intergrowth). Again, TEM detection methods are recommended. CA Labs PLM report comments will denote suspected amounts of asbestiform anthophyllite with talc, where further analysis is recommended.

Some samples (floor tiles, surfacings, etc.) may contain fibers too small to be detectable by PLM analysis and should be analyzed by TEM bulk protocols.

A "trace asbestos" will be reported if the analyst observes far less than 1% asbestos. CA Labs defines "trace asbestos" as a few fibers detected by the analyst in several preparations and will indicate as such under these circumstances.

Since allowable variation in quantification of samples close to 1% is high, <1% may be reported. Such results are ideal for point counting, and the technique is mandatory for friable samples (NESHAP, Nov. 1990 and clarification letter 8 May 1991) under 1% percent asbestos or "trace asbestos". **In order to make all initial PLM reports issued from CA Labs NESHAP compliant, all <1% asbestos results (except floor tiles) will be point counted at no additional charge.**

Qualifications

CA Labs is accredited by the National Voluntary Accreditation Program (NVLAP) for selected test methods for airborne fiber analysis (TEM), and for bulk asbestos fiber analysis (PLM). CA Labs is also accredited by AIHA LAP, LLC. in the PLM asbestos field of testing for Industrial Hygiene. All analysts have completed college courses or hold a degree in a natural science (geology, biology, or environmental science). Recognition by a state professional board in one these disciplines is preferred, but not required. Extensive in-house training programs are used to augment the educational background of the analyst. The Laboratory Director and Quality Manager have received supplemental McCrone Research training for asbestos identification. Analysis performed at Crisp Analytical Labs, LLC 1929 Old Denton Road Carrollton, TX 75006

Dallas NVLAP Lab Code 200349-0 TEM/PLM TDSHS 30-0235
AIHA LAP, LLC Laboratory #102929

Overview of Project Sample Material Containing Asbestos

| Customer Project: | | Elevator Lobby Sampling | | | CA Labs Project #: CAL26031776AG | |
|----------------------|----------|-------------------------|---------------------------------------------|----------------------------------------------------|------------------------------------------|--|
| Laboratory Sample ID | Sample # | Layer # | Analysts Physical Description of Subsample | Asbestos type / calibrated visual estimate percent | List of Affected Building Material Types | |
| 21420 | 01 | 1-1 | Fireproofing/ off-white fireproofing | 11% Chrysotile | off-white fireproofing | |

Dallas NVLAP Lab Code 200349-0 TEM/PLM TDSHS 30-0235
AIHA LAP, LLC Laboratory #102929

Glossary of abbreviations (non-asbestos fibers and non-fibrous minerals):

| | | | |
|------------------|--------------|--------------------|--------------------------|
| ca - carbonate | pe - perlite | fg - fiberglass | pa - palygorskite (clay) |
| gypsum - gypsum | qu - quartz | mw - mineral wool | |
| bi - binder | | wo - wollastinite | |
| or - organic | | ta - talc | |
| ma - matrix | | sy - synthetic | |
| mi - mica | | ce - cellulose | |
| ve - vermiculite | | br - brucite | |
| ot - other | | ka - kaolin (clay) | |

This report relates to the items tested as received. This report is not to be used by the customer to claim product certification, approval or endorsement by NVLAP, NIST, AIHA LAP, LLC, or any other agency of the federal government. This report may not be reproduced except in full without written permission from CA Labs. These results are submitted pursuant to CA Labs' current terms and sale, condition of sale, including the company's standard warranty and limitations of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety (90) days before discarding. A shipping or handling fee may be assessed for the return of any samples.

CA Labs
Dedicated to Quality

Crisp Analytical, L.L.C.
1929 Old Denton Road
Carrollton, TX 75006
Phone 972-242-2754
Fax 972-242-2798

CA Labs, L.L.C.
12232 Industriplex, Suite 32
Baton Rouge, LA 70809
Phone 225-751-5632
Fax 225-751-5634

Polarized Light Asbestiform Materials Characterization

| | | | |
|--------------------------------------------|-------------------|--------------------------|-------------------------------|
| Customer Info: | Attn: Gary Nooner | Customer Project: | CA Labs Project #: |
| Environmental Protection Associates | | Elevator Lobby Sampling | CAL26031776AG |
| #9 Remington Cove Little Rock, AR 72204 | | Turnaround Time: | Date: 3/9/2026 |
| | | 24 hour | Samples Rec'd: 3/6/26 10:30AM |
| Phone # | 501-562-3818 | | Date Of Sampling: 3/4/2026 |
| Fax # | | | Purchase Order #: |

| Laboratory Sample ID | Sample # | Com ment | Layer # | Analysts Physical Description of Subsample | Homo-geneo us (Y/N) | Asbestos type / calibrated visual estimate percent | Non-asbestos fiber type / percent | Non-fibrous type / percent |
|----------------------|----------|----------|---------|---------------------------------------------|---------------------|----------------------------------------------------|-----------------------------------|----------------------------|
| 21420 | 01 | | 1-1 | Fireproofing/ off-white fireproofing | y | 11% Chrysotile | 10% ce | 79% qu,ca,ma |

Dallas NVLAP Lab Code 200349-0 TEM/PLM TDSHS 30-0235

AIHA LAP, LLC Laboratory #102929

Analysis Method: Interim (40CFR Part 763 Appendix E to Subpart E) / Improved (EPA-600 / R-93/116). *All samples received in good condition unless noted.*
Preparation Method: HCL acid washing for carbonate based samples, chemical reduction for organically bound components, oil immersion for identification of asbestos types by dispersion attaining / becke line method.


| | | | |
|----------------|------------------|-------------------|--------------------------|
| ca - carbonate | mi - mica | fg - fiberglass | ce - cellulose |
| gy - gypsum | ve - vermiculite | mw - mineral wool | br - brucite |
| bi - binder | ot - other | wo - wollastonite | ka - kaolin (clay) |
| or - organic | pe - perlite | ta - talc | pa - palygorskite (clay) |
| ma - matrix | qu - quartz | sy - synthetic | |

Approved Signatories:



Josh Strange
Analyst

1. Fire Damage significant fiber damage - reported percentages reflect unaltered fibers
2. Fire Damage no significant fiber damages effecting fibrous percentages
3. Actinolite in association with Vermiculite
4. Layer not analyzed - attached to previous positive layer and contamination is suspected
5. Not enough sample to analyze



C.T. Ren
Technical Manager
Tanner Rasmussen

Senior Analyst
Julio Robles

6. Anthophyllite in association with Fibrous Talc
7. Contamination suspected from other building materials
8. Favorable scenario for water separation on vermiculite for possible analysis by another method
9. < 1% Result point counted positive
10. TEM analysis suggested



Elevator Lobby 1st Floor



Elevator Lobby Basement



Elevator Lobby 3rd Floor



Elevator Lobby 2nd Floor



Elevator Lobby 5th Floor



Elevator Lobby 4th Floor



Elevator Lobby 7th Floor



Elevator Lobby 6th Floor



Elevator Lobby 9th Floor



Elevator Lobby 8th Floor



Elevator Lobby 10th Floor

ARKANSAS DIVISION OF ENVIRONMENTAL QUALITY
ASBESTOS PROGRAM



GARY NOONER

has satisfied the requirements of AHERA/ASHARA under TSCA Title II, and those of Rule 21 of the Arkansas Pollution Control and Ecology Commission, pursuant to Ark. Code Ann. § 20-27-1001 *et seq.*, and is hereby certified to perform certain asbestos-related work, within the State of Arkansas, in the following discipline(s):

| Discipline | Expiration Date |
|----------------------|-----------------|
| Proj Designer | 12/31/2026 |
| Inspector..... | 12/31/2026 |
| Air Monitor | 12/31/2026 |
| Contractor/Sup | 12/31/2026 |



Bailey Taylor

Bailey Taylor

Director, Division of Environmental Quality
Chief Administrator of the Environment
Arkansas Department of Energy and Environment

Certification Number: 005065

ARKANSAS DIVISION OF ENVIRONMENTAL QUALITY
ASBESTOS PROGRAM



**ENVIRONMENTAL PROTECTION
ASSOCIATES (EPA)**

is qualified to perform certain asbestos-related work within the State of Arkansas, under Rule 21 of the Arkansas Pollution Control and Ecology Commission and Ark. Code Ann. § 20-27-1001 et seq., and is hereby licensed as an

Asbestos Abatement Contractor



Bailey Taylor

License Number: 000020-CCL-CT
Expiration Date: November 30, 2026

Bailey Taylor
Director, Division of Environmental Quality
Chief Administrator of the Environment
Arkansas Department of Energy and Environment

State of Arkansas
Commercial Contractors Licensing Board

ENVIRONMENTAL PROTECTION ASSOCIATES OF RUSSELLVILLE, INC.
9 REMINGTON COVE
LITTLE ROCK, AR 72204

ENVIRONMENTAL PROTECTION ASSOCIATES OF RUSSELLVILLE, INC.

This is to Certify That

_____ is duly licensed under the provisions of Ark. Code Ann. § 17-25-101 et. seq. as amended and is entitled to practice Contracting in the State of Arkansas within the following classifications/specialties:

BUILDING
- (COMMERCIAL & RESIDENTIAL)
SPECIALTY
Asbestos
Environmental General

This contractor has an unlimited suggested bid limit.

from May 16, 2025 until June 30, 2026 when this Certificate expires.

Witness our hands of the Board, dated at North Little Rock, Arkansas.



[Handwritten Signature]

CHAIRMAN

[Handwritten Signature]

SECRETARY

May 16, 2025 - dsa



CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)
1/13/2026

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must have ADDITIONAL INSURED provisions or be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

| | |
|-----------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| PRODUCER Sterling Seacrest Pritchard, Inc. 9900 Maumelle Blvd. STE B North Little Rock AR 72113 | CONTACT NAME: Hannah Tryon, CIC, ACSR PHONE (A/C, No, Ext): 501-478-2976 E-MAIL ADDRESS: htryon@sspins.com FAX (A/C, No): |
| | INSURER(S) AFFORDING COVERAGE INSURER A: Arch Specialty Insurance Company INSURER B: Arch Insurance Company INSURER C: Carolina Casualty Insurance INSURER D: INSURER E: INSURER F: |

COVERAGES **CERTIFICATE NUMBER: 1113966921** **REVISION NUMBER:**


THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

| INSR LTR | TYPE OF INSURANCE | ADDL SUBR INSD WVD | POLICY NUMBER | POLICY EFF (MM/DD/YYYY) | POLICY EXP (MM/DD/YYYY) | LIMITS | | | | | |
|----------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------|---------------|-------------------------|-------------------------|-------------------------------------------|------------------------|------------|------------|--------------------------------------------------------------------------------|--|
| A | <input checked="" type="checkbox"/> COMMERCIAL GENERAL LIABILITY <input type="checkbox"/> CLAIMS-MADE <input checked="" type="checkbox"/> OCCUR <input checked="" type="checkbox"/> Blkt Contractual <input checked="" type="checkbox"/> XCU Included GEN'L AGGREGATE LIMIT APPLIES PER: <input type="checkbox"/> POLICY <input checked="" type="checkbox"/> PRO-JECT <input type="checkbox"/> LOC OTHER: | | 12EMP2232806 | 12/31/2025 | 12/31/2026 | EACH OCCURRENCE | \$1,000,000 | | | | |
| | | | | | | DAMAGE TO RENTED PREMISES (Ea occurrence) | \$100,000 | | | | |
| | | | | | | MED EXP (Any one person) | \$5,000 | | | | |
| | | | | | | PERSONAL & ADV INJURY | \$1,000,000 | | | | |
| | | | | | | GENERAL AGGREGATE | \$2,000,000 | | | | |
| | | | | | | PRODUCTS - COMP/OP AGG | \$2,000,000 | | | | |
| | | | | | | | \$ | | | | |
| B | <input checked="" type="checkbox"/> AUTOMOBILE LIABILITY <input checked="" type="checkbox"/> ANY AUTO <input type="checkbox"/> OWNED AUTOS ONLY <input checked="" type="checkbox"/> HIRED AUTOS ONLY <input type="checkbox"/> SCHEDULED AUTOS <input checked="" type="checkbox"/> NON-OWNED AUTOS ONLY | | 11CAB2362901 | 12/31/2025 | 12/31/2026 | COMBINED SINGLE LIMIT (Ea accident) | \$1,000,000 | | | | |
| | | | | | | BODILY INJURY (Per person) | \$ | | | | |
| | | | | | | BODILY INJURY (Per accident) | \$ | | | | |
| | | | | | | PROPERTY DAMAGE (Per accident) | \$ | | | | |
| | | | | | | | \$ | | | | |
| A | <input type="checkbox"/> UMBRELLA LIAB <input checked="" type="checkbox"/> OCCUR <input checked="" type="checkbox"/> EXCESS LIAB <input type="checkbox"/> CLAIMS-MADE DED <input checked="" type="checkbox"/> RETENTION \$ 0 | | 12EMX2232906 | 12/31/2025 | 12/31/2026 | EACH OCCURRENCE | \$5,000,000 | | | | |
| | | | | | | AGGREGATE | \$5,000,000 | | | | |
| | | | | | | | \$ | | | | |
| C | WORKERS COMPENSATION AND EMPLOYERS' LIABILITY ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH) If yes, describe under DESCRIPTION OF OPERATIONS below <table style="float: right;"> <tr><td>Y/N</td><td></td></tr> <tr><td>N</td><td>N/A</td></tr> </table> | Y/N | | N | N/A | | BIN926906213 | 12/31/2025 | 12/31/2026 | <input checked="" type="checkbox"/> PER STATUTE <input type="checkbox"/> OTHER | |
| Y/N | | | | | | | | | | | |
| N | N/A | | | | | | | | | | |
| | | | | | | E.L. EACH ACCIDENT | \$1,000,000 | | | | |
| | | | | | | E.L. DISEASE - EA EMPLOYEE | \$1,000,000 | | | | |
| | | | | | | E.L. DISEASE - POLICY LIMIT | \$1,000,000 | | | | |
| A | Contractors Pollution Liability Professional Liability* Fungus/Spore/Mold Liability* | | 12EMP2232806 | 12/31/2025 | 12/31/2026 | Limit Per Incident Aggregate | 1,000,000 2,000,000 | | | | |


DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (ACORD 101, Additional Remarks Schedule, may be attached if more space is required)
The following applies when required in a written contract or agreement: Certificate holder and owner are included as Additional Insured with respect to General Liability (including ongoing and completed operations), Auto Liability, and Professional Liability; Waiver of subrogation is provided on General Liability, Auto Liability, Umbrella, Professional Liability, and Workers' Compensation. The General Liability policy contains a special endorsement with "Primary and Noncontributory" wording. Umbrella Policy Follows Form in regards to the scheduled underlying General Liability, Auto Liability, Employers' Liability, Contractors Pollution Liability, Fungus/Spore/Mold Liability, and Professional Liability policies shown herein. *Professional Liability and Mold are Claims-Made policies. Subcontractor No.: 25.008-20500 | Project: CHI St. Vincent Morrilton- MRI Addition, 4 Hospital Drive, Morrilton, AR 72110| Amount: \$3,870.00 30 Day Notice of Cancellation applies in favor of Certificate Holder, except 10 days for Non-Payment of Premium.

| | |
|--------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| CERTIFICATE HOLDER <p style="text-align: center;">*** For Bidding Purposes***</p> | CANCELLATION <p style="text-align: center;">SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.</p> |
| | AUTHORIZED REPRESENTATIVE |


ARKANSAS DEPARTMENT OF TRANSPORTATION CONSTRUCTION PLANS: ARDOT CENTRAL OFFICE FIFTH AND SIXTH FLOOR RENOVATION LITTLE ROCK, ARKANSAS PULASKI COUNTY JOB 42-170




ARDOT DIST. 6



COUNTY MAP
SCALE: NO SCALE



VICINITY MAP
SCALE: NO SCALE



LOCATION MAP
SCALE: NO SCALE

| ABBREVIATIONS | | SYMBOL LEGEND | | MATERIAL LEGEND | |
|---------------|-----------------------------|---------------|-----------------------------|-----------------|----------------------------|
| AD | AREA DRAIN | INSUL | GALVANIZED INSULATION | (X) (X) | DOOR AND FRAME |
| ADA | AMERICANS WITH DISABILITIES | INT | INTERIOR | (X) | HARDWARE SET |
| AFG | ABOVE FINISHED FLOOR | LVP | LUXURY VINYL PLANK | (X) | WINDOW TAG |
| ALUM | ALUMINUM | MAX | MAXIMUM | XXXXX | ROOM NAME |
| ANOD | ANODIZED | MBM | METAL BUILDING MANUFACTURER | XXXXX | FINISH |
| BOT | BOTTOM | MECH | MECHANICAL | X-X' | CEILING HEIGHT |
| CJ | CONTROL JOINT | MIN | MINIMUM | | ROOM NUMBER |
| CLG | CEILING | MTL | METAL | X/AX.X | MILLWORK ELEVATION TAG |
| CLR | CLEAR | NIC | NOT IN CONTRACT | (X) | DRAWING NUMBER |
| CMU | CONCRETE MASONRY UNIT | NO | NUMBER | (X) | SHEET NUMBER |
| COL | COLUMN | NOM | NOMINAL | (X) | KEYED PLAN NOTE |
| CONC | CONCRETE | OC | ON CENTER | (X) | KEYED DEMOLITION PLAN NOTE |
| CONT | CONTINUOUS | OPG | OPENING | | |
| DEMO | DEMOLITION | PLUMB | PLUMBING | | |
| DTL | DETAIL | PLAS. LAM. | PLASTIC LAMINATE | | |
| DIA | DIAMETER | PLYWD | PLYWOOD | | |
| DIM | DIMENSION | PVC | POLYVINYL CHLORIDE | | |
| EA | EACH | RBR | RUBBER | | |
| EJ | EXPANSION JOINT | RD | ROOF DRAIN | | |
| ELEC | ELECTRICAL | REQ | REQUIRED | | |
| ELEV | ELEVATION | SIM | SIMILAR | | |
| EQ | EQUAL | SPEC | SPECIFICATION | | |
| EW | ELECTRIC WATER COOLER | SPK | SPRINKLER | | |
| EXIST | EXISTING | STRUCT | STRUCTURAL | | |
| FD | FLOOR DRAIN | T&G | TONGUE AND GROOVE | | |
| FEC | FIRE EXTINGUISHER CABINET | TELE | TELEPHONE | | |
| FEE | FINISHED FLOOR ELEVATION | TLT | TOILET | | |
| FIXT | FIXTURE | TYP | TYPICAL | | |
| FLR | FLOOR | UNO | UNLESS NOTED OTHERWISE | | |
| GA | GAUGE | VCT | VINYL COMPOSITION TILE | | |


| INDEX OF SHEETS | | |
|-----------------|-----|-------------------------------------------------|
| SHEET | NO. | SHEET DESCRIPTION |
| G1.1 | 1 | TITLE SHEET |
| A1.1 | 2 | DEMOLITION PLANS |
| A1.2 | 3 | FLOOR PLANS, SCHEDULES, AND MILLWORK ELEVATIONS |
| A1.3 | 4 | REFLECTED CEILINGS PLANS, SECTIONS AND DETAILS |
| M1.1 | 5 | HVAC PLANS |

ARDOT CENTRAL OFFICE
FIFTH AND SIXTH FLOOR RENOVATION
Little Rock, Arkansas
Pulaski County




DATE: MARCH 9, 2026
JOB NO: 42-170
DRAWN BY: K.B.
REVISIONS:



- NOTES:
1. REMOVE EXISTING WALLS AND DOORS AS SHOWN DASHED.
 2. REMOVE EXISTING WINDOW TRIM AND CASINGS.
 3. EXISTING FIRE ALARM EQUIPMENT AND EMERGENCY ANNUNCIATION SYSTEM SHALL BE PROTECTED DURING DEMOLITION. OWNER SHALL PROVIDE THE REMOVAL AND REINSTALLATION OF ANY EQUIPMENT THAT IS EFFECTED DURING THE DEMOLITION PHASE.
 4. CONTRACTOR SHALL EMPLOY A LICENSED AND BONDED ASBESTOS ABATEMENT COMPANY TO REMOVE EXISTING FLOOR TILES, CEILING GRID, CEILING TILES, LIGHTS, AIR DIFFUSERS, FLEX DUCT BACK TO MAIN DUCT AND ALL MATERIALS CONTAINING ASBESTOS SUCH AS FIREPROOFING AND PIPE INSULATION.
 5. ALL EXISTING EQUIPMENT, DUCTWORK, TIE WIRES, ETC. SHALL BE CLEANED OF ASBESTOS MATERIAL.
 6. ABATEMENT COMPANY SHALL PROVIDE A CLEARANCE LETTER TO THE OWNER STATING WORK PREVIOUSLY DESCRIBED HAS BEEN COMPLETED, THE AIR QUALITY OF THE SPACE MEETS OR EXCEEDS REQUIRED AIR QUALITY STANDARDS AND THE AREA IS ASBESTOS FREE.
 7. ONCE ABATEMENT IS COMPLETED AND CLEARANCE LETTER HAS BEEN ISSUED PROVIDE A SPRAY ON FIREPROOFING RATED FOR TWO HOURS ON STEEL BEAMS AND CONCRETE DECK ABOVE.
 8. PATCH AND REPAIR EXISTING WALLS.
 9. OWNER SHALL PROVIDE ALL ELECTRICAL, PLUMBING AND IT WORK.
 10. EXISTING OFFICE FURNITURE SHALL BE COVERED AND PROTECTED DURING CONSTRUCTION.



NORTH
 1 ALL FIFTH FLOOR DEMOLITION PLAN
 SCALE: 1/8"=1'-0"




NORTH
 2 ALL SIXTH FLOOR DEMOLITION PLAN
 SCALE: 1/8"=1'-0"




ARDOT CENTRAL OFFICE
FIFTH AND SIXTH FLOOR RENOVATION
 Little Rock, Arkansas
 Pulaski County



DATE: MARCH 9, 2026
 JOB NO: 42-170
 DRAWN BY: K.B.
 REVISIONS:



NORTH
1 FIFTH FLOOR FLOOR PLAN
 SCALE: 1/8"=1'-0"




NORTH
2 SIXTH FLOOR FLOOR PLAN
 SCALE: 1/8"=1'-0"


ROOM FINISH SCHEDULE

| MATERIAL | ROOM FINISH MARK | | | | | | | | COMMENTS | |
|------------------------|------------------|---|---|---|---|---|---|---|----------|--|
| | A | B | C | D | E | F | G | H | | |
| FLOOR | | | | | | | | | | |
| CARPET TILE | ● | | | | | | | | | |
| LUXURY VINYL TILE | | ● | ● | | | | | | | |
| BASE | | | | | | | | | | |
| VINYL BASE | | ● | ● | ● | | | | | | |
| WALLS | | | | | | | | | | |
| GYP. BOARD, PAINT WC-1 | ● | ● | | | | | | | | |
| GYP. BOARD, PAINT WC-2 | | | ● | | | | | | | |
| CEILING | | | | | | | | | | |
| 2x2 ACOUSTICAL TILE | ● | ● | ● | | | | | | | |

- DOOR HARDWARE SCHEDULE:**
- HW-1 EACH DOOR SHALL HAVE:
- 3 HINGES STANLEY FB8168 SATIN NICKEL FIVE
 - KNUCKLE BALL BEARING HEAVY WEIGHT FULL MORTISE BUTT HINGE
 - DOOR HANDLES SCHLAGE ND10S RHO (RHODES) PASSAGE LEVER SATIN NICKEL FINISH.
 - WALL STOP ROCKWOOD/ASSA ABLOY 406 SATIN NICKEL FINISH.
- HW-2 EACH DOOR SHALL HAVE:
- 3 HINGES STANLEY FB8168 SATIN NICKEL FIVE
 - KNUCKLE BALL BEARING HEAVY WEIGHT FULL MORTISE BUTT HINGE
 - DOOR HANDLES SCHLAGE ND10S RHO (RHODES) KEYED LOCKSET LEVER SATIN NICKEL FINISH.
 - WALL STOP ROCKWOOD/ASSA ABLOY 406 SATIN NICKEL FINISH.
- COLOR SCHEDULE:**
- WC-1: SHERWIN WILLIAMS SW7015 REPOSE GRAY EGG SHELL
- WC-2: SHERWIN WILLIAMS SW7067 CITYSCAPE EGG SHELL
- DOOR AND TRIM: SHERWIN WILLIAMS SW7067 CITYSCAPE SEMI-GLOSS
- CARPET: PHILADELPHIA COMMERCIAL 92598 STARTLED WIRED 54492 24x24 CARPET TILE QUARTER TURN PHILADELPHIA COMMERCIAL PYLON LL 5M506 CHARCOAL SOAPSTONE 00938 18x36
- LVT: ROPPE 700 SERIES 4" 100 BLACK WILSONART ASSAN NIGHT 7949K-18 VERTICAL GRAIN PATTERN
- BASE: MILLWORK: SOLID SURFACE STARON ASPEN SNOW
- COUNTER TOP: ARMSTRONG PRELUDE XL WHITE
- CEILING GRID: ARMSTRONG FINE FISSURED HIGH NRC
- CEILING TILE: REGULAR 24x24 WHITE



3 DOOR SCHEDULE
 SCALE: 1/4"=1'-0"



4 MILLWORK ELEVATIONS
 SCALE: 1/4"=1'-0"

**ARDOT CENTRAL OFFICE
 FIFTH AND SIXTH FLOOR RENOVATION**
 Little Rock, Arkansas
 Pulaski County



Digitally Signed
 March 9, 2026

DATE: MARCH 9, 2026
 JOB NO: 42-170
 DRAWN BY: K.K.B.
 REVISIONS:

| AIR DISTRIBUTION SCHEDULE | | | | | | | | |
|---------------------------|---------|------------|--------------------------|----------------|----------|--------------|--------|---------------------|
| MARK | SERVICE | PANEL SIZE | DESCRIPTION | INSTALLATION | MATERIAL | MANUFACTURER | MODEL | REMARKS |
| (A) | SUPPLY | 24x24 | CEILING LAY-IN DIFFUSER | LAY-IN CEILING | ALUMINUM | TITUS | TMS | FURNISH WITH DAMPER |
| (B) | SUPPLY | 24x24 | CEILING SURFACE DIFFUSER | GYP. CEILING | ALUMINUM | TITUS | TDC-AA | PLASTER RING, OBD |
| (C) | RETURN | 24x24 | LAY-IN EGGRATE DIFFUSER | LAY-IN CEILING | ALUMINUM | TITUS | 50F | |

| MECHANICAL SYMBOL LEGEND | | | |
|--------------------------|-------------------------------------|--------|-----------------------------|
| SYMBOL | DESCRIPTION | SYMBOL | DESCRIPTION |
| | SUPPLY DIFFUSER | | THERMOSTAT |
| | RETURN GRILLE | | DUCT MOUNTED SMOKE DETECTOR |
| | WALL RETURN GRILLE | | SUPPLY DUCT W/ LINER |
| | DIRECTION OF AIRFLOW - RETURN | | CONNECT TO EXISTING |
| | DIRECTION OF AIRFLOW - SUPPLY | | 3/4" UNDERCUT |
| | EXISTING TAP LOCATION ON EXSTG DUCT | | EXISTING DUCT |

GENERAL NOTES:


- DEMOLISH ALL EXISTING ROUND RUNOUTS, DIFFUSER TROFFERS, ETC.
- ENLARGE OR PATCH EXISTING RUN-OUT TAPS. CONTRACTOR'S OPTION. EXISTING TAP LOCATIONS ARE BASED ON ORIGINAL DESIGN AND MAY VARY SLIGHTLY.
- HARVEST AND PROTECT EXISTING THERMOSTATS TO REINSTALL IN LOCATIONS SHOWN.

KEYED NOTES:


- REUSE EXISTING TAP. MATCH DIFFUSER NECK TO TAP SIZE. REINSULATE AND SEAL WITH PRO-SEAL.

ABBREVIATIONS


- TOD TOP OF DUCT
- BOD BOTTOM OF DUCT
- EXSTG EXISTING
- AFF ABOVE FINISHED FLOOR
- RL/RS REFRIGERANT LIQUID/SUCTION
- CD CONDENSATE DRAIN
- NG NATURAL GAS



1 FIFTH FLOOR MECHANICAL PLAN
SCALE: 1/8"=1'-0"



2 SIXTH FLOOR MECHANICAL PLAN
SCALE: 1/8"=1'-0"



1 TYPICAL DIFFUSER BRANCH CONNECTION DETAIL
SCALE: N.T.S.

**ARDOT CENTRAL OFFICE
FIFTH AND SIXTH FLOOR RENOVATION**
Little Rock, Arkansas
Pulaski County

STATE OF ARKANSAS
LICENSED PROFESSIONAL ENGINEER
No. 13866
JERIC M. TYLER
Digitally Signed
March 9, 2026

DATE: MARCH 9, 2026
JOB NO: 42-170
DRAWN BY: K.B.
REVISIONS: